

CORAL HARBOUR, NU, Canada

WMO: 719150

Lat: 64.188N

Lon: 83.349W

Elev: 62

StdP: 100.58

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-40.6	-39.0	-44.3	0.0	-40.5	-43.1	0.1	-38.9	15.7	-23.0	13.3	-24.4	4.1	330	1.044

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	19.1	12.8	16.6	11.5	14.7	10.5	13.4	18.0	12.1	15.9	10.9	14.1	5.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.9	8.1	14.4	9.7	7.5	13.4	8.7	7.0	12.3	37.7	18.1	34.4	16.0	31.5	14.1	17.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.5	10.6	DB	-42.4	23.1	2.3	1.8	-44.0	24.4	-45.3	25.5	-46.6	26.5	-48.3	27.8	(4)
(5)			WB	-42.4	15.5	2.2	1.2	-44.0	16.3	-45.3	17.0	-46.6	17.7	-48.2	18.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.1	-28.9	-29.4	-24.6	-15.5	-5.6	3.6	10.4	8.3	2.3	-5.3	-14.7	-23.1	(6)
(7)		DBStd	14.82	6.46	5.70	6.67	5.99	4.69	3.56	2.94	2.72	3.09	4.59	7.05	7.58	(7)
(8)		HDD10.0	7396	1207	1103	1072	764	485	196	31	67	231	473	741	1026	(8)
(9)		HDD18.3	10377	1466	1336	1330	1014	743	443	247	311	481	732	991	1284	(9)
(10)		CDD10.0	59	0	0	0	0	0	3	42	14	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	5	0	0	0	0	0	0	5	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.1	5.1	5.0	5.0	4.9	5.1	4.9	4.6	4.8	5.2	5.5	5.8	5.5	(14)
(15)	Precipitation	PrecAvg	303	9	9	12	17	17	27	42	55	40	38	24	14	(15)
(16)		PrecMax	547	23	32	58	66	44	84	112	128	100	166	50	37	(16)
(17)		PrecMin	195	0	0	0	3	3	0	2	15	4	5	7	1	(17)
(18)		PrecStd	65	6	7	9	10	10	18	28	25	22	26	12	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-6.6	-11.1	-5.4	0.5	4.4	18.2	23.8	20.6	12.7	2.7	-0.4	-1.8	(19)
(20)			MCWB	-7.1	-11.5	-5.9	0.0	2.5	12.0	15.1	13.4	8.6	2.3	-0.6	-2.0	(20)
(21)		2%	DB	-12.4	-15.7	-9.0	-2.2	2.3	14.1	20.6	16.8	10.1	1.7	-1.8	-6.0	(21)
(22)			MCWB	-13.0	-16.3	-9.6	-2.9	1.2	9.3	13.5	11.7	7.1	1.3	-2.0	-6.3	(22)
(23)		5%	DB	-16.7	-18.6	-11.6	-4.2	1.4	11.4	18.3	14.9	8.2	1.1	-2.8	-8.5	(23)
(24)			MCWB	-17.2	-19.1	-12.1	-4.8	0.5	7.7	12.4	10.8	6.4	0.7	-3.1	-8.8	(24)
(25)		10%	DB	-19.3	-20.9	-14.4	-6.3	0.5	9.5	16.2	13.2	6.8	0.5	-4.5	-11.9	(25)
(26)			MCWB	-19.7	-21.3	-15.0	-6.9	-0.2	6.4	11.3	9.9	5.4	0.1	-4.9	-12.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.0	-11.5	-5.8	0.3	2.7	12.3	15.4	14.3	9.7	2.5	-0.5	-1.9	(27)
(28)			MCDWB	-6.5	-11.3	-5.4	0.6	4.0	17.7	22.1	17.5	11.6	2.6	-0.4	-1.8	(28)
(29)		2%	WB	-12.9	-16.2	-9.5	-2.8	1.4	9.7	14.0	12.5	7.7	1.4	-1.9	-6.4	(29)
(30)			MCDWB	-12.3	-15.7	-9.0	-2.2	2.2	13.5	19.5	16.0	9.1	1.6	-1.8	-6.1	(30)
(31)		5%	WB	-17.2	-19.0	-12.1	-4.8	0.7	7.9	12.9	11.3	6.6	0.8	-3.1	-8.8	(31)
(32)			MCDWB	-16.8	-18.6	-11.6	-4.3	1.3	11.1	17.4	14.0	8.0	1.0	-2.9	-8.5	(32)
(33)		10%	WB	-19.7	-21.3	-14.9	-6.9	-0.1	6.5	11.7	10.2	5.6	0.2	-4.8	-12.4	(33)
(34)			MCDWB	-19.3	-20.9	-14.4	-6.3	0.5	9.3	15.7	12.7	6.8	0.4	-4.5	-12.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.0	7.0	8.4	9.0	6.1	6.0	8.3	7.0	5.3	5.4	7.7	7.6	(35)
(36)			MCDBR	8.7	8.7	9.1	7.3	5.0	10.0	12.3	10.1	8.1	3.8	6.7	8.8	(36)
(37)			MCWBR	8.6	8.6	9.0	7.1	4.4	6.4	6.5	6.0	6.0	3.8	6.9	8.8	(37)
(38)		5% WB	MCDWB	8.7	8.6	9.1	7.3	4.5	9.7	11.1	9.0	7.3	3.8	6.9	8.8	(38)
(39)			MCWBR	8.5	8.5	9.0	7.1	4.1	6.4	6.3	5.9	5.7	3.9	7.1	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.194	0.228	0.275	0.337	0.339	0.326	0.359	0.346	0.317	0.273	0.173	0.158	(40)	
(41)		taud	1.864	2.147	2.125	1.978	2.111	2.365	2.399	2.441	2.423	2.225	1.934	1.892	(41)	
(42)		Ebn at Noon	353	710	808	820	863	891	845	825	771	626	399	186	(42)	
(43)		Edh at Noon	29	58	93	138	133	106	100	88	72	54	25	11	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.16	0.90	2.64	4.82	5.56	5.85	5.43	3.62	2.08	0.69	0.20	0.06	(44)	
(45)		RadStd	0.02	0.08	0.14	0.19	0.49	0.56	0.50	0.29	0.21	0.06	0.03	0.00	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page