

BACCARO POINT, NS, Canada

WMO: 719200

Lat: **43.4508N**Lon: **65.4717W**Elev: **5**StdP: **101.27**Time Zone: **-4.00 (NAA)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.4	-10.2	-15.8	0.9	-10.5	-13.8	1.1	-8.6	21.9	-0.2	19.4	-0.6	7.5	340	0.805

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	20.0	17.7	18.9	17.1	17.9	16.6	18.6	19.3	17.7	18.4	16.9	17.6	5.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.2	18.8	17.4	12.5	18.0	16.6	11.8	17.3	52.6	19.5	49.9	18.5	47.6	17.7	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	16.0	13.9	DB	-15.4	23.8	2.4	1.3	-17.2	24.7	-18.6	25.5	-20.0	26.2	-21.7	27.2	(4)
(5)			WB	-15.0	21.0	2.2	1.2	-16.6	21.9	-17.8	22.6	-19.0	23.3	-20.6	24.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-1.2	-1.4	0.8	4.4	7.9	11.7	13.8	14.8	14.3	11.0	6.5	2.1	(6)	
	DBStd	6.57	4.81	4.03	3.25	2.21	1.88	1.98	1.72	1.94	2.19	3.09	3.70	4.20	(7)	
	HDD10.0	1578	346	318	286	167	70	6	0	0	1	26	113	246	(8)	
	HDD18.3	4100	604	551	544	417	324	200	141	111	122	227	355	504	(9)	
	CDD10.0	522	0	0	0	0	4	56	118	149	129	57	7	1	(10)	
	CDD18.3	2	0	0	0	0	0	0	0	1	1	0	0	0	(11)	
	CDH23.3	2	0	0	0	0	0	1	0	2	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.6	8.2	8.0	7.8	7.1	6.0	5.3	4.7	4.6	5.4	7.0	7.4	7.9	(14)	
(15) Precipitation	PrecAvg	1364	131	97	128	116	100	86	89	88	119	131	140	141	(15)	
	PrecMax	1686	238	156	304	184	210	136	181	168	337	323	251	224	(16)	
	PrecMin	1033	55	53	42	42	32	26	21	26	43	47	61	75	(17)	
	PrecStd	185	43	33	67	39	49	34	42	43	65	63	52	36	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	7.9	8.8	11.8	15.7	20.8	21.2	22.1	21.0	18.5	15.1	11.9	(19)	
		MCWB	9.4	7.3	6.7	8.5	11.4	14.8	17.9	18.9	18.4	16.3	14.4	11.5	(20)	
	2%	DB	7.8	6.1	7.0	9.5	13.1	17.5	18.9	19.9	19.6	17.1	13.5	10.5	(21)	
		MCWB	7.4	5.7	6.0	7.4	10.7	14.4	17.1	18.2	18.0	16.3	12.7	10.1	(22)	
	5%	DB	6.7	4.9	5.9	8.3	11.6	15.5	17.5	18.8	18.6	16.2	12.4	9.3	(23)	
		MCWB	6.2	4.3	5.0	7.0	9.9	13.8	16.3	17.4	17.2	15.4	11.6	8.9	(24)	
	10%	DB	5.4	3.9	4.9	7.4	10.6	14.3	16.5	17.8	17.6	15.4	11.5	8.0	(25)	
		MCWB	4.8	3.3	4.2	6.3	9.3	13.0	15.6	16.6	16.4	14.4	10.7	7.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	7.5	7.9	9.7	12.8	16.7	18.9	20.4	19.7	17.6	14.7	11.5	(27)	
		MCDB	8.7	7.6	8.4	10.3	14.2	18.6	19.9	21.4	20.0	17.9	14.9	11.6	(28)	
	2%	WB	7.2	5.8	6.4	8.2	11.3	15.1	17.6	18.8	18.4	16.7	13.0	10.2	(29)	
		MCDB	7.4	6.0	6.8	8.7	12.4	16.5	18.4	19.5	18.9	17.1	13.3	10.4	(30)	
	5%	WB	6.0	4.5	5.3	7.5	10.5	14.2	16.6	17.8	17.5	15.9	11.8	9.0	(31)	
		MCDB	6.2	4.7	5.7	8.1	11.4	15.4	17.3	18.5	18.1	16.3	12.2	9.3	(32)	
	10%	WB	4.5	3.4	4.3	6.6	9.7	13.3	15.8	17.0	16.6	14.9	10.9	7.7	(33)	
		MCDB	4.9	3.8	4.8	7.4	10.5	14.4	16.5	17.7	17.2	15.5	11.4	8.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	5.8	5.1	4.3	4.3	4.8	4.9	5.0	5.0	5.1	5.3	6.0	(35)	
		MCDBR	7.3	6.3	6.0	5.9	6.5	7.7	7.0	6.5	6.0	5.7	5.5	6.1	(36)	
	5% WB	MCWBR	7.8	6.4	5.6	4.6	4.6	5.2	5.2	4.5	5.0	4.8	5.7	6.5	(37)	
		MCWBR	7.3	6.3	5.8	5.1	5.9	6.9	6.3	5.7	5.3	4.8	5.4	6.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.317	0.316	0.340	0.362	0.387	0.414	0.427	0.409	0.369	0.351	0.334	0.318	(40)	
		taud	2.435	2.468	2.436	2.410	2.386	2.338	2.331	2.375	2.445	2.501	2.503	2.474	(41)	
	Ebn at Noon		811	883	902	903	886	859	843	847	859	831	788	775	(42)	
		Edh at Noon	75	86	100	111	117	124	123	114	99	83	71	67	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.35	2.26	3.57	4.48	5.05	5.60	5.44	5.05	4.27	2.77	1.57	1.12	(44)	
	RadStd		0.12	0.23	0.25	0.41	0.62	0.56	0.38	0.29	0.23	0.30	0.18	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-118	N/A	N/A	(46)
(47)	Regional (11 neighbors)	N/A	N/A	+0.84	N/A	+0.42	+0.48	N/A	N/A	+65	+5	(47)

Nomenclature: See separate page