

ENNADAI LAKE, NU, Canada

WMO: 719230

Lat: 61.132N

Lon: 100.884W

Elev: 1158

StdP: 14.09

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -40.3	(c) -37.0	(d) -47.5	(e) 0.4	(f) -40.2	(g) -43.9	(h) 0.4	(i) -36.7	(j) 41.7	(k) -12.4	(l) 37.6	(m) -11.0	(n) 13.0	(o) 320	(p) 1.034

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 15.7	(c) 75.4	(d) 59.9	(e) 71.3	(f) 57.9	(g) 67.6	(h) 56.6	(i) 61.9	(j) 70.7	(k) 59.7	(l) 68.2	(m) 57.9	(n) 65.5	(o) 11.7	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.3	75.8	65.3	56.3	70.4	63.0	54.3	65.3	60.9	28.3	71.2	26.7	68.5	25.5	65.6	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
36.8	32.5	29.1	-43.4	81.9	3.0	2.9	-45.6	84.0	-47.3	85.7	-49.0	87.3	-51.2	89.4
			-42.6	65.5	4.0	2.7	-45.4	67.4	-47.7	68.9	-50.0	70.4	-52.9	72.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	-17.8	-14.1	-5.9	10.2	27.4	48.2	57.4	53.4	42.1	25.0	3.1	-12.0
	DBStd	28.89	13.28	12.64	14.77	13.87	11.28	9.10	6.58	6.31	8.01	9.44	11.84	13.50
	HDD50	12074	2101	1796	1732	1194	701	141	11	36	257	776	1406	1923
	HDD65	17079	2566	2216	2197	1644	1164	507	249	364	688	1240	1856	2388
	CDD50	489	0	0	0	0	2	87	240	140	20	0	0	0
	CDD65	19	0	0	0	0	0	3	13	3	0	0	0	0
	CDH74	159	0	0	0	0	1	43	99	16	0	0	0	0
	CDH80	13	0	0	0	0	0	4	8	1	0	0	0	0
Wind	WSAvg	14.5	14.4	15.1	15.3	15.1	14.4	13.5	13.0	14.0	16.0	15.8	14.1	12.9
Precipitation	PrecAvg	12.8	0.4	0.2	0.4	0.6	0.9	1.5	2.3	1.8	2.0	1.5	0.6	0.4
	PrecMax	18.5	1.7	0.6	1.7	1.1	2.9	2.8	4.7	3.6	7.0	4.1	1.1	0.8
	PrecMin	8.7	0.1	0.0	0.0	0.1	0.1	0.3	0.7	0.8	0.5	0.4	0.2	0.1
	PrecStd	2.4	0.4	0.2	0.4	0.3	0.7	0.6	1.2	0.7	1.5	0.9	0.3	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	24.0	34.7	41.9	62.2	79.0	81.3	76.1	65.5	51.0	32.0	22.8
		MCWB	20.3	23.4	31.9	38.0	48.8	58.9	62.3	61.3	55.8	45.7	31.4	22.1
	2%	DB	13.7	16.1	28.6	37.3	54.5	73.6	77.0	70.9	61.0	44.2	27.8	18.0
		MCWB	13.2	15.3	26.8	34.6	45.8	56.5	61.2	59.0	53.0	41.6	27.2	17.5
	5%	DB	8.6	10.2	22.5	34.6	47.7	68.4	72.9	67.3	57.1	40.5	24.1	13.4
		MCWB	8.3	9.6	21.4	32.6	41.8	55.1	58.9	57.4	50.9	38.8	23.6	12.9
	10%	DB	1.8	5.2	16.5	30.8	42.4	63.5	69.4	63.6	53.5	36.8	20.3	8.6
		MCWB	1.3	4.8	15.7	29.3	38.4	52.5	57.6	55.8	49.3	35.6	19.8	8.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.2	23.6	31.9	38.3	51.4	63.1	66.1	64.0	57.0	46.7	31.4	22.2
		MCDB	20.4	24.2	34.3	41.4	58.5	71.6	76.5	73.6	63.1	50.4	31.9	23.0
	2%	WB	13.4	15.7	27.0	34.9	46.0	59.0	62.9	60.6	54.1	41.9	27.3	17.3
		MCDB	13.7	16.3	28.4	37.0	53.9	69.9	71.9	67.7	59.2	44.2	27.7	17.7
	5%	WB	8.1	9.7	21.4	32.7	42.1	55.7	60.7	58.5	51.9	38.7	23.7	12.7
		MCDB	8.6	10.2	22.5	34.5	47.7	66.2	69.9	65.0	56.0	40.2	24.1	13.0
	10%	WB	1.3	4.8	15.7	29.3	38.4	53.1	58.8	56.7	49.6	35.6	19.9	8.0
		MCDB	1.7	5.2	16.5	30.9	42.5	62.7	67.1	62.3	53.0	36.7	20.3	8.4
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.8	15.9	17.0	14.5	17.5	15.7	13.2	11.1	8.9	11.9	12.6
		MCDBR	21.9	19.9	19.0	17.3	22.2	24.6	21.2	18.7	17.0	12.0	14.4	20.8
		MCWBR	21.1	19.7	17.7	15.2	14.8	12.0	8.8	9.4	10.4	9.6	13.6	19.7
	5% WB	MCDBR	21.8	20.0	19.1	16.9	21.1	22.3	18.4	16.4	15.7	11.6	13.9	19.7
		MCWBR	21.0	19.8	17.9	15.0	14.6	12.4	9.2	9.7	10.6	9.5	13.7	19.5
Clear-Sky Solar Irradiance	taub		0.191	0.239	0.253	0.307	0.317	0.345	0.357	0.341	0.306	0.262	0.192	0.152
	taud		2.080	2.200	2.260	2.155	2.320	2.411	2.408	2.449	2.538	2.409	2.102	1.948
	Ebn at Noon		186	243	281	280	287	280	273	269	262	234	181	148
	Edh at Noon		12	21	28	38	35	33	32	29	22	17	11	8
All-Sky Solar Radiation	RadAvg		114	397	968	1627	1896	1852	1675	1251	760	312	134	56
	RadStd		10	23	67	106	128	190	113	96	85	43	17	5

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page