

RESOLUTE BAY, NU, Canada

WMO: 719240

Lat: 74.720N

Lon: 94.970W

Elev: 68

StdP: 100.51

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.5	-39.9	-44.8	0.0	-41.2	-43.7	0.1	-39.7	17.0	-26.8	15.9	-25.8	4.1	330	1.204

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	12.0	8.6	10.1	7.3	8.4	6.2	8.7	11.7	7.5	9.8	6.3	8.2	5.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.5	6.0	9.8	5.4	5.6	8.7	4.5	5.3	7.6	26.5	11.8	23.8	10.0	21.4	8.2	13.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.7	12.3	DB	-43.3	14.2	2.2	2.8	-44.9	16.2	-46.1	17.9	-47.3	19.4	-48.9	21.4	(4)
(5)			WB	-43.3	10.4	1.9	1.5	-44.7	11.5	-45.8	12.3	-46.9	13.2	-48.3	14.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-14.8	-30.8	-32.0	-29.4	-20.8	-9.7	0.6	4.8	2.5	-3.5	-12.2	-20.8	-27.1
	DBStd	13.97	4.85	4.85	6.24	5.42	4.94	3.29	3.11	3.15	3.36	5.53	5.76	5.77
	HDD10.0	9043	1266	1175	1222	925	609	283	166	231	406	687	923	1151
	HDD18.3	12082	1524	1408	1480	1175	868	533	421	489	656	946	1173	1409
	CDD10.0	3	0	0	0	0	0	0	3	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.5	5.0	4.9	5.1	5.2	5.3	5.4	5.6	5.6	6.3	6.3	5.9	5.1
Precipitation	PrecAvg	152	3	3	5	8	9	12	26	33	22	14	8	5
	PrecMax	218	10	10	21	33	29	30	81	80	56	42	24	17
	PrecMin	86	0	0	0	0	0	0	0	0	1	3	0	0
	PrecStd	33	3	3	5	7	7	8	19	18	13	8	6	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-11.4	-16.6	-9.8	-6.3	1.4	11.1	15.6	12.4	4.8	-0.7	-5.4	-8.2
		MCWB	-11.5	-17.2	-10.5	-7.0	0.1	7.4	10.1	8.9	3.1	-1.2	-5.8	-8.8
	2%	DB	-19.0	-19.6	-14.1	-8.7	0.0	8.3	13.3	10.2	2.7	-2.0	-7.9	-13.1
		MCWB	-19.4	-20.0	-14.6	-9.3	-0.9	5.7	9.3	7.6	1.7	-2.4	-8.3	-13.5
	5%	DB	-21.9	-22.4	-17.0	-10.7	-1.3	6.3	11.5	8.6	1.5	-3.0	-10.1	-16.0
		MCWB	-22.2	-22.8	-17.5	-11.3	-2.1	4.4	8.3	6.6	0.9	-3.4	-10.5	-16.5
	10%	DB	-23.9	-24.7	-20.2	-13.2	-2.7	4.7	9.7	7.2	0.6	-4.3	-12.7	-18.6
		MCWB	-24.2	-25.1	-20.6	-13.8	-3.4	3.2	7.1	5.6	0.0	-4.8	-13.1	-19.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.9	-17.2	-10.6	-6.8	0.6	7.8	10.8	9.0	3.2	-1.0	-5.9	-8.7
		MCDB	-11.7	-16.7	-10.0	-6.4	1.1	10.4	14.3	11.9	4.3	-0.7	-5.5	-8.0
	2%	WB	-19.4	-20.0	-14.5	-9.3	-0.9	5.8	9.5	7.8	1.8	-2.3	-8.3	-13.5
		MCDB	-19.0	-19.6	-14.2	-8.8	-0.2	8.1	12.9	9.8	2.4	-2.1	-8.0	-13.1
	5%	WB	-22.3	-22.7	-17.5	-11.4	-2.1	4.5	8.3	6.7	1.0	-3.3	-10.5	-16.4
		MCDB	-22.0	-22.5	-17.0	-10.7	-1.3	6.1	11.3	8.3	1.5	-3.0	-10.0	-16.0
	10%	WB	-24.2	-25.0	-20.5	-13.8	-3.4	3.3	7.2	5.7	0.1	-4.7	-13.1	-19.0
		MCDB	-23.9	-24.7	-20.1	-13.2	-2.7	4.5	9.6	7.1	0.5	-4.3	-12.7	-18.6
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.5	5.8	6.0	5.0	3.8	4.9	3.9	3.4	4.9	5.5	5.8
		MCDBR	7.4	7.6	6.7	6.8	5.0	5.6	7.4	6.0	3.5	4.3	6.5	7.4
		MCWBR	7.3	7.5	6.7	6.5	4.5	4.0	4.9	4.2	3.0	4.4	6.4	7.2
	5% WB	MCDBR	7.4	7.5	6.7	6.8	4.7	5.3	7.3	5.7	3.3	4.4	6.5	7.4
		MCWBR	7.3	7.3	6.7	6.5	4.3	3.9	5.0	4.2	3.0	4.5	6.4	7.2
Clear-Sky Solar Irradiance	taub	N/A	0.149	0.220	0.281	0.304	0.303	0.303	0.291	0.249	0.162	N/A	N/A	
	taud	N/A	1.877	2.174	2.089	2.127	2.296	2.470	2.523	2.419	1.914	N/A	N/A	
	Ebn at Noon	0	343	728	801	840	864	854	816	710	277	0	0	
	Edh at Noon	0	18	56	99	113	100	81	66	46	15	0	0	
All-Sky Solar Radiation	RadAvg	0.00	0.09	1.36	4.09	6.38	6.72	5.03	2.77	1.10	0.23	0.00	0.00	
	RadStd	0.00	0.01	0.08	0.16	0.33	0.70	0.55	0.34	0.15	0.04	0.00	0.00	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.68	+1.56	+1.00	N/A	N/A	N/A	-245	-244	N/A	N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page