

BAKER LAKE AP, NU, Canada

WMO: 719260

Lat: 64.299N

Lon: 96.078W

Elev: 19

StdP: 101.10

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.1	-39.7	-44.6	0.0	-40.5	-43.6	0.1	-39.5	18.5	-29.9	17.3	-29.2	4.1	320	1.036

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	22.3	14.5	19.4	13.3	17.1	12.2	15.3	20.5	13.9	18.4	12.7	16.6	5.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	9.3	17.0	11.6	8.5	15.7	10.4	7.8	14.5	43.0	20.6	39.2	18.3	35.9	16.7	20.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.8	12.4	DB	-42.5	26.9	1.9	2.3	-43.9	28.6	-45.0	30.0	-46.1	31.3	-47.5	33.0	(4)
(5)			WB	-42.5	17.8	1.9	1.5	-43.9	18.8	-45.0	19.7	-46.0	20.5	-47.4	21.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-10.3	-30.5	-30.5	-25.7	-16.4	-5.7	5.5	12.2	10.6	3.8	-5.6	-17.9	-25.4
	DBStd	16.24	6.42	5.78	6.95	6.39	5.29	4.06	3.33	3.11	3.85	5.04	6.91	6.77
	HDD10.0	7567	1254	1135	1106	791	487	143	16	29	188	484	837	1097
	HDD18.3	10469	1513	1368	1364	1041	745	384	192	241	436	743	1087	1355
	CDD10.0	142	0	0	0	0	0	9	83	47	3	0	0	0
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	48	0	0	0	0	0	7	33	8	0	0	0	0
	CDH26.7	5	0	0	0	0	0	1	3	1	0	0	0	0
Wind	WSAvg	5.6	6.2	6.3	5.8	6.0	5.6	4.5	4.5	5.0	5.4	6.0	6.0	6.2
Precipitation	PrecAvg	266	9	7	12	15	16	23	38	42	42	32	19	10
	PrecMax	386	28	27	39	40	42	59	100	93	94	87	60	33
	PrecMin	153	0	0	0	1	0	0	1	5	8	5	0	1
	PrecStd	58	7	6	8	9	11	15	25	25	21	18	13	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.2	-13.4	-6.0	1.0	6.5	23.4	26.6	24.1	17.1	5.7	-0.9	-4.5
		MCWB	-10.7	-14.1	-6.4	0.4	4.0	14.6	16.6	16.3	11.9	4.6	-1.4	-4.9
	2%	DB	-15.5	-16.1	-9.5	-1.7	3.7	17.4	23.8	20.2	13.5	3.2	-3.3	-9.5
		MCWB	-16.1	-16.7	-10.0	-2.4	2.1	11.3	15.0	13.7	10.1	2.3	-3.7	-9.9
	5%	DB	-17.7	-18.5	-12.2	-4.2	2.2	14.5	21.0	17.7	11.0	1.8	-4.9	-12.4
		MCWB	-18.1	-19.0	-12.7	-4.8	1.1	9.6	13.9	12.6	8.6	1.2	-5.4	-12.9
	10%	DB	-20.5	-21.3	-14.8	-6.5	1.1	12.0	18.6	15.9	9.4	0.9	-7.0	-15.0
		MCWB	-20.9	-21.7	-15.2	-7.1	0.2	8.1	12.8	11.9	7.6	0.3	-7.4	-15.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.7	-13.7	-6.4	0.6	4.3	14.8	17.5	16.8	12.8	4.8	-1.1	-4.7
		MCDB	-10.4	-13.3	-6.1	1.0	6.1	22.4	24.8	22.3	16.4	5.6	-0.8	-4.5
	2%	WB	-16.0	-16.6	-9.9	-2.2	2.2	11.8	15.9	14.8	10.6	2.5	-3.6	-9.9
		MCDB	-15.6	-16.2	-9.6	-1.7	3.4	16.7	21.8	18.5	12.8	3.0	-3.4	-9.6
	5%	WB	-18.2	-19.0	-12.6	-4.8	1.2	9.9	14.6	13.5	9.0	1.2	-5.3	-12.8
		MCDB	-17.7	-18.5	-12.2	-4.2	2.0	14.1	19.7	16.7	10.7	1.7	-4.9	-12.5
	10%	WB	-20.9	-21.7	-15.2	-7.0	0.4	8.2	13.3	12.2	7.7	0.4	-7.4	-15.5
		MCDB	-20.6	-21.3	-14.8	-6.5	1.1	11.6	18.0	15.1	9.2	0.9	-7.0	-15.0
Mean Daily Temperature Range		MDBR	6.3	6.3	7.4	8.1	6.1	8.1	9.7	8.0	6.1	5.2	6.7	6.7
	5% DB	MCDBR	9.3	9.8	9.3	8.9	6.2	13.6	14.0	11.8	9.7	4.9	7.0	9.5
		MCWBR	9.3	9.6	9.2	8.6	5.1	8.5	7.3	6.7	6.7	4.6	7.1	9.4
	5% WB	MCDBR	9.4	9.8	9.5	8.9	5.9	13.1	12.7	10.5	9.1	4.9	7.2	9.4
		MCWBR	9.3	9.6	9.4	8.6	4.9	8.5	7.3	6.7	6.7	4.7	7.2	9.4
Clear-Sky Solar Irradiance	taub	0.161	0.231	0.256	0.323	0.349	0.332	0.349	0.334	0.305	0.261	0.166	0.149	
	taud	1.927	2.151	2.228	2.060	2.132	2.452	2.456	2.494	2.506	2.258	1.925	1.920	
	Ebn at Noon	444	703	845	839	852	886	858	839	794	648	405	203	
	Edh at Noon	26	57	83	126	130	97	95	83	66	51	24	10	
All-Sky Solar Radiation	RadAvg	0.17	0.94	2.73	5.08	6.39	5.73	5.41	3.84	2.12	0.75	0.25	0.06	
	RadStd	0.02	0.06	0.12	0.22	0.39	0.44	0.42	0.33	0.24	0.12	0.04	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page