

POOL'S ISLAND, NL, Canada

WMO: 719310

Lat: 49.1127N

Lon: 53.5825W

Elev: 63

StdP: 14.66

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.9	5.8	-5.4	4.1	3.7	-1.8	5.0	6.8	46.6	29.1	42.7	29.2	15.3	280	0.885

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.9	75.9	64.6	72.2	63.7	69.0	62.5	67.4	72.4	65.5	69.8	63.5	67.6	18.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	94.6	70.2	63.7	88.4	67.9	61.9	82.9	65.7	31.9	72.3	30.4	69.9	28.9	67.6	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.4	34.8	30.1	DB	-2.7	82.6	5.6	3.1	-6.7	84.9	-9.9	86.7	-13.0	88.4	-17.1	90.7	(4)
(5)			WB	-3.5	70.5	5.7	1.8	-7.6	71.8	-11.0	72.8	-14.2	73.9	-18.3	75.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.3	22.9	22.0	26.3	33.9	41.3	49.2	59.3	60.5	54.5	45.6	37.3	29.4	(6)	
	DBStd	14.74	7.94	8.39	7.55	5.19	6.08	7.14	6.70	5.26	5.83	5.67	6.04	6.76	(7)	
	HDD50	4437	840	783	736	482	281	100	8	1	22	161	383	640	(8)	
	HDD65	9061	1305	1203	1201	932	734	475	199	157	318	600	832	1105	(9)	
	CDD50	898	0	0	0	0	12	77	297	328	156	26	2	0	(10)	
	CDD65	45	0	0	0	0	0	2	22	19	2	0	0	0	(11)	
	CDH74	193	0	0	0	0	1	27	90	67	8	0	0	0	(12)	
	CDH80	24	0	0	0	0	0	3	13	8	0	0	0	0	(13)	
(14) Wind	WSAvg	15.3	17.8	17.1	16.8	15.6	14.3	13.3	12.5	12.7	14.3	15.2	16.4	17.2	(14)	
(15) Precipitation	PrecAvg	45.3	3.6	3.2	3.3	3.5	3.2	3.0	3.6	3.9	4.5	4.4	4.2	4.4	(15)	
	PrecMax	51.7	6.8	4.9	5.6	8.5	5.2	5.6	6.5	5.4	8.0	7.7	7.0	6.5	(16)	
	PrecMin	41.5	1.9	1.6	1.5	1.7	1.3	1.3	1.8	1.4	1.5	2.2	2.7	2.8	(17)	
	PrecStd	3.5	1.5	0.8	1.0	1.7	1.1	1.1	1.2	1.1	1.5	1.5	1.1	1.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.5	43.1	45.5	55.0	69.4	77.9	81.3	80.3	74.4	66.0	57.3	50.5	(19)	
		MCWB	45.6	41.9	42.0	46.5	57.5	63.7	67.4	67.1	64.9	58.7	54.3	48.7	(20)	
	2%	DB	40.9	39.0	41.0	47.8	60.7	70.1	76.2	75.3	69.3	60.3	52.2	43.8	(21)	
		MCWB	40.3	37.8	38.5	42.9	52.6	60.9	65.1	64.6	62.1	56.6	50.5	42.4	(22)	
	5%	DB	36.5	35.7	37.6	43.6	55.1	64.5	72.3	71.6	66.1	56.9	49.2	40.3	(23)	
		MCWB	35.3	34.7	35.8	40.1	49.0	58.2	63.9	64.1	60.3	53.2	47.4	39.2	(24)	
	10%	DB	33.4	33.4	34.9	40.7	50.5	60.2	68.9	68.4	63.2	54.0	46.0	37.7	(25)	
		MCWB	32.5	32.5	33.5	38.0	46.6	55.2	62.7	62.8	58.8	51.4	44.5	36.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.2	42.1	42.9	49.0	59.4	66.8	70.7	69.6	67.1	61.2	54.7	48.6	(27)	
		MCDB	45.8	42.8	44.0	51.7	66.7	73.9	78.3	74.7	71.3	63.2	56.8	49.8	(28)	
	2%	WB	39.9	38.1	39.0	43.8	53.7	62.3	67.8	67.3	64.2	57.5	50.9	42.8	(29)	
		MCDB	40.4	38.8	40.5	47.2	58.6	68.2	72.9	72.1	67.3	59.7	51.8	43.5	(30)	
	5%	WB	35.5	34.9	36.0	40.6	49.9	58.9	65.6	65.4	61.7	54.1	47.8	39.2	(31)	
		MCDB	36.2	35.5	37.4	43.0	54.4	63.9	69.8	69.7	64.6	55.8	48.8	40.0	(32)	
	10%	WB	32.7	32.6	33.9	38.2	46.8	55.4	63.4	63.6	59.6	51.7	44.7	36.9	(33)	
		MCDB	33.2	33.2	34.7	40.2	50.3	59.9	67.8	67.4	62.4	53.5	45.7	37.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	12.6	11.4	9.4	11.6	12.2	12.7	10.9	11.4	9.8	9.2	9.8	(35)	
		MCDBR	17.3	13.9	13.8	15.3	21.3	21.3	18.9	16.7	16.3	14.4	13.4	13.4	(36)	
		MCWBR	17.0	14.0	12.6	11.3	14.0	13.2	10.4	9.1	10.4	11.5	13.0	13.9	(37)	
	5% WB	MCDBR	16.6	13.4	12.8	14.1	19.5	20.2	16.7	14.5	13.9	13.2	13.3	12.9	(38)	
		MCWBR	17.0	13.7	12.2	11.5	14.2	13.7	11.0	9.6	10.6	11.8	13.2	13.6	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.306	0.300	0.332	0.362	0.373	0.399	0.416	0.395	0.368	0.344	0.317	0.308	(40)	
	taud		2.297	2.358	2.269	2.324	2.399	2.355	2.356	2.413	2.471	2.480	2.462	2.303	(41)	
	Ebn at Noon		234	270	278	281	281	274	267	267	264	251	233	215	(42)	
	Edh at Noon		23	27	35	37	36	38	37	34	29	24	20	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		273	514	889	1276	1514	1620	1652	1394	1061	628	341	215	(44)	
	RadStd		23	54	93	134	135	137	167	101	75	74	38	20	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page