

HAY RIVER, NT, Canada

WMO: 719350

Lat: 60.8394N

Lon: 115.7816W

Elev: 165

StdP: 99.36

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.8	-34.4	-41.2	0.1	-36.7	-38.9	0.1	-34.3	9.3	-16.3	8.4	-17.5	1.9	240	0.729

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	27.2	16.9	25.1	16.1	23.1	15.3	18.1	24.6	17.2	23.1	16.3	21.7	4.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.7	11.4	20.1	14.7	10.7	19.5	13.8	10.1	18.8	51.8	24.6	48.9	23.1	46.3	21.7	21.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.9	7.0	-39.5	31.0	2.1	1.6	-41.0	32.2	-42.2	33.1	-43.4	34.0	-45.0	35.2		
(5)			-39.6	19.9	2.1	1.1	-41.1	20.6	-42.3	21.3	-43.5	21.9	-45.0	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.0	-21.4	-18.9	-13.8	-3.0	5.8	13.0	16.7	14.8	9.3	1.0	-10.6	-18.1	(6)
(7)		DBStd	14.91	8.07	7.42	8.94	7.55	5.73	4.45	3.38	3.58	4.32	4.48	6.46	7.93	(7)
(8)		HDD10.0	4923	973	808	738	391	155	21	1	4	64	281	617	873	(8)
(9)		HDD18.3	7462	1231	1042	996	639	388	167	74	119	271	537	867	1131	(9)
(10)		CDD10.0	543	0	0	0	1	26	111	207	153	43	2	0	0	(10)
(11)		CDD18.3	41	0	0	0	0	1	7	22	10	1	0	0	0	(11)
(12)		CDH23.3	393	0	0	0	1	17	78	182	104	11	1	0	0	(12)
(13)		CDH26.7	74	0	0	0	0	2	12	37	22	1	0	0	0	(13)
(14)	Wind	WSAvg	3.2	2.9	2.9	3.1	3.4	3.6	3.1	3.1	3.2	3.6	3.4	3.1	(14)	
(15)	Precipitation	PrecAvg	373	24	19	19	18	24	36	48	43	40	37	36	23	(15)
(16)		PrecMax	526	51	43	56	76	60	129	110	100	124	112	114	63	(16)
(17)		PrecMin	239	2	2	1	1	0	4	6	3	5	4	10	6	(17)
(18)		PrecStd	88	12	10	12	18	14	28	28	24	23	26	24	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.5	4.4	9.8	18.8	25.6	28.5	30.0	29.4	24.9	16.2	6.6	2.2	(19)
(20)			MCWB	0.3	1.2	4.2	9.5	13.4	16.6	18.0	18.2	15.6	10.0	2.8	-0.6	(20)
(21)		2%	DB	-2.1	-0.9	5.9	13.9	22.0	25.6	27.5	26.2	21.2	11.8	1.7	-1.1	(21)
(22)			MCWB	-3.6	-2.7	1.9	6.5	11.9	15.5	17.4	17.0	13.6	7.1	0.2	-2.5	(22)
(23)		5%	DB	-6.4	-5.0	3.0	10.4	18.6	23.2	25.3	23.7	18.6	9.2	-0.2	-4.4	(23)
(24)			MCWB	-7.2	-6.0	0.0	4.8	10.1	14.4	16.8	16.1	12.3	5.9	-1.0	-5.2	(24)
(25)		10%	DB	-10.3	-8.4	0.0	7.3	15.3	20.8	23.2	21.4	16.2	7.2	-2.1	-7.0	(25)
(26)			MCWB	-10.8	-9.2	-2.0	3.1	8.6	13.6	16.1	15.2	11.5	4.9	-2.8	-7.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.2	1.4	4.3	9.9	14.3	18.1	19.6	19.4	16.4	10.7	3.0	-0.1	(27)
(28)			MCDWB	2.5	4.3	9.3	18.7	24.0	25.1	26.9	27.1	23.3	15.4	6.3	1.9	(28)
(29)		2%	WB	-3.7	-2.7	2.0	7.0	12.2	16.5	18.4	17.8	14.5	7.8	0.3	-2.5	(29)
(30)			MCDWB	-2.2	-0.9	5.4	13.2	20.8	23.2	24.9	24.1	19.5	10.9	1.3	-1.1	(30)
(31)		5%	WB	-7.2	-6.1	0.0	5.0	10.5	15.4	17.5	16.8	13.1	6.2	-1.1	-5.1	(31)
(32)			MCDWB	-6.6	-5.0	2.8	10.0	18.1	21.6	23.5	22.2	17.4	8.9	-0.1	-4.4	(32)
(33)		10%	WB	-10.8	-9.2	-2.1	3.2	8.8	14.2	16.7	15.8	11.9	4.8	-2.8	-7.6	(33)
(34)			MCDWB	-10.3	-8.4	0.0	7.1	14.9	19.8	22.2	20.6	15.7	7.1	-2.1	-6.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	9.6	10.6	10.3	10.1	9.9	9.2	8.7	6.3	6.6	7.5	(35)	
(36)			MCDBR	10.7	13.2	12.9	14.1	15.8	13.7	12.9	13.4	12.9	10.4	7.2	9.2	(36)
(37)			MCWBR	9.9	11.9	9.7	8.7	8.2	6.5	6.0	6.6	7.3	6.8	6.2	8.3	(37)
(38)		5% WB	MCDWB	10.8	12.9	12.3	13.5	15.2	11.9	10.9	11.8	11.4	9.4	7.0	9.1	(38)
(39)			MCWBR	10.0	11.6	9.2	8.5	8.3	6.3	5.7	6.4	6.9	6.4	6.2	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.210	0.241	0.267	0.321	0.353	0.356	0.378	0.351	0.313	0.274	0.209	0.160	(40)	
(41)		taud	2.101	2.277	2.294	2.342	2.407	2.423	2.396	2.499	2.552	2.504	2.160	1.995	(41)	
(42)		Ebn at Noon	561	778	871	877	871	873	840	840	819	741	561	478	(42)	
(43)		Edh at Noon	38	62	86	101	103	103	104	87	69	51	35	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.37	1.24	3.02	4.86	5.83	6.12	5.54	4.32	2.72	1.18	0.39	0.19	(44)	
(45)		RadStd	0.03	0.08	0.17	0.28	0.39	0.49	0.32	0.22	0.23	0.12	0.05	0.02	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	+0.54	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	+1.30	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page