

LADY FRANKLIN POINT, NU, Canada

WMO: 719370

Lat: 68.475N

Lon: 113.221W

Elev: 52

StdP: 14.67

Time Zone: -7.00 (NAM)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-37.9	-35.7	-41.5	0.5	-33.9	-40.2	0.5	-33.4	41.5	-15.8	39.5	-15.7	8.1	90	1.109

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	58.0	51.0	54.9	49.4	52.5	48.0	50.8	55.2	48.7	52.8	46.9	50.4	11.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
47.8	49.2	53.0	46.0	45.9	50.5	43.8	42.2	49.0	20.8	55.4	19.6	52.9	18.6	50.5	57.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
35.8	30.8	27.5	-39.9	62.7	3.6	5.0	-42.5	66.3	-44.6	69.2	-46.7	72.0	-49.3	75.7
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-20.4	-20.4	-12.8	0.8	19.2	37.3	45.7	44.0	35.6	19.6	-0.9	-12.2	(6)
	DBStd	25.88	10.11	10.31	10.06	10.58	9.16	5.91	5.71	5.26	5.69	9.12	12.27	11.30	(7)
	HDD50	14104	2183	1972	1948	1476	956	383	157	199	432	941	1528	1929	(8)
	HDD65	19544	2648	2392	2413	1926	1421	832	600	652	882	1406	1978	2394	(9)
	CDD50	36	0	0	0	0	0	1	23	12	0	0	0	0	(10)
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
	WSAvg	12.7	12.4	13.0	12.9	12.6	13.3	13.4	11.9	11.8	13.4	13.7	12.3	12.2	(14)
	PrecAvg	4.8	0.2	0.1	0.1	0.2	0.2	0.4	0.8	0.9	0.7	0.7	0.3	0.1	(15)
(16) Precipitation	PrecMax	8.7	0.8	0.5	0.6	0.7	0.7	1.3	2.0	2.0	2.3	2.0	0.9	0.2	(16)
	PrecMin	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.0	0.1	0.0	0.0	(17)
	PrecStd	1.6	0.2	0.1	0.2	0.2	0.2	0.3	0.6	0.4	0.6	0.4	0.2	0.1	(18)
	PrecStd	1.6	0.2	0.1	0.2	0.2	0.2	0.3	0.6	0.4	0.6	0.4	0.2	0.1	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	8.3	17.6	29.5	38.4	57.1	64.3	60.9	50.6	37.7	29.2	21.7	(19)
		MCWB	12.7	7.5	17.0	28.6	37.2	50.0	54.4	54.5	47.6	35.8	29.2	21.0	(20)
	2%	DB	7.4	3.1	11.6	23.5	36.0	51.5	59.3	56.8	47.4	35.3	26.6	12.5	(21)
		MCWB	7.1	2.2	10.8	22.8	34.9	47.5	50.8	52.4	44.8	34.1	26.4	12.0	(22)
	5%	DB	1.6	-1.7	6.9	19.6	34.3	47.8	56.4	53.8	45.1	33.0	22.9	8.9	(23)
		MCWB	1.1	-2.5	6.2	18.9	33.4	43.6	49.3	50.4	43.2	32.0	22.1	8.4	(24)
	10%	DB	-6.3	-5.5	3.1	15.9	32.6	45.4	54.0	51.4	43.2	30.9	17.0	5.8	(25)
		MCWB	-7.0	-6.2	2.5	14.9	32.0	41.7	48.2	48.2	41.8	30.0	16.3	5.1	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.5	9.4	14.4	26.0	37.7	49.8	52.2	54.9	45.1	35.6	22.8	20.2	(27)
		MCDB	15.0	10.2	15.1	26.6	38.5	54.3	58.8	60.4	46.8	36.3	23.1	21.1	(28)
	2%	WB	9.2	2.3	10.4	22.1	35.5	46.2	50.4	51.9	43.5	33.7	18.9	11.5	(29)
		MCDB	9.7	3.0	11.5	22.8	36.4	49.7	56.3	55.4	44.8	34.5	19.7	11.9	(30)
	5%	WB	1.4	-2.6	4.6	17.3	33.2	43.1	48.6	49.4	41.9	32.0	13.3	8.1	(31)
		MCDB	2.0	-1.8	5.1	18.0	33.8	46.3	53.7	52.1	43.1	32.7	14.1	8.6	(32)
	10%	WB	-7.7	-6.5	0.3	12.8	31.9	41.1	47.2	47.0	40.2	29.9	8.0	5.1	(33)
		MCDB	-7.0	-5.8	0.9	13.5	32.6	44.1	51.6	49.2	41.0	30.7	8.8	5.8	(34)
(36) Mean Daily Temperature Range	MDBR		9.2	9.9	11.1	12.4	10.1	7.8	9.8	7.2	5.2	7.4	8.9	9.6	(35)
	5% DB	MCDBR	14.0	16.7	14.8	13.1	8.9	12.2	14.5	10.7	7.0	5.4	8.8	12.6	(36)
		MCWBR	14.0	14.5	15.1	12.9	8.2	7.6	8.6	7.9	5.8	4.2	9.5	10.4	(37)
	5% WB	MCDBR	14.0	14.3	14.0	12.8	8.3	9.9	12.6	10.3	6.8	4.1	10.4	10.0	(38)
		MCWBR	14.0	14.0	14.0	12.7	7.8	7.9	8.6	7.7	5.8	4.2	10.3	9.9	(39)
(40) Clear-Sky Solar Irradiance	taub		0.154	0.211	0.246	0.291	0.326	0.336	0.363	0.344	0.305	0.240	0.158	N/A	(40)
	taud		1.886	2.059	2.189	2.120	2.129	2.321	2.354	2.463	2.499	2.245	1.921	N/A	(41)
	Ebn at Noon		35	188	254	270	271	273	260	253	236	176	28	0	(42)
	Edh at Noon		2	14	24	35	39	34	32	26	19	12	2	0	(43)
(44) All-Sky Solar Radiation	RadAvg		8	148	675	1349	1943	2052	1721	1157	561	167	22	0	(44)
	RadStd		1	16	44	111	152	120	121	122	67	22	2	0	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page