

LADY FRANKLIN POINT, NU, Canada

WMO: 719370

Lat: 68.475N

Lon: 113.221W

Elev: 16

StdP: 101.13

Time Zone: -7.00 (NAM)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-38.9	-37.6	-40.8	0.1	-36.6	-40.1	0.1	-36.3	18.5	-26.6	17.7	-26.5	3.6	90	1.109

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	14.4	10.6	12.7	9.7	11.4	8.9	10.4	12.9	9.3	11.5	8.3	10.2	5.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	7.0	11.6	7.8	6.6	10.3	6.5	6.0	9.4	30.5	13.0	27.8	11.6	25.4	10.3	14.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.0	13.8	12.3	DB	-40.0	17.1	2.0	2.8	-41.4	19.1	-42.6	20.7	-43.7	22.2	-45.2	24.3	(p)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(p)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.4	-29.1	-29.1	-24.9	-17.3	-7.1	2.9	7.6	6.7	2.0	-6.9	-18.3	-24.6
	DBStd	14.38	5.61	5.73	5.59	5.88	5.09	3.28	3.17	2.92	3.16	5.07	6.82	6.28
	HDD10.0	7836	1213	1096	1082	820	531	213	87	111	240	523	849	1072
	HDD18.3	10858	1471	1329	1341	1070	789	462	333	362	490	781	1099	1330
	CDD10.0	20	0	0	0	0	0	1	13	7	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.7	5.5	5.8	5.8	5.7	5.9	6.0	5.3	5.3	6.0	6.1	5.5	5.4
Precipitation	PrecAvg	121	4	3	3	4	4	11	21	24	18	17	7	3
	PrecMax	222	21	13	14	19	18	32	52	51	59	52	23	5
	PrecMin	40	0	0	0	0	0	0	3	4	1	3	0	0
	PrecStd	40	5	3	4	5	4	8	15	11	15	11	6	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.2	-13.2	-8.0	-1.4	3.6	13.9	18.0	16.0	10.3	3.2	-1.6	-5.7
		MCWB	-10.7	-13.6	-8.3	-1.9	2.9	10.0	12.4	12.5	8.7	2.1	-1.6	-6.1
	2%	DB	-13.7	-16.1	-11.3	-4.7	2.2	10.8	15.2	13.8	8.5	1.8	-3.0	-10.8
		MCWB	-13.9	-16.6	-11.8	-5.1	1.6	8.6	10.4	11.3	7.1	1.2	-3.1	-11.1
	5%	DB	-16.9	-18.7	-13.9	-6.9	1.3	8.8	13.6	12.1	7.3	0.6	-5.1	-12.8
		MCWB	-17.2	-19.1	-14.4	-7.3	0.8	6.4	9.6	10.2	6.2	0.0	-5.5	-13.1
	10%	DB	-21.3	-20.8	-16.1	-9.0	0.4	7.4	12.2	10.8	6.2	-0.6	-8.4	-14.6
		MCWB	-21.6	-21.2	-16.4	-9.5	0.0	5.4	9.0	9.0	5.4	-1.1	-8.7	-14.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-9.7	-12.5	-9.8	-3.3	3.2	9.9	11.2	12.7	7.3	2.0	-5.1	-6.5
		MCDB	-9.4	-12.1	-9.4	-3.0	3.6	12.4	14.9	15.8	8.2	2.4	-4.9	-6.1
	2%	WB	-12.7	-16.5	-12.0	-5.5	1.9	7.9	10.2	11.1	6.4	0.9	-7.3	-11.4
		MCDB	-12.4	-16.1	-11.4	-5.1	2.5	9.8	13.5	13.0	7.1	1.4	-6.8	-11.2
	5%	WB	-17.0	-19.2	-15.2	-8.2	0.7	6.2	9.2	9.7	5.5	0.0	-10.4	-13.3
		MCDB	-16.7	-18.8	-14.9	-7.8	1.0	8.0	12.0	11.1	6.2	0.4	-9.9	-13.0
	10%	WB	-22.0	-21.4	-17.6	-10.6	-0.1	5.1	8.4	8.4	4.5	-1.1	-13.3	-14.9
		MCDB	-21.7	-21.0	-17.3	-10.3	0.3	6.7	10.9	9.6	5.0	-0.7	-12.9	-14.5
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.5	6.2	6.9	5.6	4.4	5.4	4.0	2.9	4.1	4.9	5.3
		MCDBR	7.8	9.3	8.2	7.3	4.9	6.8	8.1	5.9	3.9	3.0	4.9	7.0
		MCWBR	7.8	8.0	8.4	7.2	4.5	4.2	4.8	4.4	3.2	2.3	5.3	5.8
	5% WB	MCDBR	7.8	8.0	7.8	7.1	4.6	5.5	7.0	5.7	3.8	2.3	5.8	5.6
		MCWBR	7.8	7.8	7.8	7.1	4.3	4.4	4.8	4.3	3.2	2.4	5.7	5.5
Clear-Sky Solar Irradiance	taub	0.154	0.211	0.246	0.291	0.326	0.336	0.363	0.344	0.305	0.240	0.158	N/A	
	taud	1.886	2.059	2.189	2.120	2.129	2.321	2.354	2.463	2.499	2.245	1.921	N/A	
	Ebn at Noon	111	594	801	850	855	861	820	799	743	555	89	0	
	Edh at Noon	7	45	75	110	124	106	100	81	59	37	5	0	
All-Sky Solar Radiation	RadAvg	0.03	0.47	2.13	4.25	6.12	6.47	5.42	3.65	1.77	0.53	0.07	0.00	
	RadStd	0.00	0.05	0.14	0.35	0.48	0.38	0.38	0.38	0.21	0.07	0.01	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page