

CAPE PARRY, NT, Canada

WMO: 719480

Lat: 70.167N

Lon: 124.717W

Elev: 284

StdP: 14.55

Time Zone: -7.00 (NAM)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-34.4	-31.4	-40.0	0.6	-33.5	-38.6	0.6	-32.3	42.7	-9.1	40.2	-10.9	9.2	250	1.150

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	60.7	53.8	56.0	51.2	52.1	48.5	53.8	59.2	51.0	54.9	48.5	51.3	10.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.1	54.1	56.2	48.1	50.2	53.4	46.1	46.5	50.5	22.5	59.0	20.9	55.2	19.5	51.4	62.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.9	35.1	30.1	DB	-36.8	67.4	3.9	5.4	-39.6	71.3	-41.9	74.4	-44.1	77.5	-47.0	81.4	(4)
(5)			WB	-35.3	57.0	2.7	3.8	-37.3	59.8	-38.8	62.0	-40.3	64.2	-42.3	67.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.1	-14.1	-14.7	-11.3	2.8	20.8	35.8	43.3	42.6	34.8	22.1	1.9	-8.4		
	DBStd	23.61	10.73	11.33	11.07	10.47	8.59	6.10	6.92	6.42	5.67	7.29	10.76	10.59		
	HDD50	13505	1988	1812	1900	1416	905	428	232	247	457	866	1443	1811		
	HDD65	18938	2453	2232	2365	1866	1370	876	674	695	907	1331	1893	2276		
	CDD50	42	0	0	0	0	0	2	23	17	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	14.0	14.1	14.6	13.5	14.5	15.2	14.0	12.1	12.5	14.4	15.2	14.0	13.7		
	PrecAvg	7.6	0.3	0.3	0.4	0.3	0.4	0.6	1.2	1.5	1.1	0.7	0.5	0.3		
	PrecMax	10.9	1.1	0.9	0.9	0.9	1.2	1.2	2.2	4.3	2.2	1.6	1.4	0.7		
(15) Precipitation	PrecMin	5.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.6	0.3	0.2	0.1	0.1		
	PrecStd	1.5	0.2	0.2	0.2	0.2	0.3	0.3	0.5	0.7	0.5	0.4	0.3	0.2		
	DB	18.8	19.0	20.6	32.4	43.7	61.4	67.9	66.0	52.1	37.8	29.0	20.8			
	MCWB	18.0	18.0	20.1	30.4	40.5	51.4	57.2	57.4	47.9	36.5	27.8	20.0			
	2% DB	11.6	12.1	13.7	25.8	37.0	52.8	62.5	59.4	47.4	34.2	23.4	16.2			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	11.0	11.2	13.0	24.5	35.2	46.9	54.0	54.0	44.3	33.1	22.5	15.6			
	5% DB	5.7	7.5	9.3	21.8	33.6	48.5	57.7	55.0	44.6	32.2	19.6	11.8			
	MCWB	5.0	6.8	8.4	20.6	32.4	44.4	51.6	51.6	42.4	31.1	18.7	11.2			
	10% DB	1.4	2.1	4.8	17.3	31.3	44.6	53.4	51.3	42.0	30.4	16.4	7.1			
	MCWB	0.7	1.3	4.2	16.3	30.5	41.7	49.1	48.9	40.4	29.2	15.5	6.5			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	17.0	20.4	22.7	31.8	36.7	50.0	57.6	57.8	48.1	36.8	23.5	22.3			
	MCDB	17.5	21.0	23.1	33.9	38.0	56.9	66.3	65.0	51.8	37.6	24.1	22.8			
	2% WB	13.0	13.7	17.3	24.1	33.3	46.5	54.4	54.2	44.3	34.6	19.0	16.5			
	MCDB	13.8	14.3	17.7	25.3	34.1	51.1	61.3	58.8	46.2	35.3	19.8	16.9			
	5% WB	6.0	9.6	12.1	19.6	31.7	44.1	51.5	51.3	42.1	32.6	14.7	13.0			
(30) Mean Daily Temperature Range	MCDB	6.5	10.3	12.7	20.6	32.5	47.8	56.6	54.4	43.9	33.5	15.5	13.5			
	10% WB	1.2	3.9	7.9	15.8	29.4	41.7	49.1	48.7	40.4	30.4	10.4	7.8			
	MCDB	1.9	4.6	8.7	16.6	30.2	44.5	52.7	50.4	41.7	31.2	11.2	8.5			
	5% DB	9.1	9.5	10.1	10.8	7.9	8.2	9.6	7.4	5.1	5.4	8.0	8.4			
	MCDBR	14.8	15.4	13.4	12.6	10.2	17.3	18.0	14.1	9.5	5.1	8.4	12.4			
(36) Clear-Sky Solar Irradiance	MCWBR	14.9	16.7	13.1	14.3	8.9	11.4	11.7	11.3	8.0	4.9	9.1	12.3			
	5% WB	15.2	17.5	13.4	15.7	9.2	14.9	16.9	15.6	8.8	5.8	8.8	12.6			
	MCWBR	15.0	17.4	13.3	15.1	8.5	11.2	11.4	11.2	7.1	5.5	8.8	12.5			
	taub	N/A	0.192	0.238	0.293	0.328	0.344	0.340	0.327	0.294	0.224	N/A	N/A			
	taud	N/A	2.022	2.166	2.073	2.088	2.282	2.444	2.531	2.538	2.180	N/A	N/A			
(42) All-Sky Solar Radiation	Ebn at Noon	0	177	249	263	267	267	266	257	235	158	0	0			
	Edh at Noon	0	12	23	36	40	34	29	23	17	10	0	0			
(44) All-Sky Solar Radiation	RadAvg	0	116	626	1399	1918	2038	1687	1014	496	133	0	0			
	RadStd	0	14	23	59	148	188	181	116	47	19	0	0			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+1.89	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+1.01	+2.12	+2.77	N/A	N/A	N/A	-398	-387	N/A	N/A

Nomenclature: See separate page