

TERRACE, BC, Canada

WMO: 719510

Lat: 54.470N

Lon: 128.580W

Elev: 713

StdP: 14.32

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.2	(c) 7.3	(d) -13.6	(e) 2.7	(f) 4.8	(g) -6.8	(h) 3.9	(i) 11.3	(j) 33.8	(k) 19.6	(l) 30.5	(m) 17.7	(n) 20.0	(o) 20	(p) 0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.2	(c) 82.8	(d) 63.0	(e) 78.3	(f) 61.3	(g) 74.0	(h) 59.5	(i) 64.4	(j) 79.3	(k) 62.5	(l) 75.5	(m) 60.8	(n) 71.3	(o) 7.1	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.9	76.2	67.7	57.3	72.0	65.7	56.0	68.5	64.1	29.8	79.7	28.4	75.5	27.2	71.5	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 26.3	(b) 23.3	(c) 20.8	(e) -0.2	(f) 89.4	(g) 5.4	(h) 3.8	(i) -4.1	(j) 92.1	(k) -7.2	(l) 94.3	(m) -10.2	(n) 96.4	(o) -14.1	(p) 99.1		
(4) 26.3	(5) 23.3	(6) 20.8	(7) -0.2	(8) 89.4	(9) 5.4	(10) 3.8	(11) -4.1	(12) 92.1	(13) -7.2	(14) 94.3	(15) -10.2	(16) 96.4	(17) -14.1	(18) 99.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	27.3	30.1	35.4	43.1	51.6	57.4	61.6	61.4	53.8	43.5	33.7	27.4	
	DBStd	14.16	10.06	7.42	6.41	5.11	6.13	5.88	5.82	5.55	5.09	4.70	6.60	8.57	
	HDD50	3403	705	558	452	216	53	3	0	0	18	209	488	701	
	HDD65	7773	1170	978	917	656	417	242	141	143	337	668	938	1166	
	CDD50	1189	0	0	0	10	102	225	360	354	132	6	0	0	
	CDD65	84	0	0	0	0	1	14	36	32	1	0	0	0	
	CDH74	938	0	0	0	2	35	177	392	316	16	0	0	0	
	CDH80	259	0	0	0	0	2	49	127	80	1	0	0	0	
Wind	WSAvg	8.4	10.8	9.5	8.4	8.1	7.7	8.2	7.8	7.2	7.2	7.6	8.4	9.5	
Precipitation	PrecAvg	54.3	7.4	5.4	3.5	2.9	2.0	1.8	2.2	2.5	4.1	8.2	7.1	7.0	
	PrecMax	64.9	16.1	10.6	7.6	7.0	3.8	3.2	5.8	6.4	10.6	14.3	14.0	14.8	
	PrecMin	35.6	2.1	0.0	0.7	0.4	0.6	0.4	0.3	0.4	1.7	2.5	2.2	1.8	
	PrecStd	6.4	3.2	2.6	1.8	1.7	0.9	0.7	1.3	1.5	2.0	2.8	3.2	3.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.8	44.5	57.9	68.7	78.3	86.1	90.1	86.7	76.2	59.5	49.0	42.8	
		MCWB	42.6	39.8	45.6	51.2	57.5	62.6	65.5	65.0	62.0	52.7	47.1	41.5	
	2%	DB	40.5	41.3	49.8	61.4	72.9	78.9	83.3	81.8	69.8	55.0	46.0	39.5	
		MCWB	39.2	37.9	41.8	47.1	55.1	60.3	63.4	63.3	58.6	51.0	44.6	38.4	
	5%	DB	38.5	39.5	45.7	56.4	68.3	73.6	78.1	77.3	65.1	52.4	43.0	37.5	
		MCWB	37.4	37.1	39.8	44.6	53.2	58.1	61.8	61.9	56.5	48.9	41.9	36.5	
	10%	DB	36.9	37.9	42.9	52.6	63.5	68.5	73.0	72.4	61.5	50.1	40.9	35.8	
		MCWB	35.9	35.9	38.5	43.2	51.1	56.1	60.1	60.1	54.8	47.5	39.7	34.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	41.0	46.6	52.9	59.0	64.4	67.2	67.0	63.2	55.4	47.7	41.8
			MCDB	43.8	42.9	54.0	65.5	76.2	81.0	86.1	82.8	73.6	57.8	48.9	42.7
2%		WB	39.6	39.0	43.2	48.2	56.3	61.3	64.6	64.4	60.1	52.0	44.6	38.5	
		MCDB	40.3	40.2	48.2	57.5	70.0	76.2	80.1	78.8	67.2	54.2	45.8	39.2	
5%		WB	37.6	37.5	41.0	46.0	54.2	58.9	62.6	62.5	57.7	49.6	42.1	36.7	
		MCDB	38.2	38.9	44.4	54.1	65.6	71.3	75.7	75.3	63.1	51.4	42.9	37.3	
10%		WB	36.1	36.2	39.2	44.2	52.2	56.8	60.6	60.8	55.8	47.7	40.0	35.0	
		MCDB	36.7	37.7	42.1	50.7	61.4	67.0	71.2	70.4	60.2	49.5	40.7	35.6	
Mean Daily Temperature Range	5% DB	MDBR	5.9	8.2	11.1	15.2	17.5	16.3	16.2	16.0	12.6	8.9	5.7	5.4	
		MCDBR	6.7	9.4	16.2	23.3	26.8	26.7	27.2	26.4	20.0	12.8	7.6	6.6	
		MCWBR	6.0	7.0	10.0	12.3	12.6	11.4	11.1	11.1	10.5	8.6	6.2	6.0	
	5% WB	MCDBR	6.7	8.4	13.9	19.1	23.1	23.5	23.8	23.0	17.2	10.8	7.5	6.5	
		MCWBR	6.1	6.7	9.3	11.0	11.4	10.3	10.2	10.1	9.6	8.1	6.4	6.0	
Clear-Sky Solar Irradiance	taub	0.273	0.282	0.314	0.352	0.382	0.384	0.369	0.361	0.334	0.320	0.289	0.262		
	taud	2.240	2.297	2.225	2.178	2.244	2.334	2.434	2.471	2.544	2.502	2.303	2.211		
	Ebn at Noon	214	258	272	276	273	274	276	272	267	244	206	190		
	Edh at Noon	18	25	34	41	40	37	33	30	25	21	17	15		
All-Sky Solar Radiation	RadAvg	162	408	662	1132	1424	1547	1453	1290	808	439	193	134		
	RadStd	22	82	126	83	163	138	198	99	111	78	38	21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+1.01	+0.79	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	+0.88	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page