

TERRACE, BC, Canada

WMO: 719510

Lat: 54.470N

Lon: 128.580W

Elev: 217

StdP: 98.74

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -16.6	(c) -13.7	(d) -25.3	(e) 0.4	(f) -15.1	(g) -21.6	(h) 0.6	(i) -11.5	(j) 15.1	(k) -6.9	(l) 13.6	(m) -8.0	(n) 8.9	(o) 20	(p) 0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	28.2	17.2	25.7	16.3	23.3	15.3	18.0	26.3	17.0	24.2	16.0	21.9	3.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	10.9	19.9	14.1	10.3	18.7	13.3	9.8	17.8	51.5	26.5	48.2	24.2	45.4	21.9	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.8	10.4	9.3	-17.9	31.9	3.0	2.1	-20.0	33.4	-21.8	34.6	-23.4	35.8	-25.6	37.3		
			-18.6	19.9	2.9	0.8	-20.7	20.5	-22.4	21.0	-24.1	21.5	-26.2	22.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-2.6	-1.1	1.9	6.2	10.9	14.1	16.4	16.3	12.1	6.4	1.0	-2.6		
	DBStd	7.87	5.59	4.12	3.56	2.84	3.40	3.26	3.23	3.08	2.83	2.61	3.67	4.76		
	HDD10.0	1891	392	310	251	120	29	2	0	0	10	116	271	389		
	HDD18.3	4318	650	543	509	364	232	134	78	79	187	371	521	648		
	CDD10.0	661	0	0	0	6	57	125	200	197	73	3	0	0		
	CDD18.3	47	0	0	0	0	1	8	20	18	1	0	0	0		
	CDH23.3	521	0	0	0	1	19	98	218	176	9	0	0	0		
	CDH26.7	144	0	0	0	0	1	27	71	44	1	0	0	0		
(14) Wind	WSAvg	3.7	4.8	4.2	3.8	3.6	3.4	3.7	3.5	3.2	3.2	3.4	3.7	4.2		
(15) Precipitation	PrecAvg	1378	187	136	88	73	52	46	55	63	103	209	180	178		
	PrecMax	1648	409	269	192	177	96	82	147	162	270	362	356	376		
	PrecMin	905	54	1	18	9	16	11	8	10	42	63	57	46		
	PrecStd	162	82	65	45	43	23	18	33	39	50	70	81	75		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	6.9	14.4	20.4	25.7	30.1	32.3	30.4	24.6	15.3	9.4	6.0		
		MCWB	5.9	4.4	7.6	10.7	14.1	17.0	18.6	18.3	16.7	11.5	8.4	5.3		
	2%	DB	4.7	5.2	9.9	16.3	22.7	26.1	28.5	27.7	21.0	12.8	7.8	4.2		
		MCWB	4.0	3.3	5.5	8.4	12.9	15.7	17.4	17.4	14.8	10.6	7.0	3.5		
	5%	DB	3.6	4.2	7.6	13.5	20.1	23.1	25.6	25.2	18.4	11.3	6.1	3.1		
		MCWB	3.0	2.8	4.3	7.0	11.8	14.5	16.6	16.6	13.6	9.4	5.5	2.5		
	10%	DB	2.7	3.3	6.0	11.4	17.5	20.3	22.8	22.4	16.4	10.1	5.0	2.1		
		MCWB	2.2	2.2	3.6	6.2	10.6	13.4	15.6	15.6	12.7	8.6	4.3	1.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.0	8.1	11.6	15.0	18.0	19.5	19.4	17.3	13.0	8.7	5.5		
		MCDB	6.5	6.1	12.2	18.6	24.5	27.2	30.0	28.2	23.1	14.3	9.4	5.9		
	2%	WB	4.2	3.9	6.2	9.0	13.5	16.3	18.1	18.0	15.6	11.1	7.0	3.6		
		MCDB	4.6	4.6	9.0	14.2	21.1	24.6	26.7	26.0	19.6	12.3	7.7	4.0		
	5%	WB	3.1	3.0	5.0	7.8	12.3	14.9	17.0	16.9	14.3	9.8	5.6	2.6		
		MCDB	3.4	3.8	6.9	12.3	18.7	21.8	24.3	24.1	17.3	10.8	6.1	2.9		
	10%	WB	2.3	2.3	4.0	6.8	11.2	13.8	15.9	16.0	13.2	8.7	4.4	1.7		
		MCDB	2.6	3.2	5.6	10.4	16.3	19.5	21.8	21.3	15.7	9.7	4.8	2.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.3	4.5	6.1	8.4	9.7	9.0	9.0	8.9	7.0	4.9	3.2	3.0		
		MCDBR	3.7	5.2	9.0	13.0	14.9	14.8	15.1	14.7	11.1	7.1	4.2	3.7		
		MCWBR	3.3	3.9	5.5	6.8	7.0	6.3	6.1	6.2	5.8	4.8	3.5	3.3		
		MCWBR	3.7	4.7	7.7	10.6	12.8	13.0	13.2	12.8	9.5	6.0	4.1	3.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.273	0.282	0.314	0.352	0.382	0.384	0.369	0.361	0.334	0.320	0.289	0.262		
		taud	2.240	2.297	2.225	2.178	2.244	2.334	2.434	2.471	2.544	2.502	2.303	2.211		
		Ebn at Noon	674	813	858	869	861	863	871	858	842	768	650	600		
		Edh at Noon	58	78	106	128	127	118	105	95	78	65	55	48		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.51	1.28	2.09	3.57	4.49	4.88	4.58	4.07	2.55	1.38	0.61	0.42		
		RadStd	0.07	0.26	0.40	0.26	0.51	0.43	0.62	0.31	0.35	0.25	0.12	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.56	+0.44	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page