

INUVIK AP, NT, Canada

WMO: 719570

Lat: 68.304N

Lon: 133.481W

Elev: 68

StdP: 100.51

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -39.5	(c) -37.4	(d) -44.0	(e) 0.0	(f) -39.3	(g) -42.1	(h) 0.1	(i) -37.2	(j) 11.2	(k) -17.7	(l) 9.0	(m) -17.8	(n) 0.7	(o) 80	(p) 0.815

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.7	(c) 26.0	(d) 16.2	(e) 23.8	(f) 15.2	(g) 21.8	(h) 14.4	(i) 17.2	(j) 23.8	(k) 16.1	(l) 22.2	(m) 15.0	(n) 20.6	(o) 3.6	(p) 190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	10.4	19.6	13.3	9.6	18.5	12.2	8.9	17.6	48.7	23.8	45.4	22.4	42.3	20.7	21.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.0	(b) 6.8	(c) 6.0	(e) -41.5	(f) 29.3	(g) 2.5	(h) 1.9	(i) -43.3	(j) 30.6	(k) -44.7	(l) 31.7	(m) -46.2	(n) 32.8	(o) -48.0	(p) 34.2		
(a) 8.0	(b) 6.8	(c) 6.0	(e) -41.4	(f) 19.0	(g) 2.4	(h) 1.4	(i) -43.1	(j) 20.0	(k) -44.5	(l) 20.8	(m) -45.8	(n) 21.5	(o) -47.5	(p) 22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-6.9	-25.0	-23.4	-21.5	-10.5	1.6	11.7	14.4	11.0	4.5	-5.9	-17.4	-22.9		
	DBStd	15.84	8.05	7.81	7.60	7.77	6.90	5.09	4.50	4.72	4.52	5.25	6.35	6.81		
	HDD10.0	6494	1086	936	976	617	272	41	13	45	173	494	823	1021		
	HDD18.3	9224	1344	1169	1234	867	518	206	136	233	414	752	1073	1279		
	CDD10.0	335	0	0	0	0	12	91	148	75	9	1	0	0		
	CDD18.3	23	0	0	0	0	0	6	13	4	0	0	0	0		
	CDH23.3	228	0	0	0	0	4	71	117	36	1	0	0	0		
	CDH26.7	38	0	0	0	0	1	14	17	7	0	0	0	0		
(14) Wind	WSAvg	2.7	2.1	2.3	2.5	2.9	3.3	3.5	3.2	3.0	2.9	2.6	2.2	2.1		
(15) Precipitation	PrecAvg	259	15	11	12	12	17	24	38	46	27	28	16	15		
	PrecMax	376	44	23	41	42	61	70	86	151	62	102	38	36		
	PrecMin	127	0	0	0	2	0	0	7	8	2	3	0	0		
	PrecStd	53	10	6	8	9	15	17	20	24	15	16	8	9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.2	-2.3	2.5	10.7	22.5	28.8	28.7	27.6	19.7	8.7	0.8	-4.1		
		MCWB	-1.9	-4.1	-0.3	5.5	12.2	17.1	17.9	18.2	12.4	5.0	-0.5	-5.2		
	2%	DB	-5.1	-5.7	-3.1	6.4	18.9	25.2	26.3	23.5	16.2	4.2	-3.2	-7.5		
		MCWB	-6.0	-7.0	-5.0	2.8	10.5	15.0	16.5	16.4	10.5	2.4	-4.1	-8.4		
	5%	DB	-9.9	-9.0	-7.0	4.1	15.5	23.0	24.4	20.9	13.7	2.1	-5.9	-10.4		
		MCWB	-10.4	-9.9	-8.2	1.1	8.6	13.9	15.8	14.7	9.3	0.9	-6.6	-11.0		
	10%	DB	-14.1	-12.1	-10.4	1.3	12.2	20.8	22.5	18.7	11.2	0.5	-8.6	-13.3		
		MCWB	-14.6	-12.7	-11.4	-1.0	6.9	12.8	15.1	13.6	8.0	-0.4	-9.2	-13.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.8	-4.0	-0.4	5.4	12.6	17.8	18.8	18.9	12.8	5.4	-0.4	-5.2		
		MCDB	-0.1	-2.3	2.2	10.5	21.1	26.4	26.3	26.6	18.1	7.6	0.6	-4.3		
	2%	WB	-6.0	-7.0	-4.8	3.0	10.8	15.9	17.5	16.9	11.1	2.8	-4.0	-8.3		
		MCDB	-5.1	-5.9	-3.2	6.2	18.2	23.8	24.2	22.7	15.5	4.2	-3.3	-7.5		
	5%	WB	-10.4	-9.9	-8.3	1.1	9.0	14.5	16.5	15.4	9.6	0.9	-6.7	-10.9		
		MCDB	-9.9	-9.0	-7.1	4.0	15.1	21.6	22.7	19.9	13.0	2.0	-6.0	-10.3		
	10%	WB	-14.5	-12.8	-11.4	-0.9	6.9	13.3	15.6	14.0	8.2	-0.4	-9.1	-13.8		
		MCDB	-14.1	-12.1	-10.4	1.3	12.0	19.9	21.4	17.9	11.0	0.5	-8.6	-13.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.5	9.0	9.3	9.1	11.0	9.7	8.4	6.6	5.2	6.2	6.3		
		MCDBR	9.3	9.5	11.1	9.9	14.2	13.4	12.6	11.4	10.6	6.2	7.1	8.7		
	5% WB	MCWBR	8.6	8.7	9.6	7.2	8.0	6.3	5.9	5.9	6.1	4.7	6.7	8.2		
		MCWBR	9.3	9.3	11.1	9.7	13.9	12.7	11.1	10.3	9.8	5.8	7.1	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.159	0.216	0.252	0.305	0.348	0.343	0.366	0.337	0.295	0.237	0.158	N/A		
	taud		1.911	2.130	2.223	2.164	2.285	2.450	2.420	2.510	2.557	2.252	1.922	N/A		
	Ebn at Noon		122	608	798	836	839	859	820	811	766	568	102	0		
	Edh at Noon		7	43	74	106	107	94	94	77	56	37	6	0		
(44) All-Sky Solar Radiation	RadAvg		0.04	0.54	2.20	4.52	5.78	6.13	4.98	3.43	1.86	0.61	0.09	0.00		
	RadStd		0.00	0.03	0.10	0.17	0.45	0.48	0.47	0.35	0.17	0.07	0.01	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.02	+2.06	+2.00	N/A	N/A	N/A	-375	-377	N/A	N/A
(47) Regional (9 neighbors)		+0.97	+1.78	+2.03	N/A	N/A	N/A	-427	-422	N/A	N/A

Nomenclature: See separate page