

CHETICAMP CS, NS, Canada

WMO: 719590

Lat: 46.650N

Lon: 60.950W

Elev: 44

StdP: 100.80

Time Zone: -4.00 (NAA)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.0	-13.7	-19.5	0.7	-15.1	-17.4	0.8	-13.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	27.3	20.9	25.9	20.1	24.5	19.6	22.2	25.9	21.4	24.6	20.5	23.5	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.9	15.6	24.6	20.1	14.9	23.8	19.3	14.1	22.9	65.4	26.1	62.3	24.6	59.4	23.5	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-19.0	30.4	2.9	1.3	-21.1	31.3	-22.8	32.0	-24.4	32.7	-26.5	33.6
			-19.3	23.7	2.8	0.8	-21.3	24.3	-23.0	24.7	-24.6	25.2	-26.6	25.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-3.5	-4.7	-1.6	3.6	9.1	14.2	18.9	18.8	15.0	9.7	5.3	0.2
	DBStd	9.11	4.96	5.15	4.86	4.34	4.20	4.03	3.05	2.70	3.68	3.72	4.38	4.30
	HDD10.0	1980	421	412	359	200	69	8	0	0	3	51	154	304
	HDD18.3	4194	678	645	617	443	287	136	30	27	112	267	391	562
	CDD10.0	942	1	0	1	7	42	133	277	273	153	43	13	1
	CDD18.3	114	0	0	0	0	1	11	48	41	13	1	0	0
	CDH23.3	570	0	0	0	0	6	63	258	196	45	3	0	0
	CDH26.7	66	0	0	0	0	0	6	33	23	3	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	1421	141	110	103	95	87	86	86	113	113	150	139	167
	PrecMax	1656	210	177	178	170	144	183	160	214	280	228	205	370
	PrecMin	1002	82	44	41	53	27	42	34	56	15	62	96	71
	PrecStd	149	38	37	33	32	27	33	33	43	65	42	31	61
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	12.5	14.2	20.3	24.2	27.3	29.2	28.9	26.8	22.8	20.0	15.5
		MCWB	13.3	9.7	11.1	14.2	16.6	20.4	22.5	21.6	21.6	18.5	17.0	13.3
	2%	DB	10.2	8.6	10.8	16.4	21.5	25.2	27.6	27.0	24.6	20.0	17.9	12.3
		MCWB	8.6	6.8	7.6	12.4	15.3	18.8	21.2	20.8	20.2	16.9	15.3	10.5
	5%	DB	5.5	5.0	8.0	13.5	19.2	23.2	26.1	25.5	22.9	18.0	15.6	9.0
		MCWB	4.2	3.1	5.5	10.2	13.5	17.7	20.3	20.2	19.4	15.3	13.3	7.5
	10%	DB	2.9	2.4	5.2	10.6	16.9	21.4	24.7	24.1	21.4	15.8	12.6	6.2
		MCWB	1.7	0.9	3.0	7.6	12.5	16.6	19.8	19.7	18.2	13.4	10.5	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	10.1	11.3	15.3	18.2	21.9	23.4	23.2	22.5	19.5	17.2	13.5
		MCDB	15.8	11.7	13.3	18.7	22.1	26.0	28.1	27.3	25.9	21.7	19.6	15.4
	2%	WB	8.9	6.7	8.2	13.0	16.5	20.3	22.4	22.0	21.0	17.4	15.4	10.5
		MCDB	10.2	8.2	10.2	16.0	20.0	23.7	26.3	25.4	23.7	19.6	17.6	12.2
	5%	WB	4.2	3.0	5.6	10.7	14.7	18.9	21.5	21.1	19.8	15.5	13.2	7.5
		MCDB	5.4	4.4	7.7	13.3	18.1	21.9	24.8	24.2	22.4	17.6	15.3	8.8
	10%	WB	1.8	0.8	3.1	7.8	12.7	17.2	20.6	20.2	18.5	13.5	10.4	5.0
		MCDB	2.8	1.9	5.1	10.5	16.2	20.6	23.6	23.3	21.0	15.5	12.1	6.1
Mean Daily Temperature Range	5% DB	MDBR	6.8	7.9	8.1	8.2	9.5	9.5	9.0	8.7	8.8	7.4	6.7	5.7
		MCDBR	12.2	12.3	12.2	13.0	13.1	12.0	10.9	10.5	10.2	10.4	10.9	10.7
		MCWBR	11.3	10.8	10.0	9.5	8.1	7.2	6.0	5.9	6.7	8.1	10.0	10.1
	5% WB	MCDBR	12.2	12.3	11.7	12.2	11.2	10.0	8.9	8.8	9.3	9.9	10.9	10.6
		MCWBR	11.5	11.2	10.2	10.0	8.2	6.8	5.5	5.7	6.8	8.3	10.0	10.1
Clear-Sky Solar Irradiance	taub	0.303	0.295	0.329	0.355	0.370	0.389	0.416	0.395	0.363	0.348	0.326	0.306	
	taud	2.320	2.302	2.272	2.375	2.418	2.378	2.357	2.420	2.481	2.476	2.450	2.375	
	Ebn at Noon	780	876	892	901	896	876	846	852	852	808	754	735	
	Edh at Noon	76	94	113	113	112	117	119	107	92	80	68	65	
All-Sky Solar Radiation	RadAvg	0.94	1.71	2.98	4.19	5.09	5.49	5.51	4.86	3.69	2.25	1.14	0.71	
	RadStd	0.07	0.24	0.33	0.36	0.42	0.50	0.37	0.31	0.30	0.21	0.14	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.44	N/A	N/A	N/A

Nomenclature: See separate page