

LIVERPOOL BAY, NT, Canada

WMO: 719600

Lat: 69.604N

Lon: 130.894W

Elev: 334

StdP: 14.52

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.5	-33.7	N/A	N/A	N/A	N/A	N/A	N/A	45.9	-7.2	41.5	-3.1	10.5	280	1.074

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	69.8	N/A	65.0	N/A	61.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.8	180

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.4	28.6	25.5	-38.9	77.3	3.1	3.7	-41.1	80.0	-43.0	82.1	-44.7	84.2	-47.0	86.9		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	-15.0	-14.0	-11.2	4.8	25.4	42.2	49.3	46.0	36.5	20.7	1.5	-10.3	
	DBStd	25.91	11.96	11.90	12.12	11.54	11.28	8.41	8.03	7.68	7.19	8.10	10.17	10.90	
	HDD50	13019	2014	1792	1897	1357	764	266	115	173	409	908	1454	1870	
	HDD65	18318	2479	2212	2362	1807	1227	684	490	590	855	1373	1904	2335	
	CDD50	180	0	0	0	0	1	33	93	49	4	0	0	0	
	CDD65	3	0	0	0	0	0	0	2	1	0	0	0	0	
	CDH74	28	0	0	0	0	0	9	14	5	0	0	0	0	
	CDH80	1	0	0	0	0	0	1	0	0	0	0	0	0	
	WSAvg	13.2	14.5	13.9	12.5	13.3	13.8	13.7	13.0	12.7	12.8	12.7	12.7	13.0	
	PrecAvg	9.6	0.5	0.4	0.4	0.3	0.5	1.1	1.6	1.8	1.3	0.8	0.5	0.4	
Precipitation	PrecMax	12.6	1.1	0.7	0.9	0.7	0.9	2.3	3.1	2.8	2.5	1.7	1.2	1.0	
	PrecMin	7.1	0.0	0.1	0.1	0.1	0.1	0.3	0.6	1.0	0.7	0.3	0.1	0.1	
	PrecStd	1.3	0.3	0.2	0.2	0.2	0.2	0.6	0.6	0.5	0.4	0.3	0.2	0.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	20.7	24.3	37.1	60.8	73.8	76.2	72.8	61.4	40.7	30.2	21.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	DB	15.7	13.5	16.9	31.9	51.9	66.8	71.4	65.7	54.7	34.9	23.4	14.3	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	DB	6.8	8.9	11.0	26.8	44.8	62.1	66.6	61.3	50.0	32.3	19.1	10.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	DB	1.2	4.4	5.8	22.2	39.3	56.6	62.1	57.2	45.9	30.3	15.9	5.6	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.9	11.2	12.0	11.2	15.4	13.7	11.0	8.4	6.6	9.7	10.2	
		MCDBR	16.0	15.8	14.3	14.7	20.4	24.9	20.2	17.1	15.8	6.7	10.4	15.3	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.150	0.201	0.244	0.297	0.331	0.329	0.343	0.325	0.288	0.222	N/A	N/A	N/A	
	taud	1.914	2.091	2.220	2.157	2.243	2.446	2.470	2.539	2.560	2.179	N/A	N/A	N/A	
	Ebn at Noon	14	184	251	265	269	275	266	259	240	167	0	0	0	
	Edh at Noon	1	12	22	33	35	30	28	23	17	11	0	0	0	
All-Sky Solar Radiation	RadAvg	4	130	623	1376	1826	1938	1650	1029	536	161	0	0	0	
	RadStd	0	10	34	60	148	150	148	109	53	16	0	0	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+2.02	+3.47	+3.69	N/A	N/A	N/A	-769	-760	N/A	N/A

Nomenclature: See separate page