

LIVERPOOL BAY, NT, Canada

WMO: 719600

Lat: 69.604N

Lon: 130.894W

Elev: 102

StdP: 100.11

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-38.1	-36.5	N/A	N/A	N/A	N/A	N/A	N/A	20.5	-21.8	18.5	-19.5	4.7	280	1.074

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	21.0	N/A	18.3	N/A	16.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.5	12.8	11.4	-39.4	25.2	1.7	2.1	-40.6	26.6	-41.6	27.9	-42.6	29.0	-43.9	30.5		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.5	-26.1	-25.5	-24.0	-15.1	-3.7	5.7	9.6	7.8	2.5	-6.3	-16.9	-23.5		
	DBStd	14.39	6.64	6.61	6.73	6.41	6.27	4.67	4.46	4.26	3.99	4.50	5.65	6.05		
	HDD10.0	7233	1119	996	1054	754	424	148	64	96	227	504	808	1039		
	HDD18.3	10177	1377	1229	1312	1004	682	380	272	328	475	763	1058	1297		
	CDD10.0	100	0	0	0	0	1	18	52	27	2	0	0	0		
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH23.3	16	0	0	0	0	0	5	8	3	0	0	0	0		
	CDH26.7	1	0	0	0	0	0	1	0	0	0	0	0	0		
Wind	WSAvg	5.9	6.5	6.2	5.6	5.9	6.2	6.1	5.8	5.7	5.7	5.7	5.7	5.8		
Precipitation	PrecAvg	245	12	10	11	8	12	27	41	45	34	21	13	11		
	PrecMax	319	28	18	22	18	23	58	78	72	63	42	30	25		
	PrecMin	180	1	3	2	2	2	7	14	25	18	7	3	3		
	PrecStd	34	7	5	5	4	6	14	16	13	9	7	5	5		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.9	-6.3	-4.3	2.8	16.0	23.2	24.5	22.7	16.3	4.9	-1.0	-6.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	-9.1	-10.3	-8.4	0.0	11.0	19.3	21.9	18.7	12.6	1.6	-4.8	-9.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	-14.0	-12.8	-11.7	-2.9	7.1	16.7	19.2	16.3	10.0	0.2	-7.2	-12.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	-17.1	-15.4	-14.5	-5.4	4.1	13.6	16.7	14.0	7.7	-0.9	-8.9	-14.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Mean Daily Temperature Range	5% DB	MDBR	5.8	6.0	6.2	6.7	6.2	8.6	7.6	6.1	4.6	3.7	5.4	5.7		
		MCDBR	8.9	8.8	8.0	8.2	11.3	13.8	11.2	9.5	8.8	3.7	5.8	8.5		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Clear-Sky Solar Irradiance	taub		0.150	0.201	0.244	0.297	0.331	0.329	0.343	0.325	0.288	0.222	N/A	N/A		
	taud		1.914	2.091	2.220	2.157	2.243	2.446	2.470	2.539	2.560	2.179	N/A	N/A		
	Ebn at Noon		45	580	790	835	847	867	839	817	758	528	0	0		
	Edh at Noon		3	38	70	104	109	93	88	73	53	34	0	0		
All-Sky Solar Radiation	RadAvg		0.01	0.41	1.97	4.34	5.75	6.11	5.20	3.25	1.69	0.51	0.00	0.00		
	RadStd		0.00	0.03	0.11	0.19	0.47	0.47	0.47	0.34	0.17	0.05	0.00	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+1.12	+1.93	+2.05	N/A	N/A	N/A	-427	-422	N/A	N/A

Nomenclature: See separate page