

GRISE FIORD, NU, Canada

WMO: 719710

Lat: 76.423N

Lon: 82.902W

Elev: 146

StdP: 14.62

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-41.1	-38.6	-49.2	0.3	-40.8	-46.2	0.4	-38.1	25.9	-2.3	18.8	0.2	1.8	50	1.045

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	51.3	44.4	48.6	43.0	46.1	41.6	45.1	50.1	43.6	47.8	42.0	45.7	13.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.6	38.9	45.7	40.2	36.9	44.5	38.8	34.8	43.1	17.7	50.6	17.0	47.8	16.2	45.9	52.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.8	19.3	14.5	DB	-44.1	56.4	4.0	3.2	-46.9	58.7	-49.3	60.5	-51.5	62.3	-54.4	64.6	(4)
(5)			WB	-44.2	48.7	4.0	2.6	-47.1	50.6	-49.4	52.1	-51.6	53.6	-54.5	55.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-19.9	-23.8	-19.6	-4.8	17.6	34.5	40.1	38.7	29.1	13.8	-0.9	-12.5
	DBStd	24.84	10.50	10.51	12.25	9.76	8.86	4.66	4.44	4.19	5.38	9.12	10.75	11.72
	HDD50	15379	2166	2067	2158	1643	1006	465	309	351	627	1121	1527	1939
	HDD65	20853	2631	2487	2623	2093	1471	915	773	816	1077	1586	1977	2404
	CDD50	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	4.3	3.2	2.7	2.9	2.9	3.6	4.1	4.3	4.5	7.0	6.9	5.0	3.8
Precipitation	PrecAvg	7.0	0.2	0.2	0.4	0.4	0.4	0.7	1.2	1.5	0.7	0.7	0.4	0.4
	PrecMax	10.2	0.7	0.5	1.3	1.2	0.9	3.0	2.9	3.7	2.3	1.7	0.9	1.3
	PrecMin	3.7	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.2	0.2	0.1	0.1	0.0
	PrecStd	1.8	0.2	0.1	0.3	0.2	0.2	0.6	0.7	0.9	0.5	0.4	0.2	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.4	15.3	30.1	21.5	36.5	54.2	56.4	52.8	42.5	34.2	30.5	17.8
		MCWB	17.1	13.7	27.2	19.1	31.5	43.7	46.3	45.5	36.9	30.2	27.2	15.7
	2%	DB	7.0	3.3	9.8	17.4	32.9	47.6	52.4	49.5	39.6	30.8	24.5	13.2
		MCWB	5.9	2.0	8.3	15.4	29.4	40.6	45.0	43.4	34.9	27.5	21.6	11.6
	5%	DB	0.8	-1.9	3.2	13.9	31.1	44.0	49.9	47.0	37.8	28.6	18.5	8.4
		MCWB	-0.2	-2.7	2.3	11.8	28.2	38.6	43.9	42.1	34.0	26.1	16.7	7.1
	10%	DB	-4.5	-7.7	-2.4	10.0	29.4	40.9	47.6	44.6	36.2	26.3	13.6	5.0
		MCWB	-5.3	-8.3	-3.3	8.4	27.0	36.7	42.8	41.0	33.0	24.2	12.1	4.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.8	14.0	27.8	19.7	32.3	44.2	47.5	46.8	37.6	30.8	27.4	16.2
		MCDB	17.2	15.4	31.0	21.8	34.5	52.0	52.8	51.7	41.1	33.4	30.4	17.6
	2%	WB	5.7	2.3	8.8	15.5	29.9	41.0	45.6	44.6	35.9	28.2	21.5	11.5
		MCDB	7.1	3.2	9.7	17.1	32.3	46.8	51.3	48.1	38.2	30.2	24.1	13.1
	5%	WB	-0.1	-2.7	2.2	12.0	28.5	38.9	44.3	42.8	34.8	26.3	16.9	7.2
		MCDB	0.8	-1.9	3.1	13.6	30.8	43.7	49.1	46.0	37.0	28.4	18.7	8.3
	10%	WB	-5.2	-8.3	-3.2	8.5	27.0	37.1	43.0	41.3	33.5	24.0	12.0	4.0
		MCDB	-4.5	-7.7	-2.4	9.9	29.3	40.5	47.2	43.9	35.9	26.3	13.5	5.0
Mean Daily Temperature Range	5% DB	MDBR	11.8	11.6	12.4	13.5	10.7	7.9	9.1	7.0	5.6	7.7	10.1	10.9
		MCDBR	17.8	16.6	17.1	14.9	10.8	13.5	13.6	10.7	6.7	8.7	13.7	12.9
		MCWBR	16.8	15.7	16.1	13.3	8.7	8.2	8.3	6.6	4.5	7.3	12.1	11.9
	5% WB	MCDBR	17.8	16.5	17.1	15.3	10.4	12.5	12.6	9.6	6.1	8.6	13.5	12.9
		MCWBR	16.8	15.7	16.0	13.8	8.6	8.0	8.3	6.5	4.4	7.6	11.9	11.9
Clear-Sky Solar Irradiance	taub	N/A	0.169	0.240	0.303	0.320	0.344	0.328	0.325	0.260	0.186	N/A	N/A	
	taud	N/A	1.840	2.028	1.972	2.052	2.141	2.335	2.357	2.304	1.897	N/A	N/A	
	Ebn at Noon	0	47	197	234	255	254	256	235	201	32	0	0	
	Edh at Noon	0	3	19	34	37	36	29	24	15	3	0	0	
All-Sky Solar Radiation	RadAvg	0	20	387	1300	2168	2292	1771	1013	408	67	0	0	
	RadStd	0	2	17	39	88	160	154	88	32	6	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page