

RESOLUTION ISLAND, NU, Canada

WMO: 719720

Lat: 61.596N

Lon: 64.639W

Elev: 1209

StdP: 14.07

Time Zone: -5.00 (NAE)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 2	(b) -22.0	(c) -19.0	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 70.4	(k) 2.2	(l) 64.7	(m) 0.6	(n) 23.4	(o) 300	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.2	(c) 59.4	(d) N/A	(e) 55.8	(f) N/A	(g) 52.3	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 15.0	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 55.5	(b) 49.6	(c) 43.3	(e) -22.4	(f) 63.4	(g) 3.2	(h) 3.5	(i) -24.8	(j) 65.9	(k) -26.7	(l) 68.0	(m) -28.5	(n) 69.9	(o) -30.8	(p) 72.5		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	-2.5	-4.9	1.7	13.1	24.5	33.8	42.3	42.2	34.0	26.4	18.8	8.9
	DBStd	17.69	9.64	9.79	10.45	8.65	6.04	5.92	7.29	5.74	4.40	4.70	5.83	9.68
	HDD50	10988	1628	1537	1497	1107	792	485	263	254	481	732	937	1275
	HDD65	16426	2093	1957	1962	1557	1257	935	704	706	931	1197	1387	1740
	CDD50	37	0	0	0	0	0	1	24	12	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	20.4	23.8	22.7	21.3	20.3	16.2	19.3	17.2	17.5	18.7	22.3	22.0	23.5
	PrecAvg	26.1	1.5	1.1	1.1	1.0	1.1	1.9	2.9	3.1	3.7	3.3	3.0	2.4
Precipitation	PrecMax	34.1	3.8	4.4	3.1	2.4	2.0	3.9	4.6	4.5	6.1	5.9	6.3	5.1
	PrecMin	20.1	0.4	0.2	0.2	0.1	0.4	1.0	1.2	1.8	1.4	1.6	1.1	0.4
	PrecStd	3.5	0.9	0.9	0.7	0.5	0.4	0.6	0.8	0.7	1.0	0.9	1.1	1.1
	PrecStd	3.5	0.9	0.9	0.7	0.5	0.4	0.6	0.8	0.7	1.0	0.9	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	29.1	29.5	31.5	35.1	47.2	54.6	65.6	63.5	49.7	42.1	32.5	33.4	
	0.4% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2% DB	23.6	22.0	25.3	30.8	40.0	50.2	61.1	58.2	45.2	36.7	30.4	30.2	
	2% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% DB	15.2	14.4	20.3	28.4	35.6	46.2	57.7	55.1	41.9	34.0	28.4	25.7	
	5% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10% DB	11.2	8.3	16.6	25.5	31.7	42.7	54.1	51.7	39.6	32.3	26.5	21.8	
	10% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	0.4% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	MDBR	7.3	7.6	8.7	8.0	6.0	7.1	9.2	8.6	5.6	5.0	5.6	6.7	
	5% DB MCDBR	13.0	13.1	12.0	9.9	9.1	12.9	13.5	13.9	9.8	7.1	7.0	8.2	
	5% DB MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.184	0.225	0.248	0.311	0.323	0.323	0.326	0.326	0.303	0.271	0.208	N/A	
	taud	2.060	2.202	2.204	2.050	2.114	2.353	2.484	2.518	2.527	2.460	2.162	N/A	
	Ebn at Noon	183	248	280	276	283	286	283	274	261	230	168	N/A	
	Edh at Noon	11	20	29	42	43	35	30	27	22	16	10	N/A	
All-Sky Solar Radiation	RadAvg	83	349	900	1507	1916	1876	1613	1223	750	339	99	37	
	RadStd	11	32	46	74	127	122	158	124	70	35	10	3	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page