

RESOLUTION ISLAND, NU, Canada

WMO: 719720

Lat: 61.596N

Lon: 64.639W

Elev: 369

StdP: 96.98

Time Zone: -5.00 (NAE)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-30.0	-28.3	N/A	N/A	N/A	N/A	N/A	N/A	31.5	-16.6	28.9	-17.4	10.5	300	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.1	15.2	N/A	13.2	N/A	11.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.8	22.2	19.4	DB	-30.2	17.4	1.8	1.9	-31.5	18.8	-32.6	20.0	-33.6	21.1	-34.9	22.5	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-6.7	-19.2	-20.5	-16.8	-10.5	-4.2	1.0	5.7	5.7	1.1	-3.1	-7.3	-12.9
	DBStd	9.83	5.36	5.44	5.81	4.80	3.35	3.29	4.05	3.19	2.44	2.61	3.24	5.38
	HDD10.0	6104	904	854	832	615	440	269	146	141	267	407	521	708
	HDD18.3	9126	1163	1087	1090	865	698	519	391	392	517	665	771	967
	CDD10.0	21	0	0	0	0	0	1	13	7	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	9.1	10.7	10.1	9.5	9.1	7.2	8.6	7.7	7.8	8.4	10.0	9.8	10.5
Precipitation	PrecAvg	662	39	27	28	26	29	47	73	80	95	84	76	60
	PrecMax	866	96	111	78	60	50	100	118	115	154	151	160	130
	PrecMin	511	9	5	4	3	10	25	31	46	36	41	29	10
	PrecStd	88	22	22	18	12	10	14	21	18	25	24	29	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.6	-1.4	-0.3	1.7	8.4	12.5	18.7	17.5	9.9	5.6	0.3	0.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-4.7	-5.5	-3.7	-0.7	4.4	10.1	16.2	14.6	7.3	2.6	-0.9	-1.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-9.3	-9.8	-6.5	-2.0	2.0	7.9	14.3	12.8	5.5	1.1	-2.0	-3.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-11.6	-13.2	-8.5	-3.6	-0.1	6.0	12.3	11.0	4.2	0.2	-3.1	-5.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.2	4.8	4.5	3.3	3.9	5.1	4.8	3.1	2.8	3.1	3.7
		MCDBR	7.2	7.3	6.6	5.5	5.1	7.2	7.5	7.7	5.4	3.9	3.9	4.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.184	0.225	0.248	0.311	0.323	0.323	0.326	0.326	0.303	0.271	0.208	N/A
	taud		2.060	2.202	2.204	2.050	2.114	2.353	2.484	2.518	2.527	2.460	2.162	N/A
	Ebn at Noon		576	782	884	871	892	902	892	864	823	725	530	N/A
	Edh at Noon		35	63	91	132	136	109	94	84	69	50	32	N/A
All-Sky Solar Radiation	RadAvg		0.26	1.10	2.84	4.75	6.04	5.91	5.09	3.86	2.37	1.07	0.31	0.12
	RadStd		0.04	0.10	0.14	0.23	0.40	0.39	0.50	0.39	0.22	0.11	0.03	0.01

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page