

CAPE MERCY, NU, Canada

WMO: 719750

Lat: 64.958N

Lon: 63.578W

Elev: 583

StdP: 94.52

Time Zone: -5.00 (NAE)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-33.5	-31.7	N/A	N/A	N/A	N/A	N/A	N/A	26.2	-17.2	23.6	-18.6	10.4	270	1.173

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	13.0	N/A	11.3	N/A	9.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.6	18.7	16.3	DB	-34.9	14.8	2.7	1.7	-36.8	16.1	-38.4	17.1	-39.9	18.1	-41.9	19.3	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.1	-21.3	-22.9	-19.8	-13.8	-6.3	-0.1	4.8	4.1	-1.2	-5.7	-10.9	-16.9
	DBStd	10.56	6.19	6.16	6.37	5.37	3.98	3.31	3.75	3.11	2.61	3.33	4.36	6.18
	HDD10.0	6970	970	921	923	713	504	302	167	184	337	487	627	834
	HDD18.3	10003	1228	1154	1182	963	763	552	419	441	587	745	877	1092
	CDD10.0	9	0	0	0	0	0	0	7	2	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.8	7.2	7.1	7.0	6.8	6.5	6.6	6.1	6.2	7.0	7.7	7.0	7.1
Precipitation	PrecAvg	603	35	24	23	27	33	43	59	78	82	82	64	53
	PrecMax	804	85	92	60	58	65	87	131	123	133	130	162	119
	PrecMin	332	10	7	6	5	10	20	20	33	20	46	22	16
	PrecStd	116	20	19	14	13	13	16	24	23	26	19	31	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.7	-4.6	-2.3	-0.2	6.8	11.8	16.4	14.4	8.4	8.3	1.4	-1.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-6.1	-7.6	-5.3	-2.4	3.3	8.6	14.0	12.1	5.7	2.4	-2.2	-4.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-9.3	-11.2	-8.0	-4.3	0.4	6.8	12.3	10.5	3.7	0.0	-3.8	-6.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-12.0	-14.0	-10.6	-6.5	-1.5	5.0	10.6	9.0	2.2	-1.5	-5.2	-8.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.9	4.6	4.9	4.6	3.9	3.5	4.3	4.1	2.8	3.1	3.7	4.4
		MCDBR	7.2	7.0	6.7	5.3	6.0	5.5	5.7	5.7	5.3	5.6	5.9	6.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.142	0.201	0.231	0.276	0.296	0.302	0.315	0.306	0.280	0.246	0.334	0.142	
	taud	1.877	2.165	2.205	2.108	2.126	2.257	2.439	2.532	2.541	2.375	3.014	1.904	
	Ebn at Noon	435	747	874	895	907	910	890	869	823	679	424	153	
	Edh at Noon	23	53	82	118	129	116	95	79	62	44	20	7	
All-Sky Solar Radiation	RadAvg	0.14	0.91	2.67	4.92	6.44	6.44	5.51	3.69	2.28	0.93	0.20	0.04	
	RadStd	0.01	0.04	0.11	0.19	0.30	0.53	0.53	0.38	0.23	0.08	0.02	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+2.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	+1.91	+2.14	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page