

RABBIT KETTLE, NT, Canada

WMO: 719800

Lat: 61.960N

Lon: 127.210W

Elev: 2028

StdP: 13.65

Time Zone: -7.00 (NAM)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-49.7	-44.0	-59.2	0.2	-49.7	-52.6	0.3	-43.8	10.2	4.9	7.9	2.7	0.5	170	0.687

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.3	81.6	58.6	77.6	56.9	74.0	55.6	60.2	76.1	58.8	73.2	57.3	70.4	4.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.1	69.6	61.8	53.3	65.2	60.7	51.8	61.5	60.1	27.5	75.8	26.4	73.3	25.4	70.8	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	9.9	8.5	DB	-53.3	88.2	5.4	4.8	-57.2	91.6	-60.3	94.4	-63.4	97.1	-67.3	100.6	(4)
(5)			WB	-52.1	63.6	5.2	2.2	-55.8	65.2	-58.8	66.4	-61.7	67.6	-65.5	69.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.3	-13.7	-4.7	10.9	31.6	46.2	56.8	60.4	56.1	44.4	27.6	-1.1	-13.4
	DBStd	29.21	15.67	12.94	14.81	9.70	7.52	5.48	4.33	5.58	6.01	9.23	13.80	14.73
	HDD50	9824	1976	1531	1211	551	165	7	1	11	181	694	1532	1964
	HDD65	14523	2441	1951	1676	1001	583	252	153	280	617	1158	1982	2429
	CDD50	794	0	0	0	0	46	212	322	199	15	0	0	0
	CDD65	20	0	0	0	0	0	7	10	3	0	0	0	0
	CDH74	808	0	0	0	0	47	230	342	186	3	0	0	0
	CDH80	184	0	0	0	0	4	62	81	37	0	0	0	0
Wind	WSAvg	2.7	0.6	1.6	3.0	4.1	4.3	4.0	3.6	3.3	3.1	2.3	1.2	0.8
Precipitation	PrecAvg	19.2	1.3	1.0	0.9	0.7	1.3	2.5	3.0	2.4	1.9	1.5	1.5	1.2
	PrecMax	24.0	2.0	1.7	1.8	1.4	2.3	4.4	5.8	4.1	3.7	2.3	2.3	2.4
	PrecMin	15.0	0.4	0.3	0.3	0.3	0.4	1.2	1.0	1.2	0.6	0.7	0.7	0.4
	PrecStd	2.3	0.4	0.4	0.4	0.3	0.5	0.9	1.0	0.7	0.7	0.4	0.4	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.4	30.3	51.7	59.2	79.0	87.1	87.6	84.5	69.2	53.9	32.7	29.5
		MCWB	27.3	25.9	40.1	43.6	53.1	60.3	60.5	60.0	53.0	43.7	30.4	28.5
	2%	DB	19.0	25.1	43.9	54.1	74.2	80.2	81.6	79.2	63.8	46.6	25.0	17.3
		MCWB	17.9	22.4	34.8	40.5	52.4	57.4	58.8	58.5	49.5	39.1	23.3	16.5
	5%	DB	12.3	19.9	39.0	51.1	68.6	75.4	77.6	74.4	60.3	42.7	20.8	12.3
		MCWB	11.6	17.8	30.9	38.8	50.2	55.0	57.7	56.8	48.5	37.2	19.7	11.6
	10%	DB	6.5	15.4	33.8	48.1	63.5	71.6	73.9	69.6	56.7	39.0	16.9	6.7
		MCWB	5.8	13.7	27.9	37.1	47.8	53.8	56.8	55.2	46.8	34.9	16.0	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.2	26.8	39.9	44.0	55.6	62.0	62.5	61.9	54.8	45.2	30.6	27.5
		MCDB	30.0	29.2	51.4	56.1	74.9	80.5	79.6	78.6	66.4	52.5	32.9	30.1
	2%	WB	17.9	22.2	34.8	41.3	53.0	59.3	60.4	59.3	51.3	39.9	23.4	16.6
		MCDB	18.9	25.0	43.7	52.3	71.1	75.1	75.7	74.9	60.2	44.8	24.7	17.4
	5%	WB	11.4	17.9	31.2	39.5	51.1	57.0	59.1	57.7	49.4	37.6	19.7	11.6
		MCDB	12.1	19.9	37.8	49.5	67.1	70.6	73.6	71.7	58.0	42.4	20.8	12.3
	10%	WB	5.8	13.8	28.1	37.7	48.7	55.0	57.8	56.1	47.7	35.2	16.1	6.1
		MCDB	6.5	15.4	33.8	47.0	62.4	67.3	70.9	68.1	55.4	38.7	17.1	6.7
Mean Daily Temperature Range	5% DB	MDBR	17.1	26.1	32.6	26.2	25.9	24.2	24.3	23.5	21.3	15.4	16.2	14.4
		MCDBR	19.2	28.4	33.0	29.7	36.2	32.9	33.5	34.3	27.9	19.5	16.0	15.7
		MCWBR	18.3	25.7	23.6	17.1	16.6	12.9	13.4	14.9	14.9	12.5	14.7	15.4
	5% WB	MCDBR	18.6	26.6	31.7	26.5	33.4	27.8	28.0	29.3	24.7	18.4	15.7	15.7
		MCWBR	17.8	24.1	22.7	15.4	15.4	11.4	12.0	13.2	13.8	12.0	14.4	15.4
Clear-Sky Solar Irradiance	taub	0.197	0.252	0.272	0.329	0.348	0.380	0.383	0.363	0.314	0.269	0.203	0.169	
	taud	2.069	2.200	2.205	2.072	2.207	2.297	2.327	2.402	2.475	2.298	2.044	1.923	
	Ebn at Noon	168	231	268	269	275	267	263	259	254	220	156	112	
	Edh at Noon	11	20	29	41	39	37	35	30	23	18	10	7	
All-Sky Solar Radiation	RadAvg	89	344	880	1512	1772	1636	1539	1246	775	359	126	44	
	RadStd	7	28	53	80	93	113	109	83	75	29	13	3	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page