

AZURE AGCM, AB, Canada

WMO: 719810

Lat: 50.5119N

Lon: 114.0131W

Elev: 1143

StdP: 88.33

Time Zone: -7.00 (NAM)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-28.2	-25.3	-31.6	0.2	-28.1	-28.5	0.3	-25.0	10.9	2.6	9.5	2.1	2.6	240	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	28.8	15.2	26.9	14.9	25.0	14.2	17.8	24.2	16.7	23.6	15.7	22.8	3.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.5	12.7	21.0	14.1	11.5	19.5	12.9	10.7	18.3	55.0	24.4	51.3	23.5	48.1	22.6	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	8.3	7.1	-32.0	32.3	2.8	2.3	-34.0	34.0	-35.6	35.3	-37.2	36.6	-39.2	38.3		
(5)			-32.2	20.3	2.7	1.5	-34.1	21.4	-35.7	22.3	-37.3	23.1	-39.3	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.3	-5.4	-7.2	-1.9	3.7	9.4	13.3	16.2	15.8	11.6	4.8	-1.7	-7.3		
	DBStd	10.52	8.41	8.55	7.95	4.94	4.45	3.13	2.78	3.22	5.10	5.43	7.54	8.39		
	HDD10.0	2704	478	482	368	195	67	7	1	2	42	174	354	536		
	HDD18.3	5137	736	715	626	439	279	155	76	88	207	420	602	794		
	CDD10.0	638	1	0	1	6	47	104	193	183	89	13	2	0		
	CDD18.3	28	0	0	0	0	1	2	11	11	4	0	0	0		
	CDH23.3	803	0	0	0	4	41	66	276	296	119	2	0	0		
	CDH26.7	183	0	0	0	0	3	11	64	80	24	0	0	0		
	WSAvg	3.1	3.6	3.1	3.4	3.5	3.4	3.2	2.5	2.3	2.8	3.1	3.5	3.4		
(15) Precipitation	PrecAvg	598	28	25	35	48	78	107	62	62	52	34	34	29		
	PrecMax	932	51	39	89	92	145	379	160	132	146	60	81	64		
	PrecMin	407	10	4	15	28	20	17	16	11	5	5	3	10		
	PrecStd	110	10	9	17	18	36	69	38	29	32	16	18	14		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	12.7	15.4	23.0	27.0	28.4	31.0	31.2	29.4	21.7	18.1	11.2		
		MCWB	4.9	5.2	6.3	9.8	12.0	16.3	16.5	14.8	13.4	10.0	7.6	3.5		
	2%	DB	9.2	9.2	13.3	18.7	24.3	25.0	28.5	28.8	26.8	18.7	13.3	7.9		
		MCWB	3.6	3.1	5.2	8.0	11.7	14.0	16.3	15.0	13.1	9.3	6.1	2.7		
	5%	DB	7.3	6.7	10.9	15.5	21.6	23.0	26.4	26.7	24.2	16.0	10.7	5.9		
		MCWB	2.3	1.4	4.0	6.2	10.9	13.4	16.3	15.0	12.6	8.1	4.7	1.5		
	10%	DB	5.5	4.3	8.5	12.6	18.9	21.1	24.4	24.5	21.2	13.6	8.2	4.2		
		MCWB	1.4	0.1	3.0	4.8	9.4	12.5	15.7	14.5	11.5	6.6	3.2	0.1		
	0.4%	WB	5.4	5.7	7.5	10.1	13.5	17.9	20.3	18.4	15.5	11.5	8.5	4.6		
		MCDB	11.5	11.3	14.3	21.9	23.7	24.0	26.3	24.7	24.4	19.4	16.1	9.8		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	3.6	3.3	5.6	8.3	12.1	15.9	18.4	17.0	14.2	9.9	6.7	2.8		
		MCDB	8.5	8.6	12.0	17.4	22.5	23.0	24.4	24.4	23.5	17.0	13.2	7.1		
	5%	WB	2.5	1.7	4.4	6.7	11.1	14.4	17.4	16.0	13.1	8.4	5.0	1.6		
		MCDB	6.9	6.1	10.6	14.6	20.1	21.1	23.7	23.8	21.9	15.3	10.1	5.7		
	10%	WB	1.5	0.3	3.0	5.2	10.0	13.2	16.4	15.1	12.0	6.9	3.2	0.3		
		MCDB	5.5	4.0	8.5	11.5	17.7	19.5	23.0	22.7	20.7	13.2	7.8	4.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	10.9	11.2	12.2	12.9	12.5	14.1	14.5	13.6	12.0	10.6	10.3		
		MCDBR	11.3	13.2	14.1	17.9	18.0	16.2	18.2	18.8	18.5	15.4	13.3	11.2		
		MCWBR	7.4	8.3	8.0	8.9	8.1	7.7	8.7	8.0	7.8	7.8	7.8	7.6		
		MCDBR	11.1	12.8	13.6	17.0	15.9	14.2	15.3	15.8	16.6	14.9	13.1	11.4		
	5% WB	MCWBR	7.5	8.6	8.1	8.8	7.5	7.5	8.5	7.9	7.5	7.9	8.0	8.0		
(40) Clear-Sky Solar Irradiance	taub		0.251	0.269	0.281	0.335	0.341	0.340	0.338	0.354	0.312	0.277	0.254	0.234		
	taud		2.441	2.436	2.464	2.321	2.376	2.416	2.430	2.386	2.483	2.555	2.508	2.446		
	Ebn at Noon		816	887	936	907	915	916	911	878	887	869	809	788		
	Edh at Noon		57	75	88	115	114	111	108	107	87	67	53	49		
	RadAvg		1.17	2.13	3.34	4.69	5.50	5.92	6.62	5.40	3.79	2.35	1.25	0.90		
(45) All-Sky Solar Radiation	RadStd		0.09	0.17	0.25	0.31	0.43	0.43	0.42	0.37	0.39	0.25	0.10	0.07		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (67 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page