

PRIDDIS ROTHNEY OBSERVATORY, AB, Canada

WMO: 719825

Lat: 50.8691N

Lon: 114.2917W

Elev: 1271

StdP: 86.96

Time Zone: -7.00 (NAM)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-26.8	-24.3	-29.7	0.3	-26.6	-27.0	0.4	-23.9	12.7	3.0	10.6	2.6	2.8	200	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	27.4	14.9	25.7	14.5	24.0	13.9	16.9	23.6	16.0	23.4	15.0	21.9	3.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.4	11.9	19.9	13.1	11.0	19.0	12.1	10.3	18.0	52.5	23.7	49.4	23.4	46.6	22.0	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	8.8	7.4	-30.6	31.1	3.1	2.4	-32.9	32.8	-34.7	34.2	-36.5	35.5	-38.8	37.2		
(5)			-30.8	19.5	3.1	1.7	-33.0	20.7	-34.8	21.7	-36.6	22.7	-38.8	23.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	-4.8	-7.4	-2.0	3.6	9.1	13.0	16.3	15.7	11.0	5.2	-2.2	-5.9	(6)
(7)		DBStd	10.31	8.30	8.77	7.91	5.13	4.76	3.34	3.10	3.48	5.26	5.20	7.33	7.66	(7)
(8)		HDD10.0	2675	457	487	373	198	74	9	1	3	51	163	366	493	(8)
(9)		HDD18.3	5123	716	721	631	441	286	163	77	94	223	408	614	751	(9)
(10)		CDD10.0	627	0	0	1	7	48	99	197	181	81	13	1	0	(10)
(11)		CDD18.3	34	0	0	0	0	1	3	14	14	3	0	0	0	(11)
(12)		CDH23.3	511	0	0	0	2	19	41	201	188	58	1	0	0	(12)
(13)		CDH26.7	91	0	0	0	0	1	6	39	38	7	0	0	0	(13)
(14)	Wind	WSAvg	3.6	3.6	3.5	3.7	3.9	3.7	3.6	3.5	3.3	3.3	3.7	3.6	3.5	(14)
(15)	Precipitation	PrecAvg	598	28	25	35	48	78	107	62	62	52	34	34	29	(15)
(16)		PrecMax	932	51	39	89	92	145	379	160	132	146	60	81	64	(16)
(17)		PrecMin	407	10	4	15	28	20	17	16	11	5	5	3	10	(17)
(18)		PrecStd	110	10	9	17	18	36	69	38	29	32	16	18	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	12.2	14.8	22.3	25.7	27.5	30.0	29.9	27.8	21.1	16.9	10.4	(19)
(20)			MCWB	4.6	4.2	5.5	9.1	11.6	15.8	15.2	15.1	12.9	9.7	6.6	2.7	(20)
(21)		2%	DB	9.2	8.7	12.1	17.9	23.2	24.2	27.5	27.2	25.0	18.1	12.0	8.1	(21)
(22)			MCWB	2.8	2.5	4.6	7.6	11.1	13.9	15.6	14.9	13.0	9.0	5.3	1.9	(22)
(23)		5%	DB	7.5	6.3	9.9	14.7	20.7	22.1	25.6	25.4	22.8	15.1	9.2	6.0	(23)
(24)			MCWB	1.9	1.0	3.1	5.9	10.3	13.2	15.5	14.6	12.4	7.5	3.5	0.9	(24)
(25)		10%	DB	5.8	4.0	7.6	11.8	18.3	20.4	23.7	23.3	20.0	13.0	6.8	4.1	(25)
(26)			MCWB	0.7	-0.6	2.0	4.1	9.1	12.1	14.8	14.3	11.3	6.3	1.8	-0.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	4.9	6.5	9.7	12.7	16.8	19.2	17.6	15.1	11.0	7.3	3.8	(27)
(28)			MCDWB	11.1	10.9	13.6	21.0	22.4	24.8	25.2	24.1	23.3	19.3	15.5	8.9	(28)
(29)		2%	WB	3.1	2.6	4.9	7.9	11.6	15.1	17.4	16.4	13.9	9.5	5.5	2.3	(29)
(30)			MCDWB	8.6	8.4	11.3	16.9	21.6	22.0	23.6	24.0	22.9	16.6	11.4	7.4	(30)
(31)		5%	WB	2.1	1.1	3.6	6.3	10.6	13.8	16.4	15.6	12.8	8.0	3.9	0.9	(31)
(32)			MCDWB	7.3	6.1	9.4	13.9	19.6	21.1	23.2	23.2	21.5	14.3	8.6	5.9	(32)
(33)		10%	WB	0.8	-0.4	2.1	4.7	9.4	12.7	15.5	14.7	11.6	6.5	2.1	-0.4	(33)
(34)			MCDWB	5.5	3.4	7.5	10.7	17.3	19.0	22.3	21.6	19.4	12.6	6.3	3.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.1	9.4	9.8	10.5	11.3	11.2	12.0	12.1	11.3	10.3	9.1	8.6	(35)
(36)			MCDBR	10.5	10.7	12.6	15.0	15.1	13.8	15.0	15.3	15.5	13.3	11.9	10.9	(36)
(37)			MCWBR	6.5	6.6	7.3	7.6	7.0	7.0	6.9	6.7	7.1	7.0	6.9	7.1	(37)
(38)		5% WB	MCDBR	10.6	10.8	12.2	14.7	14.1	12.8	12.9	13.5	14.6	13.0	12.1	11.0	(38)
(39)			MCWBR	6.9	6.9	7.3	7.7	6.7	6.9	7.0	6.8	7.0	7.1	7.2	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.246	0.268	0.276	0.332	0.337	0.340	0.336	0.350	0.307	0.274	0.250	0.234	(40)	
(41)		taud	2.449	2.434	2.479	2.327	2.384	2.410	2.431	2.397	2.496	2.571	2.519	2.442	(41)	
(42)		Ebn at Noon	819	885	941	910	918	915	913	881	891	872	812	781	(42)	
(43)		Edh at Noon	56	75	87	114	113	111	107	106	85	65	52	48	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.13	2.09	3.29	4.60	5.38	5.72	6.41	5.28	3.72	2.30	1.22	0.89	(44)	
(45)		RadStd	0.08	0.15	0.23	0.32	0.44	0.45	0.44	0.37	0.41	0.23	0.09	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (68 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page