

REA POINT, NU, Canada

WMO: 719830

Lat: 75.367N

Lon: 105.717W

Elev: 49

StdP: 14.67

Time Zone: -7.00 (NAM)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-44.3	-41.0	-51.5	0.3	-43.2	-48.3	0.3	-40.3	43.4	-15.0	39.7	-17.8	7.3	310	1.209

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	48.1	45.3	45.2	43.1	43.0	41.3	45.9	47.7	43.5	45.2	41.6	43.0	12.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.3	43.1	46.8	42.0	39.4	44.4	40.2	36.8	42.2	18.1	47.9	16.9	45.2	16.0	43.2	54.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
34.7	30.2	27.1	-47.8	54.1	4.6	4.0	-51.1	57.0	-53.8	59.4	-56.4	61.6	-59.8	64.5
			-47.2	50.0	3.3	3.3	-49.6	52.4	-51.6	54.3	-53.4	56.2	-55.8	58.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.0	-22.9	-25.0	-23.6	-5.8	15.1	33.0	39.3	35.2	24.0	6.2	-9.6	-20.2
	DBStd	25.09	9.32	9.24	9.53	9.58	8.68	5.21	3.74	3.44	6.72	9.38	9.08	8.62
	HDD50	16805	2260	2101	2283	1675	1081	511	334	458	780	1358	1788	2176
	HDD65	22279	2725	2521	2748	2125	1546	961	798	923	1230	1823	2238	2641
	CDD50	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.6	14.1	13.1	13.1	12.6	11.9	11.7	11.8	11.4	13.5	12.4	12.5	13.6
Precipitation	PrecAvg	6.5	0.2	0.2	0.2	0.2	0.3	0.7	1.1	1.3	0.8	0.7	0.4	0.3
	PrecMax	10.2	0.6	0.8	0.8	0.7	1.1	1.8	2.2	2.4	1.4	1.3	1.0	0.9
	PrecMin	2.0	0.0	0.0	0.0	0.0	0.1	0.1	0.3	0.2	0.2	0.3	0.1	0.0
	PrecStd	1.8	0.2	0.2	0.2	0.2	0.2	0.4	0.5	0.5	0.4	0.3	0.3	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.3	5.1	4.7	25.4	35.9	50.4	54.8	47.4	39.4	28.7	17.6	10.6
		MCWB	2.9	4.6	4.2	24.7	33.3	45.9	50.6	45.3	38.0	28.4	17.4	10.5
	2%	DB	-2.4	-2.1	-1.4	18.3	32.9	44.4	50.0	43.6	35.8	26.7	12.8	3.2
		MCWB	-2.9	-2.8	-1.9	17.6	31.8	42.2	46.8	42.0	34.9	26.2	12.6	2.7
	5%	DB	-5.3	-6.6	-6.2	12.4	30.5	40.8	47.0	41.7	33.6	24.1	7.7	-2.5
		MCWB	-5.7	-7.0	-6.7	11.7	29.7	39.2	44.5	40.4	33.0	23.8	7.2	-2.9
	10%	DB	-9.1	-11.0	-10.1	8.7	28.0	38.5	45.0	40.0	32.1	21.1	4.0	-7.2
		MCWB	-9.5	-11.4	-10.6	8.1	27.2	37.2	42.9	39.0	31.6	20.7	3.6	-7.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	4.4	4.4	24.7	34.2	46.7	51.1	46.0	38.3	28.1	17.3	10.4
		MCDB	3.1	4.9	4.6	25.4	35.1	49.9	54.0	46.8	39.4	28.1	17.4	10.5
	2%	WB	-2.8	-2.7	-1.7	17.7	31.6	42.3	47.9	42.6	35.1	25.6	12.5	2.9
		MCDB	-2.6	-2.3	-1.4	18.2	32.5	44.3	50.1	43.6	35.5	25.9	12.7	3.2
	5%	WB	-5.7	-6.9	-6.6	11.8	29.6	39.4	45.0	40.7	33.0	22.9	7.3	-2.9
		MCDB	-5.3	-6.7	-6.3	12.3	30.4	40.8	46.8	41.6	33.4	23.1	7.7	-2.6
	10%	WB	-9.5	-11.3	-10.4	8.1	27.1	37.5	43.2	39.3	31.5	20.0	3.6	-7.5
		MCDB	-9.2	-11.0	-10.0	8.7	27.8	38.5	45.0	40.1	31.9	20.4	4.0	-7.2
Mean Daily Temperature Range	5% DB	MDBR	10.9	10.8	11.3	13.0	10.4	6.5	7.6	6.5	6.7	10.0	11.0	10.8
		MCDBR	15.8	15.2	15.1	12.8	10.3	9.5	11.2	9.6	6.9	10.1	15.5	17.1
		MCWBR	15.7	15.0	15.0	12.3	9.6	7.4	8.9	8.2	6.6	10.0	15.4	17.1
	5% WB	MCDBR	15.8	15.2	15.1	12.5	10.7	9.0	11.1	9.8	6.9	10.1	15.6	17.0
		MCWBR	15.6	15.0	15.0	12.0	9.6	7.3	9.1	8.4	6.5	10.2	15.5	17.0
Clear-Sky Solar Irradiance	taub	N/A	0.155	0.225	0.282	0.308	0.337	0.338	0.314	0.263	0.179	N/A	N/A	
	taud	N/A	1.869	2.127	2.078	2.092	2.160	2.330	2.400	2.313	1.878	N/A	N/A	
	Ebn at Noon	0	87	220	251	263	259	255	244	208	57	0	0	
	Edh at Noon	0	5	18	31	36	36	30	23	16	4	0	0	
All-Sky Solar Radiation	RadAvg	0	23	349	1197	1819	1999	1590	915	364	72	0	0	
	RadStd	0	2	18	51	133	146	152	67	46	8	0	0	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page