

MOULD BAY, NT, Canada

WMO: 719890

Lat: 76.237N

Lon: 119.347W

Elev: 5

StdP: 14.69

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-48.8	-45.4	-57.2	0.2	-48.1	-53.3	0.2	-44.7	33.3	-13.8	29.9	-14.1	3.9	50	1.167

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	52.5	47.1	48.8	44.6	45.6	42.4	47.4	52.1	44.9	48.4	42.6	45.4	11.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
43.7	41.9	49.2	41.7	38.8	46.8	39.8	36.1	44.5	18.8	52.5	17.6	48.6	16.4	45.5	54.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.2	25.7	22.8	DB	-51.6	55.5	5.4	4.7	-55.6	58.9	-58.7	61.7	-61.8	64.3	-65.7	67.8	(4)
(5)			WB	-51.4	49.7	5.1	3.0	-55.1	51.9	-58.1	53.7	-60.9	55.3	-64.6	57.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.3	-24.7	-26.5	-23.3	-8.2	15.0	33.2	39.8	35.2	23.1	4.1	-10.2	-20.5		
	DBStd	25.91	10.98	10.67	11.53	9.68	9.41	5.68	5.21	5.37	7.52	10.48	10.32	10.88		
	HDD50	17067	2316	2142	2271	1746	1084	505	320	460	808	1423	1807	2185		
	HDD65	22537	2781	2562	2736	2196	1549	954	781	925	1258	1888	2257	2650		
	CDD50	4	0	0	0	0	0	0	4	0	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	9.6	9.1	8.2	8.7	8.6	9.3	10.8	11.4	10.9	11.1	9.4	8.7	8.7		
	PrecAvg	4.5	0.1	0.2	0.1	0.2	0.4	0.4	0.6	1.0	0.7	0.5	0.2	0.2		
(15) Precipitation	PrecMax	6.3	0.5	0.8	0.5	0.8	1.4	1.2	1.4	2.6	2.2	1.3	0.7	0.7		
	PrecMin	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0		
	PrecStd	1.1	0.2	0.2	0.1	0.2	0.3	0.3	0.4	0.6	0.4	0.3	0.2	0.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	6.0	10.0	23.4	35.8	51.3	59.0	53.9	39.4	29.1	21.0	14.4		
		MCWB	7.0	5.2	9.3	22.1	32.4	46.0	49.1	47.7	37.8	28.7	20.3	13.8		
	2%	DB	0.6	-1.1	4.2	15.3	32.8	47.1	55.0	48.6	36.2	26.6	14.2	6.1		
		MCWB	0.1	-1.5	3.7	14.4	30.8	42.9	48.3	45.1	35.1	26.0	13.6	5.6		
	5%	DB	-3.4	-5.8	-1.6	10.4	30.4	43.0	51.4	45.1	34.2	23.7	8.3	0.6		
		MCWB	-3.9	-6.3	-2.0	9.6	28.8	39.8	46.5	42.4	33.4	23.0	7.8	0.1		
	10%	DB	-8.3	-10.1	-6.0	6.2	28.1	40.3	48.2	42.5	32.5	19.8	4.7	-3.7		
		MCWB	-8.7	-10.5	-6.4	5.5	26.7	37.8	44.1	40.3	31.7	19.1	4.2	-4.2		
	0.4%	WB	7.3	5.7	9.4	22.1	33.1	46.7	50.9	48.5	38.1	28.8	20.5	14.0		
		MCDB	7.7	6.2	9.7	23.3	35.4	50.9	56.8	52.8	38.9	28.8	21.0	14.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	0.3	-1.5	3.8	14.4	31.0	42.9	48.6	45.2	35.3	26.0	13.5	5.6		
		MCDB	0.7	-1.2	4.2	15.3	32.5	46.6	54.0	48.2	35.9	26.6	14.1	6.0		
	5%	WB	-3.8	-6.3	-2.0	9.6	28.9	40.2	46.6	42.7	33.6	23.1	7.9	0.1		
		MCDB	-3.4	-5.8	-1.6	10.3	30.2	42.8	51.4	44.9	34.2	23.6	8.3	0.5		
	10%	WB	-8.6	-10.5	-6.4	5.5	26.6	37.9	44.4	40.5	31.8	19.2	4.2	-4.2		
		MCDB	-8.3	-10.1	-6.0	6.2	27.8	40.0	47.8	42.3	32.4	19.8	4.6	-3.8		
	5% DB	MDBR	13.0	13.6	12.9	14.7	10.8	7.1	8.4	6.8	7.0	11.3	12.5	12.5		
		MCDBR	18.2	18.8	15.5	14.5	11.1	10.4	13.4	10.9	6.2	11.4	14.9	16.7		
		MCWBR	18.0	18.7	15.3	14.0	10.0	7.6	9.1	8.2	5.4	11.3	14.9	16.6		
		MCWBR	18.1	18.9	15.3	14.3	10.5	10.1	12.4	10.5	5.9	11.4	15.0	16.9		
(35) Mean Daily Temperature Range	5% WB	MCWBR	17.9	18.8	15.2	13.8	9.3	7.5	9.0	8.0	5.4	11.4	15.0	16.8		
	Clear-Sky Solar Irradiance	taub	N/A	0.162	0.230	0.305	0.328	0.341	0.335	0.317	0.287	0.173	N/A	N/A		
		taud	N/A	1.881	2.102	2.005	2.041	2.209	2.373	2.403	2.153	1.892	N/A	N/A		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	0	59	208	235	252	256	254	240	180	41	0	0		
		Edh at Noon	0	3	17	33	38	34	28	23	17	3	0	0		
(44) All-Sky Solar Radiation	RadStd		0	17	326	1159	1740	2023	1535	883	374	59	0	0		
			0	1	18	81	137	139	141	80	34	7	0	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page