

KEE FIELD, WV, USA

WMO: 720160

Lat: 37.601N

Lon: 81.559W

Elev: 1783

StdP: 13.77

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 63884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	14.9	1.0	6.2	18.0	6.4	8.2	22.2	10.1	34.9	8.6	36.7	0.7	310	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	89.9	72.6	87.9	71.8	85.8	71.3	76.7	84.1	75.2	82.9	73.9	81.2	1.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.6	138.5	79.7	73.0	130.9	78.3	72.1	126.9	77.4	41.5	85.0	40.0	83.1	38.8	81.1	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.4	5.3	1.4	92.7	7.4	2.5	-4.0	94.6	-8.4	96.0	-12.5	97.4	-17.9	99.3		
			1.0	78.7	8.0	2.3	-4.8	80.3	-9.5	81.7	-13.9	82.9	-19.7	84.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.4	34.4	37.1	45.4	55.8	64.0	70.9	73.8	73.3	67.9	56.6	45.6	38.8	(6)
	DBStd	16.23	10.61	10.37	10.05	8.53	7.54	4.75	4.30	4.07	6.01	8.67	8.79	9.57	(7)
	HDD50	1711	493	373	212	43	3	0	0	0	37	183	367		(8)
	HDD65	4465	948	782	609	288	114	10	2	1	38	280	581	812	(9)
	CDD50	3684	10	11	69	218	437	628	736	724	537	242	52	20	(10)
	CDD65	964	0	0	1	13	83	189	273	260	125	20	0	0	(11)
	CDH74	7479	0	2	46	361	781	1441	1942	1696	984	214	11	1	(12)
	CDH80	2341	0	0	4	82	204	449	673	552	333	43	1	0	(13)
(14) Wind	WSAvg	0.9	1.2	1.4	1.4	1.7	0.9	0.7	0.5	0.4	0.5	0.7	0.7	1.0	(14)
(15) Precipitation	PrecAvg	48.0	3.9	3.3	4.4	4.1	4.9	4.8	5.4	4.1	3.3	2.8	3.1	3.9	(15)
	PrecMax	65.5	6.9	8.1	8.0	6.3	9.0	8.4	9.7	6.1	6.7	5.6	7.7	6.8	(16)
	PrecMin	38.6	2.0	1.1	1.4	1.8	2.0	1.8	2.3	1.5	1.1	0.6	0.9	2.1	(17)
	PrecStd	6.5	1.3	1.5	1.7	1.4	2.2	1.7	1.9	1.3	1.5	1.4	1.5	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.2	69.7	79.2	87.2	88.7	90.3	91.4	91.2	91.0	84.2	74.8	69.8	(19)
		MCWB	58.4	56.0	59.4	61.2	69.6	72.2	74.9	74.8	69.7	68.9	61.5	61.3	(20)
	2%	DB	59.5	63.0	73.2	82.0	85.3	88.0	89.5	88.4	88.0	79.6	69.7	63.0	(21)
		MCWB	53.2	52.5	56.2	60.0	67.8	72.4	74.0	73.4	69.7	64.9	57.3	56.8	(22)
	5%	DB	54.4	57.5	68.3	78.8	81.9	85.7	86.8	86.1	84.0	75.2	64.0	57.8	(23)
		MCWB	50.2	50.1	54.2	58.8	67.2	71.6	73.0	72.9	69.9	63.1	54.8	53.9	(24)
	10%	DB	50.1	53.5	62.9	73.2	79.0	82.2	83.9	82.8	80.2	70.5	60.0	53.7	(25)
		MCWB	46.9	47.4	52.5	57.1	65.8	70.0	72.0	72.1	67.9	61.5	53.1	51.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.2	59.7	62.7	67.0	74.0	76.7	79.3	79.3	76.2	71.3	63.3	63.0	(27)
		MCDB	63.0	62.7	73.4	79.8	83.2	85.0	86.4	85.5	84.1	79.5	70.9	66.7	(28)
	2%	WB	54.7	54.8	59.8	64.3	71.3	75.1	76.9	76.5	73.5	68.9	59.9	58.7	(29)
		MCDB	57.9	59.9	69.2	74.6	80.3	83.3	84.0	83.6	81.5	75.7	65.5	61.9	(30)
	5%	WB	50.8	51.4	57.4	61.9	69.4	73.6	75.3	74.8	71.6	66.1	57.4	54.5	(31)
		MCDB	53.5	56.3	65.1	71.2	77.8	81.5	83.1	81.6	79.1	71.2	62.1	56.7	(32)
	10%	WB	46.4	47.6	54.3	59.7	67.8	72.1	73.9	73.3	69.7	63.2	54.4	51.0	(33)
		MCDB	49.1	52.8	60.2	68.4	75.5	79.4	80.9	80.0	76.3	67.9	58.3	53.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.2	19.7	22.6	26.7	23.3	22.0	20.2	20.1	22.1	23.0	22.2	17.5	(35)
		MCDBR	24.6	28.4	32.4	35.3	27.6	25.6	23.6	23.3	27.4	28.4	28.3	23.9	(36)
	5% WB	MCWBR	17.5	18.3	16.3	14.5	12.3	11.4	9.8	10.2	11.1	14.1	16.8	16.9	(37)
		MCWBR	21.4	24.4	26.0	26.4	23.8	22.3	20.5	20.4	23.0	22.6	22.3	21.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.300	0.310	0.333	0.375	0.418	0.443	0.472	0.481	0.377	0.347	0.314	0.293	(40)
		taud	2.510	2.469	2.458	2.354	2.228	2.198	2.140	2.091	2.378	2.467	2.532	2.552	(41)
	Ebn at Noon		283	293	296	287	275	267	258	252	277	276	275	279	(42)
		Edh at Noon	25	30	33	38	44	46	48	49	35	29	24	23	(43)
(44) All-Sky Solar Radiation	RadAvg		618	822	1181	1551	1735	1908	1782	1670	1413	1057	771	547	(44)
	RadStd		65	113	93	119	135	121	103	84	133	133	90	61	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+241	+128

Nomenclature: See separate page