

BRIDGEPORT, TX, USA

WMO: 720261

Lat: 33.175N

Lon: 97.828W

Elev: 851

StdP: 14.25

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53976

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.2	24.6	8.3	8.7	27.3	12.1	10.5	35.8	22.3	50.6	20.4	51.7	4.9	0	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.7	102.2	71.7	99.4	71.9	96.8	72.2	77.4	90.3	76.6	89.0	75.7	87.6	7.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.6	133.4	80.5	73.4	128.1	79.7	72.6	124.8	79.8	41.4	90.7	40.5	88.9	39.7	87.7	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.8	17.8	16.2	13.0	104.2	3.9	3.8	10.2	106.9	7.9	109.1	5.7	111.2	2.8	114.0		
			12.6	78.6	3.6	1.8	10.0	79.9	7.8	81.0	5.8	82.0	3.2	83.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	44.7	48.5	57.2	63.8	71.7	80.5	83.3	83.8	76.2	65.3	54.9	45.9
	DBStd	16.12	9.82	11.06	9.95	8.16	7.26	4.88	4.92	5.49	6.03	8.76	9.37	9.51
	HDD50	680	223	148	45	7	0	0	0	0	0	6	57	194
	HDD65	2544	633	471	277	117	26	0	0	0	2	104	320	594
	CDD50	6059	57	106	268	422	673	914	1032	1049	786	480	204	68
	CDD65	2449	2	9	36	82	234	464	567	584	338	113	17	3
	CDH74	29570	35	108	352	813	2374	5502	7476	7639	3756	1295	188	32
	CDH80	14911	2	22	81	223	913	2766	4262	4405	1770	428	37	2
Wind	WSAvg	6.7	7.0	7.5	8.3	8.3	7.3	7.0	5.5	5.4	5.0	5.9	6.4	6.4
Precipitation	PrecAvg	35.0	1.7	2.4	3.0	3.3	3.7	3.8	2.3	2.2	3.6	3.8	2.4	2.1
	PrecMax	47.4	3.6	7.4	8.1	10.7	6.8	12.2	4.7	5.8	8.8	9.4	6.2	8.4
	PrecMin	25.1	0.1	0.0	0.0	0.3	1.2	1.2	0.1	0.0	0.6	0.5	0.1	0.0
	PrecStd	6.1	1.0	2.0	1.9	2.2	1.9	2.6	1.6	1.6	2.2	2.9	2.1	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	82.4	86.8	91.1	95.5	100.6	106.1	106.4	99.1	92.6	84.7	78.8
		MCWB	56.6	61.1	63.5	65.5	72.4	72.1	71.0	70.6	69.8	69.8	64.4	60.8
	2%	DB	72.4	77.2	81.8	86.1	91.3	98.0	102.2	103.3	95.0	88.4	79.2	72.3
		MCWB	55.4	59.7	62.6	66.2	71.3	71.8	71.2	71.0	71.4	69.4	61.2	57.5
	5%	DB	67.7	72.3	77.7	81.8	88.4	95.1	99.3	99.8	92.2	84.8	75.0	67.9
		MCWB	55.0	58.3	61.8	65.6	69.6	72.6	71.5	72.6	71.6	67.9	61.3	56.7
	10%	DB	63.1	67.8	73.4	78.9	85.7	92.4	96.3	97.1	90.0	81.5	71.4	63.2
		MCWB	51.8	56.5	59.9	64.2	69.6	73.2	72.4	72.7	70.8	65.7	59.9	53.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.1	66.2	68.4	72.7	76.9	79.2	79.1	78.0	77.4	74.8	70.2	66.3
		MCDB	69.0	74.1	79.0	81.1	89.4	90.2	91.7	91.8	88.9	84.7	76.6	72.0
	2%	WB	60.2	64.0	66.4	70.4	74.8	77.0	77.4	77.1	75.9	72.8	66.6	62.4
		MCDB	66.9	71.5	76.0	79.0	85.8	88.7	90.3	90.8	86.1	82.0	71.9	69.1
	5%	WB	56.1	61.5	64.8	68.7	73.3	75.8	76.4	76.2	74.8	71.2	64.3	58.9
		MCDB	66.0	68.8	73.4	77.3	83.2	87.4	88.6	89.5	84.4	80.3	70.7	64.0
	10%	WB	52.1	58.3	63.1	67.1	72.0	74.8	75.2	75.3	73.6	69.3	62.1	54.5
		MCDB	61.9	66.6	71.0	76.0	81.5	86.3	86.9	88.2	82.8	77.7	70.0	61.8
Mean Daily Temperature Range	5% DB	MDBR	23.7	22.9	23.6	23.5	21.6	20.9	22.8	22.7	23.0	24.7	24.1	22.5
		MCDBR	31.9	30.0	27.9	27.0	25.6	23.8	26.7	25.6	25.5	27.1	28.9	30.5
		MCWBR	18.2	16.5	13.5	13.2	9.3	5.9	6.2	6.0	7.7	11.6	15.4	17.7
	5% WB	MCDBR	27.7	25.9	21.6	20.6	20.0	20.4	20.9	21.7	20.1	21.2	20.3	23.0
		MCWBR	18.6	17.0	11.9	12.2	9.8	7.2	6.7	6.3	7.1	10.4	14.7	16.9
Clear-Sky Solar Irradiance	taub	0.305	0.315	0.348	0.382	0.418	0.431	0.433	0.427	0.394	0.353	0.326	0.310	
	taud	2.510	2.488	2.417	2.344	2.308	2.308	2.342	2.337	2.379	2.478	2.490	2.495	
	Ebn at Noon	291	298	295	287	277	272	270	271	276	281	279	282	
	Edh at Noon	27	30	35	40	42	42	40	39	36	30	27	26	
All-Sky Solar Radiation	RadAvg	938	1117	1467	1778	1910	2136	2159	1975	1649	1291	993	818	
	RadStd	96	173	104	147	195	197	144	120	145	192	128	101	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page