

BAINBRIDGE, GA, USA

WMO: 720268

Lat: 30.983N

Lon: 84.633W

Elev: 141

StdP: 14.62

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 53882

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.1	33.6	16.1	12.5	36.6	19.5	14.7	41.5	21.5	52.3	19.2	54.3	3.6	320	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	98.6	77.0	96.8	77.3	95.0	77.5	82.6	92.0	81.3	90.2	80.3	88.6	6.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	160.4	86.6	79.2	152.4	84.8	78.7	149.5	84.2	46.3	92.8	44.9	90.8	43.9	90.1	97.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.4	16.2	13.4	DB	24.7	101.5	2.8	6.6	22.6	106.2	21.0	110.1	19.4	113.8	17.4	118.6	
			WB	23.1	84.8	3.0	4.4	20.9	88.0	19.1	90.6	17.4	93.1	15.3	96.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.5	52.6	56.4	61.7	68.8	76.4	82.8	83.9	83.6	79.8	70.6	60.3	55.8
	DBStd	13.15	9.73	8.86	8.05	5.71	5.30	3.42	2.71	3.09	4.28	7.31	7.77	9.37
	HDD50	187	86	36	10	0	0	0	0	0	0	0	9	46
	HDD65	1373	397	261	159	28	3	0	0	0	0	34	181	310
	CDD50	7292	167	216	373	563	819	985	1052	1042	893	638	318	226
	CDD65	3002	13	20	57	141	357	535	587	577	443	207	40	25
	CDH74	30186	61	144	495	1320	3519	5740	6422	6077	4180	1775	326	127
	CDH80	13317	1	15	79	353	1534	2825	3123	2887	1878	575	42	5
Wind	WSAvg	5.2	5.9	6.0	6.5	6.1	5.5	4.4	4.0	3.9	4.9	5.2	5.2	5.5
Precipitation	PrecAvg	55.7	5.0	4.0	5.7	3.8	3.2	5.7	6.5	5.8	5.4	3.3	3.4	3.3
	PrecMax	76.3	16.1	7.5	11.7	8.0	12.1	10.9	11.5	11.3	16.7	10.2	12.6	5.1
	PrecMin	36.5	1.1	0.6	0.7	1.2	0.4	2.0	3.5	2.1	1.6	0.3	0.7	1.7
	PrecStd	11.6	3.2	2.2	3.5	2.0	2.7	2.8	2.1	2.3	3.7	2.6	2.7	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	81.9	85.9	90.3	97.0	99.8	99.3	99.5	97.3	92.6	84.2	81.0
		MCWB	67.9	68.9	67.9	73.1	72.8	76.4	78.6	77.3	75.1	74.4	71.2	70.1
	2%	DB	75.4	78.8	81.8	87.7	93.3	97.4	97.4	97.3	95.0	89.8	81.0	77.4
		MCWB	66.3	65.5	67.1	71.3	71.8	76.1	78.2	77.9	76.2	74.7	69.6	67.8
	5%	DB	72.2	74.6	80.5	83.8	90.9	96.5	95.5	95.3	91.4	86.2	78.6	73.3
		MCWB	65.2	64.9	66.2	69.0	71.0	76.6	78.9	79.0	75.3	71.2	66.3	67.7
	10%	DB	69.5	71.9	76.8	81.4	88.5	93.1	93.2	92.7	90.3	82.3	73.5	71.6
		MCWB	64.4	64.0	64.0	66.8	71.4	76.1	77.5	77.9	75.3	69.9	64.0	66.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	72.0	73.1	76.8	79.6	84.1	84.2	83.4	82.9	80.8	74.6	73.5
		MCDB	75.1	78.0	78.9	85.3	88.1	94.0	93.8	93.0	91.1	85.8	80.5	78.1
	2%	WB	68.9	69.8	71.2	73.8	77.3	81.4	82.4	82.1	80.0	77.5	72.5	71.5
		MCDB	72.5	74.3	77.3	81.8	84.8	90.4	92.2	91.4	87.3	83.2	77.9	75.7
	5%	WB	66.5	67.8	69.3	72.0	75.4	79.9	81.2	80.9	78.4	75.4	70.3	69.6
		MCDB	71.3	73.1	74.8	79.4	83.9	88.4	90.4	89.8	86.3	81.5	74.4	71.9
	10%	WB	63.7	65.0	67.0	70.3	74.1	78.4	80.2	79.7	77.3	73.7	67.9	66.7
		MCDB	66.7	69.8	74.2	76.6	82.3	87.3	88.5	87.8	85.7	79.9	73.3	71.2
Mean Daily Temperature Range	5% DB	MDBR	20.9	21.7	22.4	22.5	21.7	19.6	19.1	18.4	19.6	22.4	23.6	20.4
		MCDBR	22.7	24.5	24.8	25.5	24.5	23.0	21.6	21.0	21.6	24.1	24.9	21.4
		MCWBR	14.6	14.6	12.2	10.4	7.7	7.0	7.4	7.3	7.4	10.0	14.1	14.3
	5% WB	MCDBR	19.5	20.0	20.5	20.2	19.3	19.7	19.3	18.4	17.9	17.6	19.7	18.6
		MCWBR	14.3	15.0	12.7	11.1	8.0	8.3	8.2	7.7	7.7	9.1	13.1	14.7
Clear-Sky Solar Irradiance	taub		0.328	0.337	0.356	0.384	0.439	0.486	0.507	0.495	0.428	0.376	0.350	0.334
	taud		2.511	2.481	2.439	2.362	2.238	2.166	2.124	2.156	2.327	2.447	2.459	2.510
	Ebn at Noon		286	293	294	288	272	258	252	253	267	276	275	278
	Edh at Noon		28	31	35	39	45	48	50	48	39	32	29	27
All-Sky Solar Radiation	RadAvg		972	1155	1536	1874	2048	1907	1871	1726	1573	1380	1090	851
	RadStd		64	139	125	150	141	147	124	123	124	134	85	82

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (36 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+284	+180

Nomenclature: See separate page