

BAINBRIDGE, GA, USAWMO: **720268**Lat: **30.983N**Lon: **84.633W**Elev: **43**StdP: **100.81**Time Zone: **-5.00 (NAE)**Period: **04-19**WBAN: **53882****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	0.9	-8.8	1.8	2.6	-7.0	2.1	5.3	9.6	11.3	8.6	12.4	1.6	320	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	37.0	25.0	36.0	25.1	35.0	25.3	28.1	33.4	27.4	32.3	26.8	31.4	2.9	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	22.9	30.3	26.2	21.8	29.3	25.9	21.4	29.0	89.8	33.8	86.6	32.6	84.3	32.3	36.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.2	7.2	6.0	-4.1	38.6	1.6	3.7	-5.2	41.2	-6.1	43.4	-7.0	45.4	-8.1	48.1	
			DB												
			WB	-5.0	29.3	1.7	2.5	-6.2	31.1	-7.1	32.5	-8.1	33.9	-9.3	35.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	11.5	13.6	16.5	20.4	24.7	28.2	28.9	28.7	26.5	21.4	15.7	13.2
	DBStd	7.31	5.40	4.92	4.47	3.17	2.94	1.90	1.51	1.72	2.38	4.06	4.32	5.21
	HDD10.0	104	48	20	6	0	0	0	0	0	0	0	5	26
	HDD18.3	763	221	145	88	16	2	0	0	0	0	19	101	172
	CDD10.0	4051	93	120	207	313	455	547	584	579	496	354	177	126
	CDD18.3	1668	7	11	32	78	198	297	326	321	246	115	22	14
	CDH23.3	16770	34	80	275	733	1955	3189	3568	3376	2322	986	181	71
	CDH26.7	7398	1	8	44	196	852	1569	1735	1604	1043	319	23	3
Wind	WSAvg	2.3	2.6	2.7	2.9	2.7	2.4	2.0	1.8	1.7	2.2	2.3	2.3	2.5
Precipitation	PrecAvg	1416	126	101	145	97	82	146	165	147	138	85	86	83
	PrecMax	1939	410	191	297	204	307	278	293	287	423	258	320	130
	PrecMin	926	29	14	17	30	10	51	88	54	40	7	19	43
	PrecStd	294	82	55	90	52	68	72	54	59	93	65	69	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	27.7	29.9	32.4	36.1	37.7	37.4	37.5	36.3	33.7	29.0	27.2
		MCWB	20.0	20.5	20.0	22.8	22.7	24.7	25.9	25.2	23.9	23.6	21.8	21.2
	2%	DB	24.1	26.0	27.7	31.0	34.0	36.4	36.3	36.3	35.0	32.1	27.2	25.2
		MCWB	19.1	18.6	19.5	21.8	22.1	24.5	25.7	25.5	24.6	23.7	20.9	19.9
	5%	DB	22.3	23.6	27.0	28.8	32.7	35.8	35.3	35.1	33.0	30.1	25.9	23.0
		MCWB	18.4	18.3	19.0	20.6	21.7	24.8	26.0	26.1	24.0	21.8	19.1	19.8
	10%	DB	20.8	22.1	24.9	27.4	31.4	33.9	34.0	33.7	32.4	27.9	23.1	22.0
		MCWB	18.0	17.8	17.8	19.3	21.9	24.5	25.3	25.5	24.1	21.1	17.8	19.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.2	22.9	24.9	26.4	28.9	29.0	28.6	28.3	27.1	23.7	23.1
		MCDB	24.0	25.6	26.1	29.6	31.1	34.4	34.3	33.9	32.9	29.9	26.9	25.6
	2%	WB	20.5	21.0	21.8	23.2	25.2	27.5	28.0	27.8	26.7	25.3	22.5	22.0
		MCDB	22.5	23.5	25.2	27.6	29.3	32.4	33.4	33.0	30.7	28.4	25.5	24.3
	5%	WB	19.1	19.9	20.7	22.2	24.1	26.6	27.3	27.2	25.8	24.1	21.3	20.9
		MCDB	21.8	22.8	23.8	26.3	28.9	31.4	32.4	32.1	30.2	27.5	23.5	22.2
	10%	WB	17.6	18.3	19.4	21.3	23.4	25.8	26.8	26.5	25.2	23.2	19.9	19.3
		MCDB	19.3	21.0	23.4	24.8	27.9	30.7	31.4	31.0	29.8	26.6	22.9	21.8
Mean Daily Temperature Range	5% DB	MDBR	11.6	12.1	12.5	12.5	12.0	10.9	10.6	10.2	10.9	12.4	13.1	11.3
		MCDBR	12.6	13.6	13.8	14.2	13.6	12.8	12.0	11.6	12.0	13.4	13.9	11.9
		MCWBR	8.1	8.1	6.8	5.8	4.3	3.9	4.1	4.1	4.1	5.6	7.8	8.0
	5% WB	MCDBR	10.8	11.1	11.4	11.2	10.7	10.9	10.7	10.2	9.9	9.8	10.9	10.4
		MCWBR	7.9	8.3	7.1	6.2	4.4	4.6	4.5	4.3	4.3	5.1	7.3	8.2
Clear-Sky Solar Irradiance	taub	0.328	0.337	0.356	0.384	0.439	0.486	0.507	0.495	0.428	0.376	0.350	0.334	
	taud	2.511	2.481	2.439	2.362	2.238	2.166	2.124	2.156	2.327	2.447	2.459	2.510	
	Ebn at Noon	903	925	928	908	856	812	793	798	843	870	866	875	
	Edh at Noon	88	99	110	124	141	151	157	150	122	101	92	84	
All-Sky Solar Radiation	RadAvg	3.06	3.64	4.84	5.91	6.46	6.01	5.90	5.44	4.96	4.35	3.44	2.68	
	RadStd	0.20	0.44	0.39	0.47	0.44	0.46	0.39	0.39	0.39	0.42	0.27	0.26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+158	+100

Nomenclature: See separate page