

COLUMBUS COUNTY AP, NC, USA

WMO: 720274

Lat: 34.273N

Lon: 78.715W

Elev: 30

StdP: 100.97

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 93799

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.1	-16.2	0.9	1.5	-13.1	1.2	2.6	8.0	17.7	7.1	17.7	1.1	0	0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	34.9	24.8	33.4	24.6	32.5	24.3	26.9	31.3	26.2	30.5	25.6	29.8	2.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.3	28.7	25.1	20.3	28.0	24.6	19.6	27.6	83.9	31.3	81.4	30.4	78.8	30.2	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.7	5.5	4.8	-7.3	36.9	2.0	1.1	-8.7	37.7	-9.8	38.4	-10.9	39.0	-12.4	39.9		
			-8.3	27.6	1.9	0.7	-9.7	28.1	-10.8	28.5	-11.9	28.8	-13.3	29.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	7.7	9.2	12.7	17.4	21.6	25.7	27.2	26.6	23.9	18.4	12.5	10.0	(6)
(7)		DBStd	8.04	5.65	5.19	5.00	4.19	3.46	2.69	2.07	2.04	2.69	4.40	4.61	5.27	(7)
(8)		HDD10.0	314	116	72	31	3	0	0	0	0	0	1	24	67	(8)
(9)		HDD18.3	1354	332	259	185	67	12	0	0	1	54	182	262	(9)	
(10)		CDD10.0	3152	42	49	114	223	359	470	533	514	416	263	100	67	(10)
(11)		CDD18.3	1152	1	3	9	38	113	221	275	256	167	57	7	4	(11)
(12)		CDH23.3	10095	4	21	83	304	916	2039	2754	2326	1211	382	40	15	(12)
(13)		CDH26.7	3859	0	1	10	61	286	847	1217	952	408	76	2	1	(13)
(14)	Wind	WSAvg	1.7	1.7	2.0	2.1	2.3	1.9	1.6	1.3	1.5	1.4	1.4	1.6	(14)	
(15)	Precipitation	PrecAvg	1355	101	89	100	83	100	131	142	162	167	94	86	85	(15)
(16)		PrecMax	1738	198	206	166	157	188	242	274	355	513	202	200	172	(16)
(17)		PrecMin	843	25	29	23	15	29	76	72	48	46	3	10	26	(17)
(18)		PrecStd	216	51	42	40	39	42	47	51	74	113	58	55	36	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.7	26.3	28.0	30.5	33.9	36.0	36.3	36.0	33.1	30.9	26.6	25.3	(19)
(20)		MCWB	18.0	18.1	17.3	19.5	22.6	25.5	26.0	25.1	22.9	22.9	19.6	19.4	(20)	
(21)		2%	DB	22.0	22.9	25.9	28.4	31.4	34.1	35.0	33.9	32.1	28.8	24.5	22.8	(21)
(22)		MCWB	17.4	17.2	17.1	18.9	21.6	24.5	25.1	25.2	23.5	21.8	18.5	18.6	(22)	
(23)		5%	DB	19.8	20.6	23.3	26.9	29.9	32.7	33.5	32.6	30.9	27.1	22.4	21.2	(23)
(24)		MCWB	16.3	15.5	15.8	18.6	21.4	24.0	25.1	24.8	22.7	20.7	17.7	18.1	(24)	
(25)		10%	DB	17.3	17.9	21.4	25.0	27.9	31.2	32.4	31.5	29.1	25.5	20.9	19.0	(25)
(26)		MCWB	13.9	13.8	15.1	17.6	20.6	23.2	24.8	24.5	22.6	20.4	17.2	16.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.9	19.7	20.0	23.3	24.5	27.5	28.0	27.8	25.8	25.2	21.8	21.6	(27)
(28)		MADB	21.6	23.3	24.4	26.4	28.9	33.3	33.8	31.4	29.6	27.2	24.7	23.6	(28)	
(29)		2%	WB	18.3	18.7	18.9	21.8	23.4	26.2	26.9	26.8	25.3	24.1	20.6	20.3	(29)
(30)		MADB	20.6	22.4	22.9	25.2	27.9	31.1	31.9	30.3	28.9	26.8	22.3	22.0	(30)	
(31)		5%	WB	16.6	16.9	17.8	20.5	22.7	25.5	26.2	26.1	24.6	23.1	19.2	18.5	(31)
(32)		MADB	19.3	19.2	21.4	23.9	27.2	30.0	30.8	29.9	28.1	25.6	21.3	20.2	(32)	
(33)		10%	WB	14.6	14.9	16.7	19.3	22.0	24.8	25.6	25.5	23.9	21.9	17.7	16.8	(33)
(34)		MADB	17.0	17.7	20.1	23.1	26.2	29.0	30.1	29.3	27.3	24.2	19.9	18.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.9	11.4	12.2	12.4	11.3	10.3	10.0	9.3	9.6	10.8	11.8	10.7	(35)	
(36)		5% DB	MADB	13.8	13.2	14.2	13.9	12.5	11.4	11.0	10.6	11.3	11.3	12.8	11.7	(36)
(37)		MCWBR	9.5	8.2	7.0	6.3	4.6	4.0	3.9	3.7	4.2	5.3	7.4	7.8	(37)	
(38)		5% WB	MADB	12.1	12.3	11.9	10.8	10.4	10.2	10.2	9.4	8.8	8.2	10.4	10.4	(38)
(39)	MCWBR	9.9	9.2	7.3	6.1	4.3	4.1	4.1	3.7	3.7	4.5	8.1	8.2	(39)		
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.333	0.369	0.401	0.465	0.493	0.537	0.512	0.433	0.397	0.350	0.323	(40)	
(41)		taud	2.500	2.469	2.394	2.295	2.165	2.131	2.027	2.091	2.308	2.370	2.463	2.534	(41)	
(42)		Ebn at Noon	887	916	904	887	830	803	765	778	829	830	846	866	(42)	
(43)		Edh at Noon	84	97	113	131	151	156	172	159	122	106	87	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.72	3.38	4.49	5.65	6.15	6.39	6.09	5.46	4.66	3.90	3.01	2.40	(44)	
(45)		RadStd	0.16	0.33	0.36	0.37	0.46	0.40	0.39	0.29	0.36	0.44	0.23	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (57 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+170	+121

Nomenclature: See separate page