

HENDERSON-OXFORD, NC, USA

WMO: 720288

Lat: 36.361N

Lon: 78.529W

Elev: 161

StdP: 99.41

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 03711

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.5	(c) -5.2	(d) -19.0	(e) 0.7	(f) -4.6	(g) -16.0	(h) 0.9	(i) -1.8	(j) 8.9	(k) 14.1	(l) 8.1	(m) 10.8	(n) 1.8	(o) 310	(p) 0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	34.0	23.1	32.5	22.6	31.1	22.3	24.6	30.2	24.0	29.5	23.5	28.6	2.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	18.1	26.0	22.6	17.6	25.7	22.2	17.3	25.5	75.1	31.1	72.9	29.4	70.9	28.8	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.7	6.7	5.6	-11.2	36.1	3.2	2.0	-13.5	37.5	-15.3	38.7	-17.1	39.8	-19.4	41.2		
			-12.2	25.5	2.9	0.8	-14.3	26.1	-16.0	26.5	-17.6	27.0	-19.7	27.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.1	4.3	5.8	9.6	14.9	19.2	23.4	25.3	24.5	21.7	15.5	9.5	6.5	(6)	
(7)		DBStd	8.60	5.79	5.32	5.56	4.40	3.94	2.99	2.41	2.50	3.10	4.50	4.78	5.13	(7)	
(8)		HDD10.0	627	193	138	78	8	0	0	0	0	0	8	67	135	(8)	
(9)		HDD18.3	1976	435	351	273	118	40	2	0	1	9	112	268	368	(9)	
(10)		CDD10.0	2477	16	22	67	157	285	401	476	449	351	177	51	27	(10)	
(11)		CDD18.3	784	0	1	3	17	67	153	217	192	109	23	2	1	(11)	
(12)		CDH23.3	6568	0	1	31	159	523	1358	1968	1578	782	158	7	3	(12)	
(13)		CDH26.7	2347	0	0	2	22	136	503	816	594	246	29	0	0	(13)	
(14)	Wind	WSAvg	2.3	2.6	2.7	2.8	3.0	2.4	2.1	1.9	1.6	1.8	2.1	2.2	2.3	(14)	
(15)	Precipitation	PrecAvg	1124	92	80	103	80	93	96	110	125	102	84	81	81	(15)	
(16)		PrecMax	1592	186	148	220	152	197	254	344	305	434	246	253	162	(16)	
(17)		PrecMin	793	18	4	18	14	17	10	25	25	12	0	12	8	(17)	
(18)		PrecStd	195	44	38	47	41	43	64	55	69	79	58	49	41	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	22.9	26.3	29.1	31.9	35.2	36.6	35.0	32.8	29.7	24.8	22.6	(19)	
(20)			MCWB	15.9	15.4	16.2	17.0	21.4	22.6	22.9	23.2	21.2	20.5	17.4	17.9	(20)	
(21)		2%	DB	18.0	20.2	23.6	27.1	29.9	32.9	34.2	33.0	31.0	27.1	21.9	19.7	(21)	
(22)			MCWB	14.3	13.8	15.2	17.2	20.2	22.4	23.4	23.2	21.5	19.5	15.5	16.7	(22)	
(23)		5%	DB	16.3	17.6	21.7	25.2	28.0	31.2	32.5	31.3	29.7	25.1	19.8	17.5	(23)	
(24)			MCWB	13.1	12.4	14.0	16.7	19.8	22.1	23.0	22.7	21.1	18.6	15.2	14.8	(24)	
(25)		10%	DB	13.8	15.1	18.8	23.0	26.5	29.8	31.0	30.0	27.8	22.8	17.6	15.1	(25)	
(26)			MCWB	9.8	10.2	12.8	15.9	18.9	21.5	22.8	22.2	20.6	18.4	14.0	12.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	17.1	18.1	20.8	22.9	24.6	25.2	25.5	24.3	22.9	19.4	19.4	(27)	
(28)			MCDWB	19.4	20.7	23.0	24.3	28.6	30.3	31.5	31.2	28.3	24.7	21.9	21.1	(28)	
(29)		2%	WB	15.5	15.6	16.8	19.4	21.7	23.8	24.6	24.7	23.3	22.0	17.8	17.3	(29)	
(30)			MCDWB	17.7	18.7	21.2	23.7	27.0	29.6	30.7	30.0	27.2	24.3	19.9	18.8	(30)	
(31)		5%	WB	13.8	13.7	15.7	18.2	20.9	23.2	24.1	24.0	22.7	20.9	16.3	15.3	(31)	
(32)			MCDWB	16.3	17.3	19.8	22.4	25.8	29.1	29.9	29.1	26.4	23.7	18.9	16.9	(32)	
(33)		10%	WB	10.8	11.0	14.2	17.1	20.2	22.6	23.6	23.3	22.0	19.2	14.6	12.5	(33)	
(34)			MCDWB	13.3	14.1	17.8	21.4	24.7	28.0	29.0	27.9	25.4	22.5	17.4	14.4	(34)	
(35)	Mean Daily Temperature Range			MDBR	9.8	10.5	11.4	12.0	11.0	10.6	10.3	9.9	10.1	10.8	10.8	9.5	(35)
(36)		5% DB	MCDBR	12.4	13.6	13.8	14.0	12.4	12.1	12.2	11.7	12.3	12.6	12.8	11.2	(36)	
(37)			MCWBR	9.3	8.7	7.3	6.4	5.0	3.9	3.6	3.8	4.4	6.2	7.8	8.5	(37)	
(38)		5% WB	MCDBR	11.3	12.1	11.9	11.1	10.5	10.7	10.3	10.0	9.6	9.8	10.5	10.0	(38)	
(39)			MCWBR	9.9	9.2	7.6	6.1	4.8	4.1	3.7	3.8	4.3	5.7	8.3	9.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.304	0.321	0.352	0.395	0.443	0.488	0.523	0.522	0.409	0.366	0.323	0.307	(40)	
(41)		taud		2.517	2.467	2.419	2.300	2.193	2.113	2.033	2.017	2.331	2.438	2.516	2.545	(41)	
(42)		Ebn at Noon		896	919	915	887	846	805	773	764	844	855	865	870	(42)	
(43)		Edh at Noon		80	94	108	129	146	158	170	169	117	96	80	74	(43)	
(44)	All-Sky Solar Radiation	RadAvg		2.50	3.21	4.21	5.33	5.91	6.41	6.01	5.45	4.48	3.62	2.76	2.17	(44)	
(45)		RadStd		0.18	0.37	0.31	0.42	0.47	0.44	0.34	0.28	0.40	0.45	0.22	0.19	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (58 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	+157	+104	

Nomenclature: See separate page