

MT PLEASANT, TX, USA

WMO: 720311

Lat: 33.096N

Lon: 94.961W

Elev: 111

StdP: 100.00

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53962

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-2.5	-12.1	1.3	1.0	-9.7	1.7	1.8	10.8	10.7	9.3	11.0	2.0	320	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.5	37.5	23.6	36.3	23.6	35.0	23.6	25.7	32.2	25.4	31.9	25.1	31.4	3.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.4	19.6	27.0	23.9	19.0	26.9	23.4	18.4	26.9	79.7	32.8	78.1	31.8	76.6	31.5	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.8	6.9	DB	-8.5	39.1	2.4	1.5	-10.2	40.2	-11.6	41.1	-12.9	41.9	-14.7	43.0	(4)
(5)			WB	-9.2	26.5	2.1	0.7	-10.7	27.0	-11.9	27.5	-13.1	27.9	-14.6	28.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	7.6	9.6	14.1	17.7	22.2	26.7	27.8	28.6	25.0	18.9	13.0	8.8
	DBStd	8.52	5.49	5.69	5.14	4.12	3.54	2.16	2.07	2.42	3.12	4.63	5.03	5.23
	HDD10.0	323	112	72	22	3	0	0	0	0	0	1	27	88
	HDD18.3	1322	334	249	148	59	11	0	0	0	1	51	171	298
	CDD10.0	3379	38	59	148	232	379	502	552	576	451	276	116	51
	CDD18.3	1337	2	3	16	39	131	252	293	318	202	68	11	2
	CDH23.3	14286	7	19	108	326	1165	2700	3336	3863	2058	627	66	12
CDH26.7	6823	0	1	12	53	397	1302	1717	2144	988	201	8	0	
Wind	WSAvg	2.6	3.1	3.3	3.4	3.3	2.7	2.3	1.9	1.8	1.9	2.3	2.7	2.9
Precipitation	PrecAvg	1175	101	95	121	105	128	105	99	67	95	115	103	104
	PrecMax	1837	235	240	254	245	252	265	260	193	213	436	308	181
	PrecMin	633	7	9	36	39	25	3	0	8	15	6	27	14
	PrecStd	321	54	59	57	53	71	73	80	47	54	94	64	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.5	25.7	28.0	30.9	33.6	37.3	37.8	40.2	37.3	32.7	27.8	25.1
		MCWB	15.4	17.1	17.8	20.7	22.6	23.0	24.2	22.2	22.4	21.9	20.1	18.7
	2%	DB	22.3	23.3	26.2	27.9	32.0	35.8	36.6	38.0	35.2	31.0	25.1	22.5
		MCWB	16.0	16.1	17.7	19.4	22.3	23.2	24.1	23.2	22.4	21.9	18.4	17.1
	5%	DB	20.0	21.4	24.2	26.9	30.5	34.1	35.2	37.1	33.6	29.0	22.9	20.5
		MCWB	15.2	16.1	16.8	18.9	22.0	23.6	24.3	23.6	22.4	20.5	17.6	16.1
	10%	DB	17.4	19.4	22.5	25.2	29.0	32.7	33.9	35.4	32.2	27.2	21.3	18.0
		MCWB	12.6	14.9	16.2	18.2	21.4	23.6	24.0	23.6	22.2	19.7	17.1	14.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.2	19.7	20.2	22.6	24.8	26.2	26.2	26.3	25.4	24.2	22.0	20.4
		MCDB	22.0	23.2	24.8	26.7	30.0	31.9	33.1	32.9	31.2	29.2	25.5	22.8
	2%	WB	17.8	18.6	19.2	21.4	23.9	25.5	25.7	25.7	24.8	23.4	20.5	19.0
		MCDB	20.3	21.3	23.7	25.6	29.2	31.2	32.5	32.6	30.4	28.0	23.1	21.5
	5%	WB	16.2	17.3	18.4	20.5	23.2	25.1	25.3	25.3	24.2	22.6	19.1	17.2
		MCDB	19.1	20.0	22.5	24.7	28.3	30.7	32.0	32.3	29.6	26.9	22.0	19.4
	10%	WB	13.4	15.6	17.4	19.7	22.4	24.6	24.9	25.0	23.6	21.6	17.8	15.2
		MCDB	16.5	19.1	21.1	23.9	27.4	30.0	31.4	31.6	28.9	25.2	20.4	17.7
Mean Daily Temperature Range	5% DB	MDBR	11.2	10.9	11.7	12.2	11.2	11.1	11.3	12.5	12.3	12.9	12.2	11.1
		MCDBR	14.5	13.4	13.1	13.4	12.4	13.0	13.3	14.6	14.1	14.0	13.5	14.0
		MCWBR	8.9	8.2	6.6	6.3	4.7	3.5	3.3	3.1	4.0	5.8	7.7	9.4
	5% WB	MCDBR	11.3	11.2	10.7	10.5	10.8	10.9	11.4	12.0	11.4	11.0	10.5	11.9
		MCWBR	8.6	8.2	6.6	6.2	4.8	3.8	3.6	3.5	3.9	5.4	7.7	9.3
Clear-Sky Solar Irradiance	taub	0.321	0.335	0.359	0.396	0.428	0.446	0.461	0.458	0.407	0.360	0.342	0.325	
	taud	2.488	2.464	2.416	2.313	2.283	2.272	2.266	2.264	2.367	2.472	2.472	2.489	
	Ebn at Noon	896	919	919	893	863	843	828	827	858	878	862	870	
	Edh at Noon	87	98	111	129	134	135	136	134	116	97	88	83	
All-Sky Solar Radiation	RadAvg	2.70	3.06	4.26	5.28	5.76	6.34	6.39	5.97	5.03	3.99	2.90	2.36	
	RadStd	0.25	0.48	0.37	0.35	0.49	0.59	0.44	0.46	0.46	0.55	0.36	0.30	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page