

CLEBURNE, TX, USA

WMO: 720320

Lat: 32.354N

Lon: 97.434W

Elev: 260

StdP: 98.24

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53981

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.9	-2.4	-12.5	1.3	-0.2	-10.1	1.6	2.7	12.4	7.3	11.0	8.2	3.4	340	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	38.0	23.1	37.4	23.3	36.2	23.3	26.1	31.1	25.7	30.9	25.3	30.7	4.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.8	27.7	24.1	19.6	27.0	23.9	19.4	26.9	82.5	30.8	80.1	31.3	78.4	30.7	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.1	8.2	DB	-8.8	40.4	2.2	1.7	-10.4	41.6	-11.7	42.6	-13.0	43.5	-14.6	44.7	(4)
(5)			WB	-9.2	27.0	2.1	0.8	-10.7	27.5	-11.9	28.0	-13.1	28.4	-14.6	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	8.3	10.5	14.9	18.6	23.0	27.9	29.4	29.6	26.4	20.1	13.9	9.0	(6)	
	DBStd	8.80	5.52	6.04	5.18	4.25	3.57	2.24	2.14	2.50	2.90	4.78	5.23	5.28	(7)	
	HDD10.0	289	98	63	18	2	0	0	0	0	0	2	22	83	(8)	
	HDD18.3	1201	313	225	129	47	8	0	0	0	0	38	148	291	(9)	
	CDD10.0	3698	44	77	169	260	402	538	602	608	492	314	139	53	(10)	
	CDD18.3	1568	2	6	22	55	151	288	344	350	242	92	15	2	(11)	
	CDH23.3	18026	21	44	147	414	1333	3429	4428	4642	2626	817	104	19	(12)	
(13)	CDH26.7	9081	2	7	23	103	487	1762	2477	2651	1266	280	21	2	(13)	
(14)	Wind	WSAvg	4.1	4.1	4.4	4.8	4.9	4.4	3.6	3.5	3.4	3.8	4.0	3.9	(14)	
(15) Precipitation	PrecAvg	959	63	68	93	81	104	93	53	67	85	98	80	70	(15)	
	PrecMax	1398	120	186	194	178	241	329	121	165	289	261	220	256	(16)	
	PrecMin	494	10	0	29	13	35	22	0	0	7	6	11	8	(17)	
	PrecStd	225	31	48	43	47	55	79	34	42	73	69	57	56	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	27.5	28.9	32.3	34.1	37.9	40.1	40.9	37.5	33.8	29.0	26.0	(19)	
		MCWB	14.5	16.2	17.3	20.1	23.3	23.1	22.8	23.0	22.1	21.2	19.7	17.0	(20)	
	2%	DB	22.6	24.1	27.2	29.0	32.7	37.0	38.0	38.7	36.0	32.0	26.3	22.6	(21)	
		MCWB	14.4	16.4	18.1	19.9	23.2	23.1	23.1	22.9	22.4	22.0	18.4	16.0	(22)	
	5%	DB	20.0	22.3	24.9	27.5	31.3	35.2	37.3	37.5	34.0	29.8	23.8	20.1	(23)	
		MCWB	14.5	15.8	17.5	20.1	22.8	23.6	23.3	23.6	22.6	21.4	17.4	15.7	(24)	
	10%	DB	17.5	20.0	22.7	26.0	29.1	33.8	36.0	36.3	32.7	27.7	22.2	17.7	(25)	
		MCWB	12.4	15.5	16.9	19.4	22.2	23.5	23.5	23.5	22.6	19.7	17.4	13.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.7	21.9	23.9	26.2	26.9	26.8	26.4	26.1	24.7	22.6	20.5	(27)	
		MCDB	21.0	23.4	25.4	27.5	29.9	31.9	31.9	31.5	30.4	28.8	25.3	22.5	(28)	
	2%	WB	17.8	19.3	20.6	22.8	25.2	25.9	25.9	25.7	25.4	23.9	21.0	18.8	(29)	
		MCDB	19.8	21.8	23.5	26.5	29.4	31.0	31.3	31.4	30.1	27.9	22.8	20.9	(30)	
	5%	WB	15.8	17.9	19.7	22.0	24.4	25.4	25.5	25.3	24.8	23.2	19.7	17.1	(31)	
		MCDB	18.4	19.7	22.9	25.2	28.5	30.6	31.0	31.3	29.5	26.8	22.4	18.2	(32)	
	10%	WB	12.9	16.2	18.7	21.1	23.6	24.9	25.1	25.0	24.3	22.3	18.4	14.8	(33)	
		MCDB	16.7	19.0	21.3	24.1	27.5	30.2	30.7	31.1	28.8	25.8	20.8	17.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	11.2	11.5	11.5	10.5	11.0	11.5	11.6	11.5	12.1	11.4	11.2	(35)	
		MCDBR	15.3	14.2	13.0	12.6	12.1	12.8	13.2	13.0	12.8	12.7	13.3	14.4	(36)	
		MCWBR	9.0	8.4	6.8	6.7	4.6	3.2	3.0	3.0	3.9	5.2	7.1	9.0	(37)	
	5% WB	MCDBR	12.4	12.0	10.3	9.9	9.7	10.0	10.8	11.0	10.2	10.2	10.4	11.3	(38)	
		MCWBR	9.5	8.8	6.7	6.6	5.1	3.5	3.4	3.1	3.6	5.0	7.7	9.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.310	0.324	0.351	0.390	0.419	0.428	0.433	0.430	0.397	0.358	0.335	0.316	(40)	
	taud		2.509	2.477	2.419	2.334	2.313	2.324	2.347	2.337	2.377	2.471	2.474	2.495	(41)	
	Ebn at Noon		915	934	928	900	872	860	853	853	869	883	875	886	(42)	
	Edh at Noon		86	98	111	127	131	129	125	125	115	97	88	83	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.96	3.48	4.55	5.49	5.89	6.64	6.77	6.20	5.21	4.11	3.12	2.61	(44)	
	RadStd		0.30	0.56	0.36	0.46	0.57	0.60	0.47	0.40	0.42	0.61	0.39	0.34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page