

SANDPOINT, ID, USA

WMO: 720322

Lat: 48.299N

Lon: 116.560W

Elev: 2127

StdP: 13.60

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 04129

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.8	11.7	-4.5	4.7	8.9	1.3	6.4	14.4	25.9	15.5	22.1	17.7	6.1	30	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.1	89.8	62.5	86.1	62.0	82.0	60.5	65.3	82.5	63.6	80.2	62.1	78.8	5.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.6	85.4	69.3	57.1	75.3	67.8	54.9	69.4	66.6	31.2	82.7	29.9	80.1	28.8	79.8	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.7	16.4	13.0	DB	-2.8	94.2	5.4	3.3	-6.7	96.5	-9.8	98.4	-12.9	100.2	-16.8	102.6	(4)
(5)			WB	-3.4	70.3	5.2	4.0	-7.1	73.2	-10.2	75.5	-13.1	77.7	-16.9	80.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.9	29.2	30.9	37.5	44.2	53.6	58.5	66.0	65.1	56.2	44.8	35.9	28.4		
	DBStd	14.64	7.60	7.11	5.76	5.81	6.36	6.22	5.22	4.89	5.86	6.00	7.19	7.55		
	HDD50	3096	645	536	389	194	38	5	0	0	11	183	426	669		
	HDD65	7122	1110	956	853	625	355	210	50	59	269	627	874	1134		
	CDD50	1611	0	0	0	20	149	261	495	467	197	20	2	0		
	CDD65	166	0	0	0	0	1	16	81	62	6	0	0	0		
	CDH74	3843	0	0	0	6	122	367	1673	1411	261	1	2	0		
	CDH80	1263	0	0	0	0	11	97	606	489	60	0	0	0		
	WSAvg	4.4	4.6	5.0	4.3	5.0	5.2	4.4	4.0	3.7	3.8	3.9	4.5	4.7		
	PrecAvg	33.6	4.3	3.3	2.9	2.2	2.6	2.4	1.3	1.3	1.7	2.6	4.8	4.8		
(15) Precipitation	PrecMax	44.3	10.2	7.8	6.7	4.9	6.8	6.2	6.6	4.4	3.7	5.5	10.8	9.1		
	PrecMin	22.9	0.3	0.2	0.1	0.3	0.7	0.4	0.0	0.0	0.0	0.0	1.1	0.7		
	PrecStd	4.8	2.1	1.9	1.4	1.0	1.2	1.2	1.3	1.2	1.1	1.6	2.2	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.2	49.6	60.7	73.1	81.4	88.4	92.9	92.7	86.4	70.4	60.6	47.5		
		MCWB	41.3	42.5	46.8	53.1	57.3	63.5	64.2	62.6	61.3	56.3	56.3	43.9		
	2%	DB	41.5	45.2	54.4	67.8	77.5	81.9	90.1	89.5	81.1	63.9	52.4	42.6		
		MCWB	38.3	39.6	44.5	51.3	57.0	61.0	63.0	61.9	59.3	51.9	48.1	39.7		
	5%	DB	39.0	43.0	50.4	62.7	72.8	78.8	86.5	85.9	76.7	59.4	49.5	38.9		
		MCWB	36.4	38.5	42.8	48.3	55.3	58.9	62.0	61.8	57.7	49.7	45.7	36.6		
	10%	DB	36.7	40.5	46.3	56.7	69.7	73.3	82.3	81.7	72.1	55.1	45.7	36.7		
		MCWB	34.7	36.9	40.4	45.2	53.7	56.9	60.8	60.3	56.0	47.7	42.9	35.1		
	0.4%	WB	42.4	44.2	49.2	55.2	60.3	66.1	69.0	66.4	64.1	58.0	56.9	44.8		
		MCDB	43.9	46.1	55.5	69.8	75.0	84.5	86.1	83.2	76.9	67.1	61.5	46.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.1	41.4	46.0	51.9	58.1	63.1	66.0	64.5	61.2	54.3	49.2	39.6		
		MCDB	41.9	43.8	51.5	65.3	73.9	79.3	82.7	81.7	75.9	60.3	51.7	42.2		
	5%	WB	37.0	39.1	43.8	49.3	56.1	60.7	64.0	63.1	59.1	51.9	45.9	37.2		
		MCDB	38.8	42.3	48.8	60.2	70.9	74.7	81.1	80.0	73.6	56.8	47.5	38.5		
	10%	WB	35.6	37.0	41.5	46.5	54.3	58.8	62.3	61.7	57.1	49.6	43.8	35.7		
		MCDB	36.8	39.5	46.2	55.3	66.5	71.2	79.4	79.3	70.3	55.6	46.0	36.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	12.7	15.6	19.5	24.0	23.3	31.1	31.1	27.5	19.4	11.9	8.8		
		MCDBR	9.9	15.8	23.3	30.3	32.9	32.9	36.7	37.9	36.6	26.2	18.4	10.3		
		MCWBR	7.7	10.6	14.0	15.4	14.9	14.7	15.2	15.9	17.1	15.8	14.2	8.6		
		MCDBR	9.5	13.2	19.9	28.0	30.4	28.7	32.7	33.7	33.0	22.3	17.0	9.3		
	5% WB	MCWBR	7.6	9.4	13.0	14.9	14.0	13.6	14.4	14.9	16.2	14.6	13.8	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.269	0.273	0.293	0.347	0.361	0.356	0.355	0.367	0.340	0.305	0.286	0.266		
	taud		2.399	2.401	2.441	2.364	2.392	2.440	2.450	2.421	2.478	2.574	2.539	2.447		
	Ebn at Noon		259	285	296	286	285	287	286	277	275	271	253	246		
	Edh at Noon		21	26	30	36	36	35	34	33	29	22	18	18		
(44) All-Sky Solar Radiation	RadAvg		303	600	915	1387	1789	1890	2278	1894	1341	778	358	242		
	RadStd		45	82	117	134	142	179	152	134	135	96	45	34		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+148	N/A

Nomenclature: See separate page