

GILLESPIE COUNTY AP, TX, USA

WMO: 720323

Lat: 30.243N

Lon: 98.910W

Elev: 517

StdP: 95.27

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 93947

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-2.6	-13.5	1.2	4.3	-10.9	1.6	5.4	10.9	9.9	9.4	11.4	2.1	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	36.3	20.8	35.2	21.0	34.1	21.2	24.3	28.7	23.8	28.4	23.4	28.2	3.7	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	18.9	26.3	22.6	18.4	25.9	22.2	18.0	25.6	76.7	29.9	74.0	27.7	72.1	28.2	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	8.0	7.3	DB	-7.9	38.5	2.1	1.3	-9.5	39.4	-10.7	40.2	-11.9	41.0	-13.4	41.9	(4)
(5)			WB	-8.9	24.7	1.9	1.0	-10.3	25.4	-11.4	26.1	-12.4	26.6	-13.8	27.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	8.8	11.3	15.2	18.8	22.5	26.2	27.6	27.9	24.8	19.6	14.0	9.7
	DBStd	7.83	4.97	5.61	4.79	4.01	3.45	2.02	1.69	1.87	2.77	4.50	5.11	4.90
	HDD10.0	231	81	48	12	1	0	0	0	0	0	2	21	66
	HDD18.3	1122	297	203	117	42	8	0	0	0	1	40	146	269
	CDD10.0	3487	44	83	174	266	389	486	545	556	444	299	141	58
	CDD18.3	1335	2	4	21	57	139	236	287	298	194	79	16	2
	CDH23.3	13456	18	55	159	482	1154	2378	3149	3427	1839	669	102	24
	CDH26.7	5953	1	7	23	122	393	1066	1579	1788	786	177	11	1
Wind	WSAvg	2.9	2.8	3.1	3.6	3.6	3.3	3.1	2.7	2.4	2.1	2.6	2.8	2.7
Precipitation	PrecAvg	853	48	53	75	65	94	92	80	63	85	86	63	50
	PrecMax	1394	113	173	241	198	230	305	553	226	184	200	192	342
	PrecMin	351	4	1	21	5	19	5	5	3	7	2	0	0
	PrecStd	256	36	45	47	47	54	74	119	56	48	56	56	71
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	27.4	29.1	32.6	34.1	36.9	37.4	37.5	36.1	32.3	28.3	26.2
		MCWB	12.8	14.3	15.6	17.3	20.9	21.1	20.5	20.9	19.9	19.4	18.1	14.8
	2%	DB	22.7	25.1	26.9	29.8	32.3	34.9	36.1	36.6	33.9	30.2	26.2	23.0
		MCWB	14.0	14.3	16.4	17.9	20.8	21.1	20.6	21.1	20.9	19.8	17.5	15.6
	5%	DB	20.4	22.5	25.1	27.7	30.6	33.2	34.9	35.4	32.6	28.8	24.1	21.3
		MCWB	13.2	14.6	16.0	18.2	20.6	21.2	20.9	21.2	20.6	19.8	17.1	14.3
	10%	DB	17.9	20.5	23.0	26.2	28.8	32.1	33.7	34.2	31.1	27.2	22.4	18.8
		MCWB	12.3	14.7	16.1	17.6	20.2	21.2	21.2	21.4	20.5	18.8	16.7	14.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	19.1	21.1	22.2	24.2	25.0	24.7	24.9	24.6	23.6	21.2	20.0
		MCDB	21.1	22.1	23.0	25.7	28.3	29.5	28.6	30.6	28.7	26.9	23.8	23.3
	2%	WB	17.1	18.1	19.6	21.4	23.3	24.1	24.0	24.1	23.8	22.7	20.3	18.0
		MCDB	19.8	20.9	23.4	25.1	28.1	28.7	28.2	28.8	27.9	26.1	23.4	20.4
	5%	WB	15.4	17.1	18.6	20.6	22.5	23.4	23.4	23.6	23.0	21.9	19.2	16.7
		MCDB	18.1	19.7	22.3	24.6	27.0	28.5	28.1	28.7	27.6	25.6	22.8	19.0
	10%	WB	13.4	15.8	17.8	19.9	21.8	22.8	22.9	23.0	22.4	21.1	17.9	14.8
		MCDB	16.8	18.9	21.0	24.0	26.0	28.1	28.0	28.6	26.9	24.8	21.1	17.5
Mean Daily Temperature Range	5% DB	MDBR	13.3	13.0	12.8	12.7	11.0	11.1	11.6	12.1	11.7	12.7	12.5	13.2
		MCDBR	17.1	15.6	14.4	14.3	13.0	13.2	13.7	13.9	13.5	12.8	13.7	16.7
		MCWBR	9.7	8.6	7.1	6.5	4.8	3.5	3.2	3.1	3.9	5.3	7.4	9.6
	5% WB	MCDBR	12.3	11.3	10.8	10.7	9.7	10.0	10.1	11.0	9.8	9.5	10.9	11.7
		MCWBR	9.2	8.1	6.7	5.9	4.6	3.6	3.1	3.3	3.5	5.1	7.2	8.8
Clear-Sky Solar Irradiance	taub		0.308	0.315	0.337	0.379	0.409	0.409	0.418	0.408	0.389	0.357	0.334	0.308
	taud		2.534	2.518	2.467	2.368	2.333	2.385	2.399	2.409	2.408	2.486	2.486	2.537
	Ebn at Noon		931	954	949	914	883	878	868	876	883	894	891	912
	Edh at Noon		86	96	108	123	128	121	119	117	113	98	90	82
All-Sky Solar Radiation	RadAvg		3.14	3.75	4.70	5.60	5.89	6.76	6.73	6.37	5.22	4.30	3.29	2.80
	RadStd		0.34	0.58	0.44	0.52	0.63	0.50	0.57	0.36	0.50	0.61	0.41	0.37

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+78

Nomenclature: See separate page