

ALLEN PARISH, LA, USA

WMO: 720346

Lat: 30.750N

Lon: 92.688W

Elev: 33

StdP: 100.93

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 53991

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.0	-1.4	-8.2	1.9	2.9	-5.3	2.4	4.0	7.5	11.7	6.9	11.3	0.8	0	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	35.9	25.2	34.7	25.3	33.6	25.3	27.7	30.8	27.2	30.7	26.8	30.7	1.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.3	23.2	28.6	26.3	21.8	28.4	25.9	21.3	28.4	88.1	31.2	85.6	29.9	83.6	31.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.8	5.6	4.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	-6.7	28.3	2.8	0.7	-8.7	28.8	-10.3	29.2	-11.8	29.6	-13.8	30.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	9.5	12.3	15.7	19.2	22.8	26.5	27.3	27.7	25.2	19.7	14.1	11.7
	DBStd	7.50	5.48	5.53	4.98	3.91	3.24	1.66	1.50	1.73	2.42	4.39	5.12	5.44
	HDD10.0	183	76	34	11	1	0	0	0	0	0	1	18	43
	HDD18.3	1013	278	181	110	36	6	0	0	0	0	38	146	218
	CDD10.0	3594	61	99	188	277	397	495	537	548	455	301	140	96
	CDD18.3	1384	4	13	29	62	145	245	278	289	205	79	19	13
	CDH23.3	13443	11	46	198	564	1428	2513	2812	2951	1899	843	123	54
	CDH26.7	5917	0	1	21	113	529	1221	1357	1498	868	294	12	2
Wind	WSAvg	1.4	1.8	2.0	2.0	1.9	1.4	1.0	0.8	0.9	1.0	1.2	1.4	1.6
Precipitation	PrecAvg	1600	163	123	116	124	125	128	125	99	120	129	142	151
	PrecMax	2078	345	297	231	358	371	314	258	159	312	392	294	241
	PrecMin	1154	30	10	37	31	1	25	44	16	48	0	22	90
	PrecStd	258	86	67	57	75	88	78	52	38	66	110	76	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.7	26.5	28.6	31.1	33.7	37.1	36.3	37.7	35.2	32.7	28.0	27.0
		MCWB	19.2	20.8	20.0	22.7	23.2	23.0	25.1	25.5	24.0	22.6	22.3	22.1
	2%	DB	22.8	24.8	27.2	29.0	32.4	35.0	35.0	36.2	33.9	31.3	26.4	24.9
		MCWB	19.2	19.4	20.3	22.1	23.4	25.0	25.6	25.9	24.4	23.3	21.2	21.3
	5%	DB	21.4	23.0	25.9	27.8	31.1	33.6	33.9	34.8	32.6	30.0	24.9	23.1
		MCWB	18.6	19.4	19.8	21.2	23.3	25.4	25.7	25.7	24.6	22.6	20.3	20.7
	10%	DB	19.9	22.0	24.0	27.0	29.9	32.5	32.8	33.1	31.6	28.0	22.9	21.7
		MCWB	17.3	19.5	19.0	20.6	23.2	25.2	25.8	25.8	24.4	21.5	20.1	19.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	22.3	23.1	24.8	26.3	28.4	28.7	28.4	27.8	26.0	24.0	23.7
		MCDB	22.8	24.2	25.1	27.6	28.9	30.8	30.4	31.4	30.0	28.9	26.0	24.8
	2%	WB	20.9	21.4	22.2	23.8	25.3	27.2	27.6	27.6	26.8	25.2	22.9	22.2
		MCDB	21.9	23.4	24.7	26.7	29.0	30.6	30.4	31.3	29.7	28.8	24.5	24.4
	5%	WB	19.6	20.7	21.3	23.0	24.6	26.6	27.1	27.2	26.0	24.4	22.0	21.2
		MCDB	21.0	22.6	23.9	25.9	28.5	30.6	30.5	31.2	29.6	28.3	24.2	23.1
	10%	WB	17.5	19.5	20.5	22.4	24.0	26.0	26.6	26.7	25.4	23.1	20.5	20.0
		MCDB	19.0	21.3	23.0	25.3	28.0	30.3	30.6	31.1	29.3	26.2	22.7	21.5
Mean Daily Temperature Range	5% DB	MDBR	12.7	12.4	13.3	13.1	12.8	11.8	11.0	11.6	12.3	15.0	13.6	11.6
		MCDBR	13.4	12.5	12.7	13.2	13.5	13.8	12.4	13.7	13.4	14.8	13.9	12.1
		MCWBR	9.8	8.1	7.3	7.0	6.4	6.0	5.1	5.2	5.9	7.4	9.0	8.7
	5% WB	MCDBR	10.9	9.6	10.6	10.9	11.7	11.7	11.2	11.7	11.5	11.8	11.0	10.6
		MCWBR	9.4	7.6	7.0	6.7	6.0	5.8	5.4	5.3	5.8	6.8	8.1	8.3
Clear-Sky Solar Irradiance	taub	0.332	0.353	0.376	0.419	0.448	0.484	0.501	0.494	0.451	0.374	0.356	0.348	
	taud	2.520	2.463	2.394	2.278	2.233	2.171	2.160	2.178	2.268	2.458	2.458	2.471	
	Ebn at Noon	900	909	907	876	848	813	798	800	822	873	861	858	
	Edh at Noon	87	101	116	135	142	150	151	147	130	100	92	88	
All-Sky Solar Radiation	RadAvg	2.81	3.21	4.45	5.44	6.01	5.95	5.87	5.55	4.99	4.32	3.25	2.49	
	RadStd	0.27	0.53	0.38	0.41	0.40	0.51	0.46	0.53	0.46	0.56	0.32	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+121	+82

Nomenclature: See separate page