

GREENE COUNTY REGIONAL, GA, USA

WMO: 720347

Lat: 33.598N

Lon: 83.139W

Elev: 677

StdP: 14.34

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 63877

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	29.8	9.1	9.0	34.6	12.2	10.5	35.7	16.8	55.3	15.4	52.5	3.4	270	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	96.9	74.4	94.8	74.5	91.4	74.2	79.2	87.9	78.2	87.5	77.3	86.9	4.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	144.9	82.4	75.4	136.5	82.0	74.6	133.0	81.4	43.3	87.8	42.2	87.6	41.1	86.9	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	11.0	9.7	DB	19.7	99.4	3.9	3.5	16.9	101.9	14.7	104.0	12.5	105.9	9.7	108.5	(4)
(5)			WB	17.7	79.8	3.6	1.8	15.1	81.2	13.0	82.2	10.9	83.3	8.3	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	46.4	50.1	56.8	64.5	71.5	78.8	80.9	80.3	75.7	65.5	54.4	49.7		
	DBStd	14.22	9.61	9.16	8.66	7.20	5.89	4.31	4.10	4.42	5.84	7.77	7.49	8.57		
	HDD50	485	187	104	36	4	0	0	0	0	0	2	38	114		
	HDD65	2294	579	421	278	94	19	0	0	1	5	91	326	480		
	CDD50	5821	75	108	246	438	668	863	958	939	770	482	170	104		
	CDD65	2154	2	5	23	78	222	413	493	474	325	106	8	5		
	CDH74	20567	4	21	196	747	1970	4152	5075	4630	2885	829	49	9		
	CDH80	8932	0	1	28	170	680	1974	2426	2162	1257	232	2	0		
(14) Wind	WSAvg	2.9	4.1	4.2	4.2	3.9	3.0	2.4	2.3	1.8	1.5	2.1	2.5	3.3		
(15) Precipitation	PrecAvg	46.7	4.2	4.6	5.2	3.1	3.1	4.1	4.1	4.4	3.8	2.9	3.2	3.5		
	PrecMax	59.1	7.1	7.4	9.4	8.3	8.4	7.6	9.1	8.9	13.9	6.8	9.2	6.5		
	PrecMin	31.6	2.0	1.6	1.1	1.3	0.6	1.0	1.0	0.9	0.1	0.2	0.5	1.5		
	PrecStd	7.1	1.5	1.8	2.1	1.8	1.7	2.1	2.1	2.4	3.1	2.0	1.9	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.9	77.3	82.5	88.2	92.9	99.1	99.1	99.6	96.9	90.4	79.2	74.7		
		MCWB	61.5	64.4	64.3	66.8	70.3	72.2	76.3	73.8	72.4	72.1	64.2	65.5		
	2%	DB	69.7	72.4	79.4	84.2	89.8	95.2	96.7	96.6	93.2	85.8	74.5	71.7		
		MCWB	60.9	61.0	63.8	66.7	70.0	73.6	75.9	75.0	72.2	69.0	61.3	64.5		
	5%	DB	64.4	69.6	75.1	81.5	86.5	92.5	93.4	92.8	90.5	81.8	71.7	68.1		
		MCWB	58.9	59.4	60.6	64.8	69.3	73.3	75.6	75.7	72.4	67.6	61.0	63.2		
	10%	DB	62.6	64.3	72.0	79.0	83.8	90.2	90.9	90.4	88.0	78.9	68.0	63.8		
		MCWB	57.1	56.3	59.3	63.1	68.9	73.1	75.4	75.3	72.4	66.4	59.5	59.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.3	67.1	68.1	72.1	75.1	78.5	80.6	80.8	77.6	75.5	70.1	70.4		
		MCDB	69.0	72.3	75.9	81.3	83.3	88.6	87.0	89.0	86.0	82.2	72.2	71.3		
	2%	WB	63.1	64.7	65.9	69.4	73.4	77.5	79.3	79.3	76.2	73.5	66.9	66.4		
		MCDB	66.3	69.9	75.6	77.5	82.8	87.9	88.2	87.7	85.9	80.5	71.4	69.1		
	5%	WB	60.9	62.2	64.1	67.8	72.2	76.6	78.2	78.2	75.1	71.9	64.1	63.6		
		MCDB	64.5	65.9	71.8	77.3	81.3	86.8	88.0	86.9	85.1	78.6	67.9	66.0		
	10%	WB	57.9	59.4	62.4	66.1	70.9	75.5	77.4	77.3	74.0	69.8	61.1	60.4		
		MCDB	61.9	64.2	69.1	75.4	79.6	85.2	87.6	86.0	83.5	75.2	66.0	64.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.6	19.7	21.5	22.4	21.5	20.9	19.8	19.3	20.4	21.3	21.2	17.8		
		MCDBR	20.5	22.0	24.3	24.7	24.6	24.2	22.4	22.6	24.0	23.7	24.1	19.8		
	5% WB	MCWBR	13.6	12.6	11.2	9.9	8.9	7.1	6.4	6.6	7.0	9.6	13.0	13.5		
		MCWBR	16.9	17.3	19.8	20.6	19.5	20.0	19.4	18.6	19.9	17.4	18.4	16.9		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.321	0.356	0.387	0.449	0.480	0.521	0.518	0.424	0.385	0.344	0.312		
		taud	2.521	2.500	2.428	2.326	2.195	2.158	2.062	2.056	2.306	2.389	2.457	2.557		
	Ebn at Noon		286	296	292	285	268	259	247	246	266	268	272	281		
		Edh at Noon	26	30	35	40	47	48	53	52	39	33	28	24		
(44) All-Sky Solar Radiation	RadAvg		879	1067	1413	1761	1946	1997	1903	1739	1515	1281	971	751		
	RadStd		48	124	103	118	156	150	129	84	142	151	88	76		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+328	+232

Nomenclature: See separate page