

GREENE COUNTY REGIONAL, GA, USA

WMO: 720347

Lat: 33.598N

Lon: 83.139W

Elev: 206

StdP: 98.87

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 63877

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.9	-1.2	-12.7	1.3	1.4	-11.0	1.5	2.1	7.5	12.9	6.9	11.4	1.5	270	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	36.1	23.6	34.9	23.6	33.0	23.5	26.2	31.0	25.7	30.8	25.2	30.5	1.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.7	28.0	24.1	19.5	27.8	23.7	19.0	27.4	82.9	31.0	80.2	30.9	77.6	30.5	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.7	4.9	4.4	-6.8	37.4	2.2	1.9	-8.4	38.8	-9.6	40.0	-10.8	41.1	-12.4	42.5		
(5)			-8.0	26.6	2.0	1.0	-9.4	27.3	-10.6	27.9	-11.7	28.5	-13.2	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	8.0	10.1	13.8	18.0	22.0	26.0	27.2	26.8	24.3	18.6	12.4	9.8
	DBStd	7.90	5.34	5.09	4.81	4.00	3.27	2.40	2.28	2.45	3.24	4.32	4.16	4.76
	HDD10.0	269	104	58	20	2	0	0	0	0	0	1	21	63
	HDD18.3	1274	322	234	154	52	11	0	0	1	3	51	181	267
	CDD10.0	3234	42	60	137	243	371	479	532	522	428	268	94	58
	CDD18.3	1197	1	3	13	43	123	229	274	263	181	59	4	3
	CDH23.3	11426	2	12	109	415	1094	2307	2819	2572	1603	461	27	5
	CDH26.7	4962	0	1	16	94	378	1097	1348	1201	698	129	1	0
Wind	WSAvg	1.3	1.8	1.9	1.9	1.7	1.3	1.1	1.0	0.8	0.7	0.9	1.1	1.5
Precipitation	PrecAvg	1186	106	116	132	79	79	105	103	111	96	74	81	89
	PrecMax	1502	180	188	238	211	213	193	230	226	353	173	234	164
	PrecMin	802	50	40	28	33	16	25	26	24	2	4	12	39
	PrecStd	180	37	45	53	45	44	53	53	60	78	50	49	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	25.1	28.0	31.2	33.8	37.3	37.3	37.6	36.0	32.5	26.2	23.7
		MCWB	16.4	18.0	17.9	19.3	21.3	22.4	24.6	23.2	22.4	22.3	17.9	18.6
	2%	DB	21.0	22.4	26.3	29.0	32.1	35.1	35.9	35.9	34.0	29.9	23.6	22.0
		MCWB	16.0	16.1	17.7	19.3	21.1	23.1	24.4	23.9	22.3	20.6	16.3	18.0
	5%	DB	18.0	20.9	23.9	27.5	30.3	33.6	34.1	33.8	32.5	27.7	22.1	20.0
		MCWB	15.0	15.2	15.9	18.2	20.7	23.0	24.2	24.3	22.4	19.8	16.1	17.3
	10%	DB	17.0	17.9	22.2	26.1	28.8	32.4	32.7	32.5	31.1	26.1	20.0	17.7
		MCWB	13.9	13.5	15.2	17.3	20.5	22.8	24.1	24.1	22.4	19.1	15.3	15.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.5	19.5	20.0	22.3	24.0	25.8	27.0	27.1	25.3	24.2	21.2	21.3
		MCDB	20.6	22.4	24.4	27.4	28.5	31.5	30.5	31.6	30.0	27.9	22.3	21.9
	2%	WB	17.3	18.2	18.9	20.8	23.0	25.3	26.3	26.3	24.6	23.0	19.4	19.1
		MCDB	19.0	21.1	24.2	25.3	28.2	31.1	31.2	30.9	30.0	26.9	21.9	20.6
	5%	WB	16.0	16.8	17.8	19.9	22.3	24.8	25.7	25.7	23.9	22.2	17.8	17.5
		MCDB	18.0	18.8	22.1	25.2	27.4	30.4	31.1	30.5	29.5	25.9	19.9	18.9
	10%	WB	14.4	15.2	16.9	18.9	21.6	24.2	25.2	25.1	23.3	21.0	16.2	15.8
		MCDB	16.6	17.9	20.6	24.1	26.4	29.6	30.9	30.0	28.6	24.0	18.9	17.9
Mean Daily Temperature Range	5% DB	MDBR	10.4	10.9	11.9	12.4	11.9	11.6	11.0	10.7	11.3	11.8	11.8	9.9
		MCDBR	11.4	12.2	13.5	13.7	13.7	13.4	12.4	12.6	13.4	13.2	13.4	11.0
		MCWBR	7.6	7.0	6.2	5.5	5.0	3.9	3.6	3.7	3.9	5.3	7.2	7.5
	5% WB	MCDBR	9.4	9.6	11.0	11.5	10.8	11.1	10.8	10.3	11.1	9.6	10.2	9.4
MCWBR		7.5	6.9	6.1	5.6	4.8	4.1	3.9	3.7	3.9	4.8	7.1	7.7	
Clear-Sky Solar Irradiance	taub	0.315	0.321	0.356	0.387	0.449	0.480	0.521	0.518	0.424	0.385	0.344	0.312	
	taud	2.521	2.500	2.428	2.326	2.195	2.158	2.062	2.056	2.306	2.389	2.457	2.557	
	Ebn at Noon	902	933	920	900	844	815	779	774	839	846	857	886	
	Edh at Noon	83	94	110	127	147	152	166	165	123	105	88	77	
All-Sky Solar Radiation	RadAvg	2.77	3.36	4.45	5.55	6.13	6.30	6.00	5.48	4.78	4.04	3.06	2.37	
	RadStd	0.15	0.39	0.33	0.37	0.49	0.47	0.41	0.27	0.45	0.48	0.28	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	+182	+129

Nomenclature: See separate page