

BALDWIN COUNTY AP, GA, USAWMO: **720348**Lat: **33.154N**Lon: **83.241W**Elev: **384**StdP: **14.49**Time Zone: **-5.00 (NAE)**Period: **05-19**WBAN: **63886****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.2	29.8	5.3	7.3	41.3	11.6	10.1	36.7	18.0	43.8	16.0	45.8	2.9	300	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	97.0	75.2	95.0	75.4	92.6	75.1	81.0	87.0	79.6	86.0	78.6	85.6	3.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	154.3	82.6	78.6	150.8	82.2	77.1	142.9	81.3	44.7	86.7	43.3	86.4	42.3	85.7	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	10.6	8.8	DB	22.0	99.7	3.6	3.6	19.4	102.3	17.3	104.4	15.2	106.4	12.6	108.9	(4)
(5)			WB	20.5	82.2	2.7	1.8	18.5	83.5	17.0	84.6	15.5	85.6	13.5	86.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	46.9	50.8	57.3	65.7	73.2	80.2	81.8	80.7	77.5	66.5	55.1	50.7		
	DBStd	14.19	9.04	8.73	8.13	6.57	5.70	3.62	4.14	4.92	4.57	7.54	7.27	8.34		
	HDD50	413	170	88	26	1	0	0	0	0	0	1	31	96		
	HDD65	2137	562	402	262	71	10	0	1	3	0	75	305	446		
	CDD50	6110	75	111	252	472	718	906	984	951	824	513	185	119		
	CDD65	2361	3	6	23	92	263	456	520	489	374	122	9	4		
	CDH74	22859	9	43	242	962	2412	4591	5509	4800	3297	916	64	14		
	CDH80	10083	0	2	39	263	967	2234	2703	2159	1471	241	4	0		
(14) Wind	WSAvg	2.1	2.9	2.7	2.9	2.2	1.9	1.5	1.4	1.5	1.8	2.3	2.2	2.4		
(15) Precipitation	PrecAvg	48.0	4.8	4.7	5.2	3.5	3.5	3.9	4.3	4.5	3.7	2.7	3.2	3.7		
	PrecMax	67.7	9.3	12.2	12.8	9.7	9.8	11.7	11.0	12.8	12.2	9.1	10.4	8.1		
	PrecMin	33.9	1.0	0.3	0.4	0.5	0.3	0.3	0.7	0.5	0.0	0.0	0.6	0.6		
	PrecStd	8.7	2.0	2.3	2.8	2.5	2.4	2.2	2.6	2.6	2.4	2.2	2.0	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.5	79.2	84.1	89.9	96.7	99.5	98.9	99.0	96.9	90.2	80.7	76.7		
		MCWB	64.5	65.4	65.2	71.3	74.0	75.2	76.5	74.9	72.4	73.2	66.0	66.1		
	2%	DB	70.2	73.2	80.9	86.1	91.2	96.7	96.8	95.3	93.2	85.8	75.2	72.1		
		MCWB	62.1	62.0	64.6	68.6	71.3	74.7	76.4	76.3	73.0	70.4	63.0	64.7		
	5%	DB	65.7	70.3	76.8	82.3	88.4	93.3	94.8	92.5	90.8	82.0	72.2	68.3		
		MCWB	59.9	60.4	61.8	66.4	70.5	74.8	76.4	76.5	73.0	68.5	62.0	64.0		
	10%	DB	62.8	66.0	72.3	80.7	85.9	90.7	91.2	90.3	88.4	79.4	69.5	64.0		
		MCWB	57.8	57.8	59.9	65.3	70.1	74.7	75.9	75.9	72.8	67.7	61.2	60.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.3	68.5	69.8	75.2	78.1	80.6	82.1	82.4	79.1	77.3	70.5	69.7		
		MCDB	71.5	73.4	75.9	83.3	89.9	86.4	89.7	88.1	83.0	81.6	73.5	71.1		
	2%	WB	64.6	66.1	67.6	72.4	75.7	78.9	80.9	81.1	77.5	74.7	68.3	66.9		
		MCDB	68.2	72.7	75.2	80.5	84.4	86.3	88.2	86.2	84.4	80.0	72.3	69.5		
	5%	WB	62.8	63.3	65.8	70.3	74.1	77.9	79.5	80.0	76.4	72.9	65.6	64.3		
		MCDB	64.4	65.9	73.9	77.4	81.9	86.6	86.9	85.4	84.1	78.6	70.2	66.8		
	10%	WB	59.0	60.6	63.3	68.4	72.8	77.0	78.4	78.8	75.1	71.3	62.9	62.4		
		MCDB	61.3	64.8	68.1	75.3	80.3	86.0	86.4	84.6	83.3	76.7	65.6	64.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.4	21.8	23.3	23.9	21.7	20.4	19.8	18.1	20.2	21.3	21.9	19.3		
		MCDBR	24.8	26.5	27.6	27.4	25.6	24.0	22.6	21.2	23.7	23.4	25.7	22.2		
		MCWBR	16.5	15.4	12.5	11.0	8.4	7.0	6.2	6.8	7.1	9.8	14.5	15.3		
	5% WB	MCDBR	18.8	20.7	22.5	21.8	20.1	19.9	19.1	17.0	18.9	18.1	19.9	19.1		
		MCWBR	15.5	14.5	12.2	11.0	8.2	7.6	7.1	7.0	7.1	9.2	14.4	15.1		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.326	0.360	0.389	0.447	0.483	0.525	0.523	0.427	0.387	0.350	0.319		
	taud		2.517	2.498	2.431	2.334	2.211	2.165	2.062	2.054	2.312	2.399	2.453	2.547		
	Ebn at Noon		285	295	291	285	268	258	246	244	266	269	270	279		
	Edh at Noon		27	30	35	40	46	48	53	52	39	33	29	25		
(44) All-Sky Solar Radiation	RadAvg		894	1082	1427	1780	1964	1987	1912	1740	1521	1295	988	766		
	RadStd		47	121	108	120	153	148	120	85	142	149	85	77		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (39 neighbors)	+0.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+311	+212

Nomenclature: See separate page