

BALDWIN COUNTY AP, GA, USAWMO: **720348**Lat: **33.154N**Lon: **83.241W**Elev: **117**StdP: **99.93**Time Zone: **-5.00 (NAE)**Period: **05-19**WBAN: **63886****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.7	-1.2	-14.8	1.0	5.2	-11.4	1.4	2.6	8.1	6.6	7.2	7.7	1.3	300	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	36.1	24.0	35.0	24.1	33.7	24.0	27.2	30.6	26.5	30.0	25.9	29.8	1.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	22.0	28.1	25.9	21.5	27.9	25.0	20.4	27.4	86.1	30.4	82.9	30.2	80.6	29.8	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.7	4.8	4.0	DB	-5.5	37.6	2.0	2.0	-7.0	39.0	-8.2	40.2	-9.3	41.3	-10.8	42.7	(4)
(5)			WB	-6.4	27.9	1.5	1.0	-7.5	28.6	-8.4	29.2	-9.2	29.8	-10.3	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	8.3	10.5	14.0	18.7	22.9	26.8	27.6	27.0	25.3	19.2	12.9	10.4	(6)
(7)		DBStd	7.88	5.02	4.85	4.52	3.65	3.17	2.01	2.30	2.74	2.54	4.19	4.04	4.63	(7)
(8)		HDD10.0	229	94	49	14	1	0	0	0	0	0	1	17	53	(8)
(9)		HDD18.3	1187	312	223	146	39	6	0	1	2	0	42	169	248	(9)
(10)		CDD10.0	3394	42	62	140	262	399	503	547	528	458	285	103	66	(10)
(11)		CDD18.3	1312	2	3	13	51	146	253	289	272	208	68	5	2	(11)
(12)		CDH23.3	12699	5	24	134	534	1340	2551	3061	2667	1832	509	36	8	(12)
(13)	CDH26.7	5602	0	1	22	146	537	1241	1502	1199	817	134	2	0	(13)	
(14)	Wind	WSAvg	1.0	1.3	1.2	1.3	1.0	0.9	0.7	0.6	0.7	0.8	1.0	1.0	1.1	(14)
(15)	Precipitation	PrecAvg	1219	123	119	131	88	89	99	109	115	93	69	81	95	(15)
(16)		PrecMax	1720	236	311	324	247	250	297	280	326	311	230	264	205	(16)
(17)		PrecMin	861	25	7	10	12	7	8	19	12	1	0	15	14	(17)
(18)		PrecStd	221	52	58	70	64	61	57	66	67	60	56	52	51	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	26.2	29.0	32.2	35.9	37.5	37.2	37.2	36.0	32.3	27.1	24.8	(19)
(20)			MCWB	18.1	18.6	18.4	21.9	23.4	24.0	24.7	23.8	22.4	22.9	18.9	19.0	(20)
(21)		2%	DB	21.2	22.9	27.2	30.1	32.9	35.9	36.0	35.1	34.0	29.9	24.0	22.3	(21)
(22)			MCWB	16.7	16.7	18.1	20.4	21.8	23.7	24.7	24.6	22.8	21.4	17.2	18.1	(22)
(23)		5%	DB	18.7	21.3	24.9	27.9	31.4	34.0	34.9	33.6	32.7	27.8	22.3	20.2	(23)
(24)			MCWB	15.5	15.8	16.5	19.1	21.4	23.8	24.7	24.7	22.8	20.3	16.7	17.8	(24)
(25)		10%	DB	17.1	18.9	22.4	27.1	29.9	32.6	32.9	32.4	31.3	26.3	20.9	17.8	(25)
(26)			MCWB	14.3	14.3	15.5	18.5	21.1	23.7	24.4	24.4	22.7	19.8	16.2	15.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.3	21.0	24.0	25.6	27.0	27.9	28.0	26.1	25.2	21.4	20.9	(27)
(28)			MCD B	21.9	23.0	24.4	28.5	32.1	30.2	32.1	31.2	28.3	27.5	23.0	21.7	(28)
(29)		2%	WB	18.1	18.9	19.8	22.5	24.3	26.1	27.2	27.3	25.3	23.7	20.2	19.4	(29)
(30)			MCD B	20.1	22.6	24.0	26.9	29.1	30.2	31.2	30.1	29.1	26.7	22.4	20.8	(30)
(31)		5%	WB	17.1	17.4	18.8	21.3	23.4	25.5	26.4	26.6	24.7	22.7	18.6	17.9	(31)
(32)			MCD B	18.0	18.8	23.3	25.2	27.7	30.3	30.5	29.7	29.0	25.9	21.2	19.3	(32)
(33)		10%	WB	15.0	15.9	17.4	20.2	22.7	25.0	25.8	26.0	24.0	21.8	17.1	16.9	(33)
(34)			MCD B	16.3	18.2	20.0	24.1	26.8	30.0	30.2	29.2	28.5	24.9	18.7	18.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.3	12.1	13.0	13.3	12.0	11.3	11.0	10.0	11.2	11.9	12.2	10.7	(35)
(36)			MCDBR	13.8	14.7	15.3	15.2	14.2	13.3	12.6	11.8	13.2	13.0	14.3	12.3	(36)
(37)			MCWBR	9.1	8.5	7.0	6.1	4.6	3.9	3.5	3.8	3.9	5.4	8.1	8.5	(37)
(38)		5% WB	MCD BR	10.5	11.5	12.5	12.1	11.2	11.1	10.6	9.5	10.5	10.0	11.0	10.6	(38)
(39)			MCWBR	8.6	8.1	6.8	6.1	4.6	4.2	3.9	3.9	4.0	5.1	8.0	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.326	0.360	0.389	0.447	0.483	0.525	0.523	0.427	0.387	0.350	0.319	(40)	
(41)		taud	2.517	2.498	2.431	2.334	2.211	2.165	2.062	2.054	2.312	2.399	2.453	2.547	(41)	
(42)		Ebn at Noon	897	929	918	900	846	812	776	770	838	847	852	880	(42)	
(43)		Edh at Noon	85	95	110	126	144	151	166	165	122	104	90	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.82	3.41	4.50	5.61	6.19	6.26	6.03	5.49	4.80	4.08	3.11	2.41	(44)	
(45)		RadStd	0.15	0.38	0.34	0.38	0.48	0.47	0.38	0.27	0.45	0.47	0.27	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+173	+118

Nomenclature: See separate page