

CLINTON, OK, USA

WMO: 720356

Lat: 35.538N

Lon: 98.933W

Elev: 1616

StdP: 13.86

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 13999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.7	18.5	-0.4	5.7	27.1	2.9	6.8	30.4	30.3	47.8	27.8	45.9	9.2	0	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	101.6	66.4	99.1	68.2	96.6	69.1	77.4	89.2	75.6	87.5	74.0	84.4	12.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.7	137.9	82.0	72.5	127.7	79.8	71.6	123.8	79.0	42.3	88.0	40.3	88.4	38.7	83.1	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.5	24.8	22.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.0	38.3	40.4	51.6	59.1	67.9	78.0	81.8	81.6	73.1	60.5	48.0	38.8
	DBStd	18.00	9.36	10.94	10.40	9.21	8.49	5.88	5.24	5.83	7.03	9.75	9.15	8.94
	HDD50	1335	377	298	107	26	1	0	0	0	0	25	142	359
	HDD65	3770	828	688	425	218	67	0	0	0	15	203	514	812
	CDD50	4998	14	30	158	300	556	840	986	978	692	350	82	12
	CDD65	1959	0	0	11	41	157	391	521	513	258	63	4	0
	CDH74	22901	2	27	137	509	1715	4531	6507	6153	2618	636	65	1
	CDH80	11671	0	5	26	153	707	2326	3645	3442	1179	176	12	0
Wind	WSAvg	9.9	9.5	10.3	11.8	12.2	10.9	10.8	8.7	7.8	8.6	9.6	10.0	9.1
Precipitation	PrecAvg	31.0	1.1	1.2	2.4	3.0	4.1	4.1	2.4	3.8	2.7	3.0	1.7	1.5
	PrecMax	49.0	2.6	3.7	6.2	8.3	8.6	11.1	5.1	7.1	7.3	7.9	6.1	4.2
	PrecMin	19.5	0.0	0.0	0.0	0.2	0.9	0.3	0.2	0.0	0.0	0.2	0.0	0.2
	PrecStd	6.7	0.7	1.1	1.8	1.8	2.1	2.6	1.3	2.0	1.9	2.0	1.8	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.3	77.5	82.4	90.4	96.5	104.2	105.6	106.5	99.1	88.4	81.0	69.0
		MCWB	51.2	53.3	56.7	63.7	64.6	65.7	65.6	65.3	65.0	67.3	58.4	50.9
	2%	DB	64.2	70.1	77.4	84.0	91.1	99.1	100.2	102.1	93.5	85.6	73.2	63.1
		MCWB	46.5	51.6	56.8	62.2	65.4	66.6	67.6	66.9	67.6	66.2	56.2	50.1
	5%	DB	60.6	63.6	72.7	79.5	88.2	95.1	98.9	99.2	90.5	81.2	69.7	58.8
		MCWB	45.1	48.8	56.8	60.3	65.1	68.3	68.6	69.3	66.8	63.1	55.0	46.8
	10%	DB	54.6	59.0	68.4	75.1	82.4	90.9	95.5	95.4	87.9	77.2	63.5	53.9
		MCWB	43.0	47.0	54.9	59.3	64.2	68.2	69.7	70.5	66.8	62.0	51.8	44.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.1	58.5	66.5	68.7	74.3	76.7	77.7	81.6	75.3	73.7	63.8	59.5
		MCDB	63.9	64.0	72.9	78.5	84.5	86.0	90.8	91.6	84.6	83.8	74.6	63.0
	2%	WB	49.8	54.9	63.4	66.4	71.8	74.7	76.2	79.2	72.9	70.2	59.9	53.1
		MCDB	61.3	66.7	69.3	76.9	82.7	86.2	89.5	88.5	82.9	78.5	67.1	57.0
	5%	WB	46.0	51.5	60.8	64.3	69.6	72.9	74.6	77.0	71.4	67.9	57.0	48.5
		MCDB	57.7	62.6	67.1	74.4	79.2	84.4	86.9	88.2	81.3	76.7	65.9	56.8
	10%	WB	43.6	47.6	57.4	62.3	67.8	71.2	73.1	74.7	69.9	64.9	53.7	44.8
		MCDB	54.0	58.8	65.9	71.0	78.7	83.2	84.8	84.6	79.8	73.4	62.1	52.9
Mean Daily Temperature Range	5% DB	MDBR	23.6	23.2	24.2	23.9	23.4	23.0	23.2	23.1	22.7	24.6	24.8	20.9
		MCDBR	32.2	33.0	29.4	29.2	27.9	27.1	26.4	27.7	26.9	27.2	31.7	29.2
		MCWBR	17.6	18.1	15.0	13.5	9.9	7.0	5.9	6.3	7.8	12.0	16.8	17.0
	5% WB	MCDBR	29.1	30.3	21.8	24.5	21.9	22.0	22.2	22.1	20.6	20.3	26.5	25.1
		MCWBR	17.3	18.2	13.3	13.8	10.5	9.9	8.6	9.0	8.9	10.9	17.3	17.3
Clear-Sky Solar Irradiance	taub	0.281	0.291	0.332	0.366	0.389	0.414	0.413	0.411	0.375	0.348	0.307	0.284	
	taud	2.527	2.508	2.408	2.343	2.350	2.323	2.346	2.305	2.382	2.440	2.494	2.518	
	Ebn at Noon	296	304	298	291	284	276	275	274	279	279	282	287	
	Edh at Noon	25	29	35	39	40	41	40	40	36	31	26	24	
All-Sky Solar Radiation	RadAvg	929	1133	1495	1845	2005	2229	2220	2005	1682	1266	970	788	
	RadStd	87	149	103	139	207	186	119	118	111	166	124	79	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page