

GREENVILLE, AL, USA

WMO: 720362

Lat: 31.846N

Lon: 86.611W

Elev: 451

StdP: 14.46

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 63874

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.5	28.5	7.7	8.3	33.8	12.2	10.4	36.6	19.0	46.6	17.6	48.7	5.3	350	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	95.5	74.9	93.9	75.0	92.2	74.9	78.4	89.4	77.8	88.5	77.1	87.3	5.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.7	136.6	82.4	75.0	133.3	81.9	74.2	129.9	81.4	42.2	90.0	41.4	88.3	40.7	87.2	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	14.1	12.2	DB	19.3	97.5	3.9	2.0	16.5	98.9	14.2	100.1	12.0	101.2	9.2	102.7	(4)
(5)			WB	18.1	80.2	4.3	0.8	15.0	80.7	12.5	81.2	10.1	81.6	6.9	82.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	48.4	53.0	59.4	65.4	73.1	79.9	81.5	81.1	77.4	67.3	55.6	52.0		
	DBStd	13.81	10.74	10.14	8.55	6.30	5.36	3.29	2.87	3.10	4.80	7.98	7.85	9.09		
	HDD50	392	163	81	22	2	0	0	0	0	0	1	32	91		
	HDD65	1941	522	351	211	70	9	0	0	0	1	71	296	410		
	CDD50	6321	112	165	314	465	715	897	975	964	823	539	199	153		
	CDD65	2396	7	16	39	82	259	447	510	499	373	144	13	7		
	CDH74	22455	42	71	302	806	2438	4459	5004	4677	3297	1227	111	21		
	CDH80	9702	10	6	40	158	932	2140	2369	2180	1456	393	18	0		
(14) Wind	WSAvg	4.9	5.9	6.1	6.2	5.4	4.5	4.1	3.8	3.6	3.8	4.7	5.0	5.6		
(15) Precipitation	PrecAvg	54.3	5.4	4.4	5.9	4.2	3.2	4.8	5.5	4.3	4.3	3.6	4.9	4.2		
	PrecMax	71.4	9.4	7.8	15.3	9.5	8.1	10.6	15.3	8.1	18.1	11.7	12.5	7.5		
	PrecMin	39.6	1.7	1.4	0.4	1.2	0.0	1.5	1.4	1.5	0.6	0.2	1.3	1.9		
	PrecStd	7.6	2.0	2.0	3.4	2.1	2.0	2.6	3.3	1.8	3.9	3.0	2.8	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	80.8	83.9	86.3	93.6	97.3	97.3	97.6	95.7	91.2	82.5	76.8		
		MCWB	65.7	67.0	64.6	66.3	71.3	74.3	76.6	74.1	73.5	72.1	64.5	65.5		
	2%	DB	73.2	76.0	80.8	83.8	90.3	94.9	94.8	94.9	93.2	87.8	76.8	73.1		
		MCWB	62.8	63.6	64.4	66.2	70.8	74.4	75.9	75.7	73.7	69.7	63.4	64.4		
	5%	DB	69.1	72.2	77.6	81.8	87.8	93.0	93.0	92.8	91.0	84.4	73.7	70.3		
		MCWB	62.1	63.0	63.5	65.1	69.9	74.4	76.1	75.8	73.5	69.1	62.6	63.9		
	10%	DB	65.4	68.9	74.2	79.2	85.5	90.8	90.9	90.6	88.4	81.1	70.5	67.3		
		MCWB	59.3	60.8	61.1	64.3	69.3	74.0	75.9	75.7	73.4	68.0	60.1	62.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.7	68.4	69.2	72.3	75.0	78.4	79.5	79.9	77.9	76.0	70.6	70.0		
		MCDB	75.6	75.4	75.7	80.1	84.8	89.8	91.0	90.8	87.0	82.8	74.2	73.4		
	2%	WB	66.3	67.0	67.4	70.6	73.7	77.5	78.4	78.6	76.9	74.3	67.8	67.3		
		MCDB	70.7	73.5	74.1	77.6	84.0	89.2	89.6	89.4	86.2	81.0	74.1	70.6		
	5%	WB	63.8	65.1	65.8	69.0	72.8	76.6	77.8	77.9	76.1	72.8	65.3	65.5		
		MCDB	67.6	71.0	73.5	75.5	82.9	87.6	88.7	88.2	85.2	80.1	70.3	68.7		
	10%	WB	60.9	62.6	64.3	67.1	71.7	75.6	77.1	77.0	75.1	70.9	62.9	63.0		
		MCDB	65.1	67.6	71.8	73.8	81.1	86.0	87.3	86.6	84.0	78.2	68.4	66.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.5	21.1	22.9	23.1	22.2	20.3	18.9	18.9	20.3	22.9	24.4	19.9		
		MCDBR	22.9	21.3	24.3	25.9	25.5	23.5	21.4	21.8	23.1	25.0	26.2	21.1		
		MCWBR	14.7	11.8	11.0	11.4	9.8	7.5	6.8	7.5	8.2	10.6	15.5	15.2		
	5% WB	MCDBR	17.9	18.9	19.2	18.4	20.0	20.1	18.9	18.6	18.5	18.8	20.8	18.1		
		MCWBR	13.7	13.2	10.6	10.4	8.3	7.6	6.9	7.3	7.7	9.7	15.1	15.1		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.331	0.356	0.382	0.430	0.466	0.528	0.510	0.431	0.369	0.343	0.323		
	taud		2.535	2.512	2.440	2.364	2.268	2.222	2.055	2.106	2.306	2.456	2.475	2.540		
	Ebn at Noon		287	295	293	288	274	262	246	249	266	277	276	280		
	Edh at Noon		27	30	35	39	43	45	53	50	39	31	28	25		
(44) All-Sky Solar Radiation	RadAvg		906	1087	1465	1811	1986	1946	1884	1753	1574	1352	1027	783		
	RadStd		63	137	130	144	133	155	121	106	122	162	94	84		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)		+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+286	+189

Nomenclature: See separate page