

DRIGGS-REED, ID, USA

WMO: 720369

Lat: 43.743N

Lon: 111.098W

Elev: 1899

StdP: 80.50

Time Zone: -7.00 (NAM)

Period: 06-19

WBAN: 04135

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.9	-20.9	-26.8	0.4	-23.2	-23.8	0.6	-20.7	11.8	-0.1	9.8	-1.4	1.3	110	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	30.6	14.1	29.3	13.8	27.8	13.5	15.9	25.9	15.2	25.3	14.5	24.7	4.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.0	11.8	17.7	11.6	10.8	17.9	10.4	9.9	17.7	51.1	25.5	48.7	25.3	46.3	24.6	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.4	DB	-30.5	32.7	3.5	1.0	-33.0	33.4	-35.1	34.0	-37.1	34.6	-39.6	35.3	(4)
(5)			WB	-30.9	17.7	3.4	1.2	-33.3	18.6	-35.3	19.2	-37.2	19.9	-39.6	20.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.7	-8.1	-5.8	-1.3	3.3	8.7	13.6	18.4	17.4	12.8	5.1	-1.1	-7.2
	DBStd	10.28	5.96	5.34	5.21	4.64	4.01	3.92	2.63	2.89	4.10	4.68	5.79	5.99
	HDD10.0	2696	562	441	352	207	73	13	0	1	21	161	332	534
	HDD18.3	5037	821	674	609	452	298	146	32	49	171	410	582	792
	CDD10.0	763	0	0	1	4	33	122	259	231	104	9	0	0
	CDD18.3	63	0	0	0	0	0	6	33	21	3	0	0	0
	CDH23.3	1956	0	0	0	1	13	256	861	669	149	7	0	0
	CDH26.7	543	0	0	0	0	0	64	262	193	23	1	0	0
Wind	WSAvg	3.1	2.6	3.2	3.4	3.6	3.3	3.4	3.1	3.0	2.9	2.9	3.0	2.8
Precipitation	PrecAvg	415	37	26	29	32	50	49	32	30	38	30	31	34
	PrecMax	610	111	65	78	87	98	148	80	107	121	82	70	101
	PrecMin	257	4	4	1	5	17	2	0	0	0	0	5	4
	PrecStd	96	21	16	19	23	24	38	23	22	30	22	15	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	6.8	15.5	21.4	25.0	31.1	31.8	31.8	29.4	23.1	15.8	7.7
		MCWB	1.1	1.9	6.1	9.0	11.0	13.8	15.0	13.6	13.0	10.2	6.9	2.9
	2%	DB	2.9	4.4	12.3	18.1	22.9	28.4	30.7	30.4	26.9	19.1	12.2	4.6
		MCWB	0.2	1.1	4.7	7.7	10.6	13.6	14.5	13.6	12.1	8.5	5.3	1.4
	5%	DB	1.5	3.1	8.5	14.9	20.6	26.4	29.5	29.0	25.0	16.6	9.6	3.0
		MCWB	-0.3	0.7	3.2	6.3	9.6	12.8	14.3	13.2	11.2	7.6	3.9	0.5
	10%	DB	0.3	2.0	6.0	11.8	18.1	24.2	28.2	27.4	23.1	13.8	7.0	1.3
		MCWB	-1.2	0.0	2.2	5.0	8.9	12.4	14.0	13.0	10.8	6.4	2.7	-0.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.0	2.6	6.8	10.1	12.6	16.0	17.3	16.5	15.7	11.1	7.8	3.3
		MCDB	3.6	4.9	14.6	20.7	21.2	27.5	27.3	25.7	22.5	21.2	13.6	6.3
	2%	WB	0.9	1.7	5.2	8.2	11.2	14.6	16.3	15.4	14.0	9.5	6.0	2.0
		MCDB	2.4	3.8	11.3	16.4	20.9	25.7	26.4	24.8	22.2	17.5	10.9	4.1
	5%	WB	0.0	1.0	3.7	6.7	10.2	13.6	15.5	14.7	12.7	8.1	4.5	0.7
		MCDB	1.4	2.7	7.9	13.7	19.5	24.1	26.0	24.5	21.8	14.6	8.9	2.2
	10%	WB	-1.1	0.3	2.3	5.4	9.2	12.7	14.9	13.9	11.5	6.9	3.1	-0.3
		MCDB	0.1	2.0	5.7	11.0	17.3	22.7	25.4	24.2	20.3	13.0	6.3	1.4
Mean Daily Temperature Range	5% DB	MDBR	11.6	10.5	11.0	11.7	13.5	15.7	18.1	17.9	16.2	13.1	11.2	10.7
		MCDBR	9.4	8.9	13.0	16.9	18.5	20.6	20.2	20.7	20.1	17.9	14.0	9.4
		MCWBR	7.5	6.8	7.4	8.6	8.7	9.2	8.4	8.2	8.7	9.3	7.9	6.6
	5% WB	MCDBR	8.3	7.7	12.0	15.5	16.6	18.6	18.3	17.7	16.0	15.2	12.3	8.2
		MCWBR	6.9	6.1	6.8	8.2	8.2	8.7	8.2	7.7	7.1	8.2	7.2	6.3
Clear-Sky Solar Irradiance	taub	0.231	0.242	0.258	0.292	0.301	0.306	0.319	0.325	0.296	0.276	0.250	0.231	
	taud	2.359	2.326	2.366	2.408	2.516	2.540	2.524	2.481	2.566	2.586	2.519	2.402	
	Ebn at Noon	923	970	992	975	970	962	945	930	940	923	900	892	
	Edh at Noon	76	95	105	110	103	101	101	102	86	74	65	66	
All-Sky Solar Radiation	RadAvg	1.71	2.60	3.86	5.13	5.94	7.04	7.37	6.24	4.83	3.06	1.85	1.33	
	RadStd	0.19	0.32	0.34	0.42	0.62	0.62	0.37	0.35	0.41	0.26	0.20	0.17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page