

PIERCE COUNTY AP, WA, USA

WMO: 720388

Lat: 47.104N

Lon: 122.287W

Elev: 164

StdP: 99.37

Time Zone: -8.00 (NAP)

Period: 07-19

WBAN: 00469

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.0	-4.1	-10.3	1.6	-3.8	-7.2	2.1	-2.1	7.2	9.7	6.0	9.0	0.0	10	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	31.3	19.3	29.0	18.5	27.3	17.8	20.2	28.5	19.2	26.9	18.4	25.4	1.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.8	20.9	17.1	12.5	20.6	16.2	11.7	19.8	58.1	28.7	55.1	26.8	52.6	25.1	23.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.5	4.7	3.9	DB	-10.2	35.1	2.0	2.7	-11.7	37.1	-12.8	38.7	-13.9	40.2	-15.4	42.1	(4)
(5)			WB	-10.4	21.9	2.0	0.9	-11.9	22.5	-13.0	23.1	-14.2	23.6	-15.6	24.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	4.7	5.3	7.2	9.4	13.0	15.6	18.6	19.0	15.6	10.5	7.1	4.0	(6)	
	DBStd	6.00	3.51	3.38	2.70	2.66	2.95	2.87	2.57	2.49	2.76	2.63	3.69	3.82	(7)	
	HDD10.0	753	166	134	95	41	5	0	0	0	1	25	100	187	(8)	
	HDD18.3	2822	423	366	346	267	166	93	27	22	89	242	338	443	(9)	
	CDD10.0	1069	2	2	7	23	99	167	267	278	168	42	12	2	(10)	
	CDD18.3	96	0	0	0	0	1	11	35	42	7	0	0	0	(11)	
	CDH23.3	1576	0	0	2	16	82	188	574	584	129	1	0	0	(12)	
	CDH26.7	529	0	0	0	3	16	63	204	212	31	0	0	0	(13)	
(14) Wind	WSAvg	0.9	0.9	1.0	1.3	1.2	0.9	0.8	0.7	0.7	0.6	0.6	1.0	0.9	(14)	
(15) Precipitation	PrecAvg	1062	150	102	114	86	62	47	18	26	44	102	165	147	(15)	
	PrecMax	1443	312	218	228	188	109	100	48	94	197	244	365	293	(16)	
	PrecMin	793	60	4	39	25	7	8	1	1	3	19	42	31	(17)	
	PrecStd	169	58	51	44	41	28	24	12	23	40	50	78	65	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	16.1	21.3	25.9	28.7	31.4	34.0	33.7	30.1	22.0	18.0	15.0	(19)	
		MCWB	10.7	10.4	12.7	15.5	16.2	19.8	19.4	19.3	19.0	15.3	14.2	11.3	(20)	
	2%	DB	12.6	13.7	17.1	21.1	25.9	28.6	31.4	32.0	27.1	18.9	16.0	12.5	(21)	
		MCWB	9.9	9.8	10.7	13.5	16.1	18.8	19.0	19.5	17.8	14.0	12.8	10.2	(22)	
	5%	DB	11.3	12.3	14.0	17.5	22.8	25.0	28.9	28.9	24.0	17.3	13.9	11.0	(23)	
		MCWB	9.4	9.2	9.6	11.1	15.0	16.7	18.4	18.8	16.8	13.0	11.7	9.5	(24)	
	10%	DB	9.9	10.9	12.4	15.0	20.0	22.5	27.0	27.1	22.2	15.9	12.5	9.0	(25)	
		MCWB	8.7	9.1	9.0	9.9	14.3	15.7	17.7	17.9	16.0	12.9	10.9	8.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.4	12.6	13.4	16.1	18.6	20.7	21.9	21.1	20.4	17.1	15.5	12.7	(27)	
		MCDB	13.6	14.3	16.1	24.3	26.4	29.6	31.7	30.5	27.4	18.9	17.7	13.7	(28)	
	2%	WB	11.0	11.2	11.8	13.7	17.0	19.2	20.0	20.0	18.9	15.4	13.6	11.2	(29)	
		MCDB	11.8	12.5	15.1	19.3	23.5	26.4	28.4	28.7	24.5	17.1	15.2	12.3	(30)	
	5%	WB	9.7	10.0	10.7	12.2	15.7	17.5	19.0	19.1	17.8	14.2	12.3	9.2	(31)	
		MCDB	10.5	11.2	13.5	15.7	21.6	22.8	26.8	27.0	21.5	16.0	13.7	10.0	(32)	
	10%	WB	8.4	8.8	9.7	10.9	14.5	16.4	18.1	18.4	16.9	13.0	11.2	8.0	(33)	
		MCDB	9.2	10.0	12.1	13.8	19.2	22.0	25.1	25.4	20.2	14.9	12.4	8.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	8.0	9.5	10.0	11.3	11.3	13.8	13.4	11.6	9.8	8.1	6.6	(35)	
		MCDBR	8.7	11.1	13.2	15.9	17.6	17.1	18.9	18.4	16.3	12.4	9.3	7.4	(36)	
	5% WB	MCWBR	5.9	7.1	7.6	8.2	8.6	7.5	7.2	7.0	7.7	7.7	6.4	5.1	(37)	
		MCWBR	6.9	8.0	11.0	13.2	15.0	15.2	16.3	16.2	13.2	9.8	8.3	6.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.319	0.315	0.323	0.358	0.374	0.367	0.349	0.356	0.344	0.327	0.319	0.328	(40)	
		taud	2.465	2.500	2.514	2.398	2.379	2.424	2.493	2.480	2.509	2.561	2.521	2.373	(41)	
	Ebn at Noon		769	860	907	897	890	897	909	889	871	836	766	697	(42)	
		Edh at Noon	67	78	89	110	116	112	103	100	89	73	63	65	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.05	1.92	2.87	4.22	5.30	5.85	6.53	5.57	4.09	2.34	1.24	0.86	(44)	
	RadStd		0.15	0.26	0.33	0.38	0.43	0.55	0.47	0.38	0.36	0.26	0.16	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page