

HOMERVILLE, GA, USA

WMO: 720392

Lat: 31.056N

Lon: 82.767W

Elev: 188

StdP: 14.60

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 00128

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.7	30.3	16.0	12.4	36.8	20.7	15.6	37.5	20.2	50.5	18.6	52.4	2.6	320	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	95.5	77.1	94.6	77.0	91.4	76.1	81.3	88.7	80.2	88.1	79.1	87.3	5.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.3	153.3	83.6	78.6	149.5	83.1	77.2	142.4	82.2	44.8	88.3	43.8	88.8	42.7	87.0	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	13.3	11.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.8	50.5	55.0	60.6	67.5	74.5	80.3	81.9	81.7	78.0	68.9	58.5	55.5
	DBStd	12.93	9.56	9.02	8.42	6.00	5.13	3.70	2.86	2.71	3.91	6.89	8.19	9.43
	HDD50	244	113	46	16	0	0	0	0	0	0	1	17	51
	HDD65	1570	455	295	186	42	4	0	0	0	0	43	228	317
	CDD50	6748	129	187	343	525	761	910	989	984	839	587	271	223
	CDD65	2599	5	16	48	117	300	460	524	519	389	165	32	24
	CDH74	24575	49	136	451	1206	2885	4636	5235	4957	3371	1284	252	113
	CDH80	10511	1	11	87	331	1196	2280	2514	2255	1429	362	35	10
(14) Wind	WSAvg	3.9	4.4	4.7	5.0	4.6	4.1	3.7	3.4	3.2	2.9	3.4	3.4	3.9
(15) Precipitation	PrecAvg	49.9	4.8	3.8	4.8	2.6	2.6	5.9	5.9	5.4	4.6	3.4	2.4	2.9
	PrecMax	66.1	16.9	7.8	10.2	5.4	6.0	10.6	8.2	9.2	15.9	10.1	7.1	4.8
	PrecMin	34.3	0.7	0.9	0.0	0.3	0.6	1.5	2.5	2.7	0.7	0.3	0.3	0.9
	PrecStd	9.3	3.6	1.7	3.0	1.4	1.4	2.4	1.3	1.7	3.7	2.9	1.8	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.1	81.5	86.0	90.0	94.9	98.8	97.4	97.2	95.1	90.1	83.9	81.4
		MCWB	68.2	66.9	66.4	70.8	71.1	76.6	77.8	77.9	74.7	73.1	73.9	71.5
	2%	DB	73.4	78.7	82.1	86.5	91.0	95.5	95.3	94.9	91.3	86.5	80.6	77.2
		MCWB	64.9	65.4	66.6	68.7	70.8	76.8	78.1	78.3	74.9	72.6	69.2	68.1
	5%	DB	70.1	74.7	79.3	83.8	89.8	93.2	93.3	92.6	90.3	83.9	77.0	73.1
		MCWB	63.6	63.9	65.2	67.7	70.8	75.9	77.6	78.3	74.9	71.0	66.9	67.8
	10%	DB	66.1	71.5	75.3	81.2	87.5	90.9	91.0	90.5	88.2	81.4	73.0	71.7
		MCWB	61.5	62.7	63.7	66.4	71.4	75.5	77.1	77.7	75.1	70.1	65.6	67.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.4	70.3	71.8	74.8	76.4	81.7	83.5	84.9	80.5	77.1	77.1	73.9
		MCDB	74.8	75.6	79.5	83.5	85.4	89.0	90.0	86.8	86.0	83.0	81.9	78.0
	2%	WB	68.2	68.4	69.9	72.7	75.3	80.1	81.2	81.3	78.9	75.5	73.4	72.1
		MCDB	72.3	74.7	76.3	80.8	84.2	88.7	89.3	88.6	85.6	82.2	75.9	75.1
	5%	WB	65.4	66.3	68.4	70.9	74.3	78.7	79.8	80.2	78.0	74.2	70.3	69.9
		MCDB	70.0	73.1	75.1	78.5	83.2	87.9	88.6	87.8	84.9	80.3	74.3	72.3
	10%	WB	62.7	63.8	66.4	69.3	73.1	77.7	78.6	79.2	77.0	72.7	67.1	67.1
		MCDB	65.1	67.2	73.3	76.1	81.9	86.9	87.4	86.9	84.1	78.2	72.8	70.7
(35) Mean Daily Temperature Range	5% DB	MDBR	21.7	23.1	23.7	24.0	22.7	20.7	19.6	18.3	19.4	22.3	24.9	21.5
		MCDBR	24.6	25.1	26.6	26.9	25.4	23.7	21.8	20.7	22.1	24.0	25.4	22.1
		MCWBR	16.1	13.8	12.4	10.3	8.0	7.4	7.0	7.2	7.6	10.4	14.1	14.4
	5% WB	MCDBR	21.3	21.0	20.6	20.6	20.1	20.7	19.7	18.2	17.4	18.0	18.7	18.4
		MCWBR	16.1	13.6	11.0	10.0	7.8	7.9	7.3	7.4	7.0	8.7	11.9	13.4
(40) Clear-Sky Solar Irradiance	taub		0.328	0.334	0.370	0.388	0.428	0.473	0.509	0.499	0.428	0.379	0.348	0.332
	taud		2.521	2.504	2.419	2.361	2.283	2.226	2.123	2.154	2.344	2.453	2.487	2.534
	Ebn at Noon		286	295	289	287	274	261	251	252	267	275	276	279
	Edh at Noon		28	31	36	39	43	45	50	48	38	32	28	26
(44) All-Sky Solar Radiation	RadAvg		973	1163	1525	1859	2032	1912	1906	1736	1536	1347	1080	854
	RadStd		62	135	135	139	121	128	118	115	124	125	74	75

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	+0.88	+1.33	N/A	N/A	N/A	N/A	N/A	-40	-140	+302	+205

Nomenclature: See separate page