

PLEASANTON, TX, USA

WMO: 720395

Lat: 28.950N

Lon: 98.517W

Elev: 430

StdP: 14.47

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 00130

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.3	33.0	9.9	9.3	50.7	15.9	12.5	46.2	20.9	62.1	18.7	60.6	2.9	20	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	24.0	101.7	73.0	99.8	72.6	98.4	72.7	78.4	85.5	77.5	86.3	77.0	85.9	8.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	143.3	79.1	75.5	135.5	79.6	74.9	133.1	79.5	42.2	87.1	41.2	85.2	40.6	85.7	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.4	16.5	14.7	DB	24.3	104.3	3.8	1.9	21.5	105.7	19.3	106.9	17.1	108.0	14.3	109.4
			WB	21.7	79.2	3.7	1.1	19.0	80.0	16.9	80.6	14.9	81.2	12.2	82.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.9	52.9	58.6	64.4	70.7	77.9	83.5	85.1	86.4	81.0	72.4	62.4	55.2
	DBStd	13.59	8.97	10.04	8.88	6.77	5.92	3.44	2.93	2.96	4.55	7.83	9.49	9.14
	HDD50	176	72	31	10	0	0	0	0	0	0	0	15	48
	HDD65	1278	387	226	122	25	2	0	0	0	0	29	158	329
	CDD50	7820	162	273	457	621	864	1006	1089	1128	930	695	387	208
	CDD65	3447	12	48	104	196	401	556	624	663	480	258	81	24
	CDH74	38283	121	379	821	1736	4002	6445	7619	8569	5114	2648	642	187
	CDH80	19259	14	101	223	604	1792	3381	4263	5015	2600	1079	157	30
(14) Wind	WSAvg	5.9	5.2	6.1	6.7	7.0	7.5	6.8	6.3	5.8	4.6	5.0	4.8	5.0
(15) Precipitation	PrecAvg	29.4	1.7	1.7	2.2	2.4	2.7	3.4	3.3	2.1	3.2	2.6	2.2	1.7
	PrecMax	52.3	4.7	6.1	8.9	6.7	6.5	10.8	13.6	8.4	9.3	7.2	7.2	10.0
	PrecMin	13.7	0.0	0.1	0.0	0.2	0.1	0.1	0.3	0.1	0.4	0.1	0.0	0.2
	PrecStd	9.7	1.5	1.8	1.8	1.9	2.0	3.0	3.8	2.0	2.1	2.0	2.0	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.7	88.6	89.8	95.0	99.3	102.1	102.7	104.2	100.3	94.3	88.5	83.6
		MCWB	62.7	63.7	63.4	68.0	72.8	73.4	72.7	72.6	70.8	71.7	69.8	64.9
	2%	DB	77.5	82.5	85.5	89.7	95.2	99.3	100.4	102.1	97.5	91.3	84.2	79.5
		MCWB	60.5	63.8	65.8	67.5	73.0	72.6	72.6	73.2	71.9	72.0	67.3	64.2
	5%	DB	73.0	79.0	82.0	86.3	92.1	97.0	99.1	100.3	94.9	89.6	81.3	74.9
		MCWB	58.7	63.0	65.3	68.4	72.5	73.1	72.6	73.0	72.0	71.2	66.6	64.0
	10%	DB	69.3	74.5	79.0	83.2	89.6	94.5	96.8	98.8	92.3	86.5	77.3	71.6
		MCWB	58.6	63.1	64.0	67.6	72.2	73.7	73.2	73.0	72.3	69.5	65.5	63.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.8	70.4	72.2	75.9	79.1	79.3	79.1	80.5	78.3	78.0	73.5	72.1
		MCDB	73.4	76.7	78.4	82.8	84.0	87.2	83.9	83.0	84.0	85.0	80.9	76.5
	2%	WB	66.1	69.2	70.4	73.9	77.4	77.9	77.7	78.0	77.1	76.3	72.1	69.7
		MCDB	72.7	74.7	77.0	81.0	86.8	86.4	86.4	86.0	85.0	83.1	78.0	74.4
	5%	WB	63.7	67.8	69.1	72.5	76.4	77.1	77.0	77.2	76.3	75.0	70.5	67.6
		MCDB	69.1	73.4	75.5	79.7	84.9	85.9	86.4	86.5	84.8	81.9	76.2	72.7
	10%	WB	60.8	66.1	68.0	71.2	75.2	76.4	76.3	76.5	75.5	73.8	68.7	64.5
		MCDB	66.8	71.9	74.8	78.4	82.9	85.2	85.8	86.1	84.6	81.6	75.0	69.3
(35) Mean Daily Temperature Range	5% DB	MDBR	23.9	22.5	23.4	23.2	21.4	21.2	22.7	24.0	22.2	24.5	23.0	22.2
		MCDBR	30.4	28.4	25.8	25.8	24.1	24.9	26.2	26.8	25.3	24.1	24.6	27.5
		MCWBR	16.7	13.8	10.9	10.1	6.9	5.5	4.9	5.1	6.4	7.9	11.6	15.5
	5% WB	MCDBR	22.6	20.5	20.3	18.6	18.6	19.9	21.1	22.7	20.0	18.7	19.6	20.2
		MCWBR	14.9	11.7	10.3	9.5	7.3	5.9	5.2	5.0	5.8	8.3	10.1	13.7
(40) Clear-Sky Solar Irradiance	taub		0.334	0.341	0.365	0.410	0.451	0.432	0.438	0.425	0.415	0.376	0.361	0.326
	taud		2.477	2.463	2.410	2.301	2.231	2.340	2.354	2.374	2.357	2.451	2.432	2.516
	Ebn at Noon		287	294	293	281	269	272	270	273	273	279	274	285
	Edh at Noon		30	32	36	42	45	40	40	39	38	33	31	27
(44) All-Sky Solar Radiation	RadAvg		960	1132	1433	1695	1852	2104	2108	2025	1663	1393	1047	858
	RadStd		110	205	156	172	185	125	184	109	164	177	116	118

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+198	+173

Nomenclature: See separate page