

PLEASANTON, TX, USA

WMO: 720395

Lat: 28.950N

Lon: 98.517W

Elev: 131

StdP: 99.76

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 00130

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	0.5	-12.3	1.3	10.4	-9.0	1.8	7.9	9.3	16.7	8.4	15.9	1.3	20	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.3	38.7	22.8	37.7	22.6	36.9	22.6	25.8	29.7	25.3	30.2	25.0	30.0	3.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.5	26.2	24.1	19.4	26.4	23.9	19.0	26.4	80.2	30.6	78.0	29.6	76.6	29.8	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.4	6.6	-4.3	40.2	2.1	1.1	-5.8	41.0	-7.1	41.6	-8.3	42.2	-9.8	43.0		
			-5.7	26.2	2.0	0.6	-7.2	26.6	-8.4	27.0	-9.5	27.3	-11.0	27.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.6	11.6	14.8	18.0	21.5	25.5	28.6	29.5	30.2	27.2	22.5	16.9	12.9
	DBStd	7.55	4.98	5.58	4.94	3.76	3.29	1.91	1.63	1.64	2.53	4.35	5.27	5.08
	HDD10.0	98	40	17	6	0	0	0	0	0	0	8	27	
	HDD18.3	710	215	126	68	14	1	0	0	0	16	88	183	
	CDD10.0	4344	90	152	254	345	480	559	605	627	517	386	215	116
	CDD18.3	1915	7	27	58	109	223	309	347	368	267	143	45	13
	CDH23.3	21268	67	211	456	964	2223	3581	4233	4761	2841	1471	357	104
	CDH26.7	10699	8	56	124	336	996	1878	2368	2786	1444	599	87	17
Wind	WSAvg	2.6	2.3	2.7	3.0	3.1	3.4	3.0	2.8	2.6	2.0	2.2	2.1	2.2
Precipitation	PrecAvg	746	42	43	57	62	69	87	84	54	81	66	55	43
	PrecMax	1329	120	155	226	169	166	275	346	214	236	184	182	254
	PrecMin	349	0	2	0	6	2	2	7	3	11	2	1	6
	PrecStd	246	38	45	45	48	51	75	97	51	54	51	52	54
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.6	31.5	32.1	35.0	37.4	38.9	39.3	40.1	38.0	34.6	31.4	28.7
		MCWB	17.1	17.6	17.4	20.0	22.7	23.0	22.6	22.6	21.6	22.1	21.0	18.3
	2%	DB	25.3	28.0	29.7	32.0	35.1	37.4	38.0	39.0	36.4	32.9	29.0	26.4
		MCWB	15.9	17.7	18.8	19.7	22.8	22.5	22.6	22.9	22.1	22.2	19.6	17.9
	5%	DB	22.8	26.1	27.8	30.1	33.4	36.1	37.3	37.9	34.9	32.0	27.4	23.8
		MCWB	14.8	17.2	18.5	20.2	22.5	22.8	22.6	22.8	22.2	21.8	19.2	17.8
	10%	DB	20.7	23.6	26.1	28.4	32.0	34.7	36.0	37.1	33.5	30.3	25.2	22.0
		MCWB	14.8	17.3	17.8	19.8	22.3	23.1	22.9	22.8	22.4	20.8	18.6	17.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.9	21.3	22.3	24.4	26.2	26.3	26.1	27.0	25.7	25.5	23.1	22.3
		MCDB	23.0	24.9	25.8	28.2	28.9	30.7	28.8	28.3	28.9	29.4	27.2	24.7
	2%	WB	18.9	20.7	21.3	23.3	25.2	25.5	25.4	25.6	25.0	24.6	22.3	20.9
		MCDB	22.6	23.7	25.0	27.2	30.5	30.2	30.2	30.0	29.4	28.4	25.6	23.5
	5%	WB	17.6	19.9	20.6	22.5	24.7	25.1	25.0	25.1	24.6	23.9	21.4	19.8
		MCDB	20.6	23.0	24.2	26.5	29.4	29.9	30.2	30.3	29.3	27.7	24.5	22.6
	10%	WB	16.0	18.9	20.0	21.8	24.0	24.7	24.6	24.7	24.2	23.2	20.4	18.1
		MCDB	19.3	22.2	23.8	25.8	28.3	29.6	29.9	30.1	29.2	27.6	23.9	20.7
Mean Daily Temperature Range	5% DB	MDBR	13.3	12.5	13.0	12.9	11.9	11.8	12.6	13.3	12.3	13.6	12.8	12.3
		MCDBR	16.9	15.8	14.4	14.3	13.4	13.9	14.6	14.9	14.1	13.4	13.7	15.3
		MCWBR	9.3	7.6	6.1	5.6	3.8	3.1	2.7	2.8	3.5	4.4	6.4	8.6
	5% WB	MCDBR	12.5	11.4	11.3	10.3	10.3	11.1	11.7	12.6	11.1	10.4	10.9	11.2
	MCWBR	8.3	6.5	5.7	5.3	4.0	3.3	2.9	2.8	3.2	4.6	5.6	7.6	
Clear-Sky Solar Irradiance	taub	0.334	0.341	0.365	0.410	0.451	0.432	0.438	0.425	0.415	0.376	0.361	0.326	
	taud	2.477	2.463	2.410	2.301	2.231	2.340	2.354	2.374	2.357	2.451	2.432	2.516	
	Ebn at Noon	905	928	923	887	847	858	852	862	861	878	865	898	
	Edh at Noon	93	102	115	132	142	127	125	122	120	103	97	86	
All-Sky Solar Radiation	RadAvg	3.03	3.57	4.52	5.34	5.84	6.63	6.65	6.38	5.24	4.39	3.30	2.71	
	RadStd	0.35	0.65	0.49	0.54	0.58	0.39	0.58	0.34	0.52	0.56	0.36	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	+96

Nomenclature: See separate page