

TALLADEGA 10 NNE, AL, USA

WMO: 720504

Lat: 33.5721N

Lon: 86.0573W

Elev: 525

StdP: 14.42

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 73803

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.7	23.6	N/A	N/A	N/A	N/A	N/A	N/A	17.7	47.1	16.4	47.4	4.0	340	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	94.8	N/A	92.8	N/A	91.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.3	340

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.5	14.5	12.8	13.1	97.5	5.8	3.3	8.9	99.8	5.5	101.7	2.2	103.6	-2.0	105.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.8	42.6	47.9	54.6	62.6	70.5	77.8	79.9	79.2	74.8	63.4	51.9	47.3
	DBStd	15.03	10.63	10.00	9.03	6.65	6.15	3.42	3.19	3.54	5.42	8.07	8.26	9.61
	HDD50	742	281	147	59	2	0	0	0	0	0	5	73	175
	HDD65	2750	695	482	337	122	29	0	0	0	4	127	401	553
	CDD50	5407	52	89	200	380	635	834	927	905	745	421	129	90
	CDD65	1939	0	4	14	50	199	384	462	440	299	78	6	3
	CDH74	18131	0	20	120	571	1803	3590	4454	4100	2661	770	38	4
Wind	WSAvg	5.2	5.8	6.3	6.6	6.1	5.1	4.6	4.4	4.4	4.2	4.9	4.7	5.5
	PrecAvg	55.2	5.2	5.3	5.8	4.8	4.2	4.5	5.1	4.0	3.8	2.9	4.3	5.2
	PrecMax	74.1	8.7	9.8	9.3	9.0	13.3	10.7	9.7	8.7	8.8	9.8	10.5	9.8
	PrecMin	29.3	2.3	2.5	1.8	1.5	0.6	2.1	1.3	0.6	0.6	0.1	1.3	2.1
	PrecStd	9.1	1.9	1.8	1.8	1.9	2.6	2.2	2.2	1.7	2.4	2.2	2.0	1.9
	DB	72.2	77.3	81.6	85.9	91.8	96.4	96.4	96.4	96.0	90.6	78.6	73.8	
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	67.6	71.7	77.4	82.8	88.8	93.2	94.0	94.1	93.1	85.4	73.5	70.8	
	2% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% DB	63.9	68.5	73.9	80.4	86.3	91.1	91.8	91.8	90.4	82.0	70.6	67.7	
	5% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10% DB	60.4	65.2	70.3	77.6	83.8	88.7	89.8	89.4	87.1	78.2	67.6	64.0	
	10% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	MDBR	20.9	21.4	22.2	24.3	21.7	20.3	19.2	19.5	21.4	23.9	24.4	19.3	
	5% DB	22.9	24.3	25.2	27.5	25.4	23.8	22.0	23.2	26.2	26.9	26.0	20.8	
	5% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.321	0.325	0.362	0.395	0.468	0.487	0.536	0.536	0.434	0.374	0.345	0.324	
	taud	2.510	2.495	2.412	2.306	2.141	2.134	2.014	1.999	2.279	2.433	2.453	2.516	
	Ebn at Noon	284	294	290	283	263	257	243	241	263	273	272	276	
	Edh at Noon	27	30	36	41	49	49	55	55	40	32	28	25	
All-Sky Solar Radiation	RadAvg	836	1002	1362	1745	1904	1941	1875	1732	1514	1271	942	712	
	RadStd	58	130	123	118	157	151	127	97	140	166	100	74	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (50 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+284	+203

Nomenclature: See separate page