

TALLADEGA 10 NNE, AL, USA

WMO: 720504

Lat: 33.5721N

Lon: 86.0573W

Elev: 160

StdP: 99.42

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 73803

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.9	(c) -4.6	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 7.9	(k) 8.4	(l) 7.3	(m) 8.5	(n) 1.8	(o) 340	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.7	(c) 34.9	(d) N/A	(e) 33.8	(f) N/A	(g) 32.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.3	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.4	(b) 6.5	(c) 5.7	(e) -10.5	(f) 36.4	(g) 3.2	(h) 1.8	(i) -12.8	(j) 37.7	(k) -14.7	(l) 38.7	(m) -16.5	(n) 39.8	(o) -18.9	(p) 41.1		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.1	5.9	8.9	12.5	17.0	21.4	25.4	26.6	26.2	23.8	17.5	11.0	8.5
	DBStd	8.35	5.91	5.55	5.02	3.70	3.42	1.90	1.77	1.97	3.01	4.48	4.59	5.34
	HDD10.0	412	156	82	33	1	0	0	0	0	0	3	41	97
	HDD18.3	1528	386	268	187	68	16	0	0	0	2	71	223	307
	CDD10.0	3004	29	49	111	211	353	463	515	503	414	234	72	50
	CDD18.3	1077	0	2	8	28	111	213	257	244	166	43	3	2
	CDH23.3	10073	0	11	67	317	1002	1994	2474	2278	1478	428	21	2
	CDH26.7	4241	0	0	6	54	346	887	1136	1041	646	122	3	0
(14) Wind	WSAvg	2.3	2.6	2.8	2.9	2.7	2.3	2.1	2.0	2.0	1.9	2.2	2.1	2.4
(15) Precipitation	PrecAvg	1401	133	135	148	121	106	114	129	102	97	74	110	131
	PrecMax	1882	220	248	237	228	337	272	246	220	224	250	267	250
	PrecMin	745	58	64	46	38	16	53	33	14	15	2	33	54
	PrecStd	232	47	46	45	48	65	56	55	43	62	57	51	48
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.3	25.1	27.5	30.0	33.2	35.8	35.8	35.8	35.5	32.5	25.9	23.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	19.8	22.1	25.2	28.2	31.6	34.0	34.4	34.5	34.0	29.7	23.1	21.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	17.7	20.3	23.3	26.9	30.2	32.8	33.2	33.2	32.5	27.8	21.4	19.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	15.8	18.4	21.3	25.3	28.8	31.5	32.1	31.9	30.6	25.7	19.8	17.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	11.9	12.3	13.5	12.1	11.3	10.7	10.8	11.9	13.3	13.6	10.7
		MCDBR	12.7	13.5	14.0	15.3	14.1	13.2	12.2	12.9	14.5	14.9	14.5	11.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.321	0.325	0.362	0.395	0.468	0.487	0.536	0.536	0.434	0.374	0.345	0.324
	taud		2.510	2.495	2.412	2.306	2.141	2.134	2.014	1.999	2.279	2.433	2.453	2.516
	Ebn at Noon		894	928	914	893	828	809	767	759	829	860	856	869
	Edh at Noon		85	95	112	130	155	155	174	174	126	100	89	80
(44) All-Sky Solar Radiation	RadAvg		2.64	3.16	4.29	5.50	6.00	6.12	5.91	5.46	4.77	4.01	2.97	2.24
	RadStd		0.18	0.41	0.39	0.37	0.49	0.47	0.40	0.31	0.44	0.52	0.32	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (50 neighbors)	+0.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+158	+113

Nomenclature: See separate page