

STEVENS FIELD, CO, USA

WMO: 720539

Lat: 37.283N

Lon: 107.050W

Elev: 7661

StdP: 11.06

Time Zone: -7.00 (NAM)

Period: 09-19

WBAN: 00165

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 0.9	(c) 6.0	(d) -9.5	(e) 4.4	(f) 29.6	(g) -5.9	(h) 5.3	(i) 32.5	(j) 18.6	(k) 31.3	(l) 15.7	(m) 31.0	(n) 0.2	(o) 300	(p) 0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.2	86.0	52.4	83.6	52.4	81.4	51.9	58.5	67.8	57.4	68.3	56.6	68.7	9.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.7	91.6	59.8	54.8	85.5	59.2	53.3	80.7	59.0	29.1	67.3	28.3	67.8	27.6	68.2	63.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	16.5	13.2	-7.9	89.8	5.1	1.6	-11.6	91.0	-14.6	91.9	-17.5	92.8	-21.2	94.0
			-8.5	61.1	4.8	1.1	-11.9	61.9	-14.7	62.5	-17.4	63.2	-20.9	64.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.6	25.7	28.9	37.2	43.4	50.0	62.2	66.8	64.3	58.3	46.4	35.8	27.6
	DBStd	15.46	7.42	7.86	6.62	5.93	6.16	4.52	3.09	2.91	5.13	6.28	6.87	7.45
	HDD50	3293	755	592	396	206	78	0	0	0	6	141	426	693
	HDD65	7196	1220	1012	861	648	466	107	18	47	207	577	875	1158
	CDD50	1699	0	0	0	7	77	367	522	442	255	29	0	0
	CDD65	129	0	0	0	0	0	24	75	24	6	0	0	0
	CDH74	3433	0	0	0	1	36	1123	1218	781	271	3	0	0
	CDH80	751	0	0	0	0	0	287	304	133	27	0	0	0
(14) Wind	WSAvg	3.3	1.7	2.8	3.7	5.1	5.1	4.6	3.6	3.2	3.2	3.0	2.3	1.8
(15) Precipitation	PrecAvg	21.0	1.7	1.5	1.7	1.5	1.3	0.9	2.2	2.8	2.3	2.0	1.5	1.6
	PrecMax	27.0	4.5	4.1	3.9	3.9	3.4	2.3	4.3	5.6	4.4	4.8	3.1	5.2
	PrecMin	14.2	0.4	0.4	0.2	0.6	0.2	0.1	0.2	1.0	0.7	0.1	0.0	0.4
	PrecStd	2.9	1.1	0.8	0.9	0.9	0.9	0.6	0.9	1.0	1.1	1.2	0.8	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	54.9	65.2	71.9	77.9	89.1	88.2	86.3	82.9	72.9	62.0	52.3
		MCWB	35.7	38.2	41.5	44.4	46.6	52.0	53.5	52.5	53.2	46.9	41.4	35.7
	2%	DB	45.3	51.4	61.1	66.5	74.2	86.3	85.8	83.3	80.5	68.4	58.6	47.7
		MCWB	32.7	36.3	39.9	42.3	45.3	51.1	53.5	52.6	51.6	45.5	40.1	33.8
	5%	DB	41.7	47.6	56.7	63.4	71.5	83.4	83.6	81.3	77.4	65.7	54.9	44.0
		MCWB	30.7	35.1	38.0	41.2	44.3	50.4	53.6	52.7	50.3	44.2	38.3	32.6
	10%	DB	38.2	43.0	52.7	60.1	68.3	80.8	81.3	79.0	74.2	62.8	50.3	39.6
		MCWB	30.1	32.5	36.2	39.8	43.6	48.9	53.8	52.9	49.3	43.4	36.4	31.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.5	39.5	42.5	46.4	49.9	57.1	60.3	60.0	57.1	53.6	44.2	38.4
		MCDB	44.5	51.6	58.7	62.8	67.5	68.6	68.0	66.5	66.7	59.2	51.2	45.3
	2%	WB	35.1	37.3	41.0	44.4	47.7	54.9	58.9	58.6	55.6	49.9	41.9	36.2
		MCDB	38.9	46.7	57.6	61.1	65.8	72.1	68.0	67.3	66.4	58.3	53.4	42.2
	5%	WB	33.7	35.5	39.1	42.6	46.1	53.3	57.8	57.4	54.5	47.6	39.5	34.5
		MCDB	37.0	45.0	54.2	58.5	65.0	75.1	68.7	67.3	65.8	57.7	52.5	39.4
	10%	WB	32.3	33.7	37.1	41.1	44.8	51.9	57.0	56.4	53.1	45.5	37.5	32.7
		MCDB	36.6	41.0	49.4	56.6	63.9	74.2	69.4	67.5	65.4	58.3	49.2	37.5
(35) Mean Daily Temperature Range	MDBR		24.4	24.0	25.9	27.0	28.7	34.8	29.2	28.8	29.2	27.7	24.5	21.7
	5% DB	MCDBR	29.6	28.5	31.7	33.5	35.3	38.0	33.0	33.9	34.0	33.1	31.2	27.1
		MCWBR	18.5	15.0	14.5	14.6	13.8	12.7	9.4	10.4	11.6	14.2	15.3	15.5
	5% WB	MCDBR	19.8	25.4	28.9	29.7	30.6	32.1	25.9	24.0	23.8	25.3	27.3	19.6
		MCWBR	12.9	14.1	13.3	13.7	12.2	11.2	7.7	8.0	9.3	11.4	13.6	12.2
(40) Clear-Sky Solar Irradiance	taub		0.224	0.229	0.254	0.281	0.298	0.294	0.347	0.324	0.282	0.259	0.245	0.230
	taud		2.547	2.556	2.530	2.512	2.523	2.536	2.444	2.477	2.638	2.668	2.596	2.554
	Ebn at Noon		318	327	325	318	311	311	294	299	311	312	306	308
	Edh at Noon		23	26	30	33	33	33	36	34	27	23	22	22
(44) All-Sky Solar Radiation	RadAvg		947	1234	1662	1995	2234	2458	2073	1889	1714	1352	1018	812
	RadStd		66	89	117	113	180	147	129	94	94	108	72	56

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page